



## Results Report

Order ID: 7062809

Karl Environmental Group  
20 Lauck Road  
Mohnton, PA 19540

Project: Allendale, NJ BOE - Hillside School  
89 Hillside Avenue  
Allendale, NJ

Attn: Kelly Mays

Regulatory ID:

Sample Number: 7062809-01

Site: HS-BLANK

Sample ID:

Collector: DT

Collect Date: 06/13/2017 5:10 am

Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 06/15/17 RPV 06/24/17 20:34 RPV

Sample Number: 7062809-02

Site: HS-NS-NURSE

Sample ID:

Collector: DT

Collect Date: 06/13/2017 5:11 am

Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 2.41 µg/L EPA 200.8 1.00 1 06/15/17 RPV 06/24/17 20:36 RPV

Sample Number: 7062809-03

Site: HS-WC-HALLRM2A-1

Sample ID:

Collector: DT

Collect Date: 06/13/2017 5:12 am

Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 06/15/17 RPV 06/24/17 20:38 RPV

Sample Number: 7062809-04

Site: HS-WC-HALLRM2A-2

Sample ID:

Collector: DT

Collect Date: 06/13/2017 5:13 am

Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 06/15/17 RPV 06/24/17 20:40 RPV

Sample Number: 7062809-05

Site: HS-TL-FAC

Sample ID:

Collector: DT

Collect Date: 06/13/2017 5:15 am

Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead 5.11 µg/L EPA 200.8 1.00 1 06/15/17 RPV 06/24/17 20:42 RPV

Report Generated On: 06/29/2017 3:00 pm  
STL\_Results Revision #1.6

7062809  
Effective: 07/09/2014





Sample Number: 7062809-06	Site: HS-WC-HALLRM3-1	Sample ID:
Collector: DT	Collect Date: 06/13/2017 5:17 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/15/17	RPV	06/24/17 20:44	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062809-07	Site: HS-WC-HALLRM3-2	Sample ID:
Collector: DT	Collect Date: 06/13/2017 5:18 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	06/15/17	RPV	06/24/17 20:50	RPV
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062809-08	Site: HS-FP-KITCH	Sample ID:
Collector: DT	Collect Date: 06/13/2017 5:21 am	Sample Type: S

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.42	µg/L	EPA 200.8	1.00	1	06/15/17	RPV	06/24/17 20:52	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062809-09	Site: Laboratory Control Sample	Sample ID:
Collector:	Collect Date: 06/14/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	14.7	µg/L	EPA 200.8	1.00	1	06/15/17	RPV	06/28/17 22:44	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 7062809-10	Site: Laboratory Control Sample Duplicate	Sample ID:
Collector:	Collect Date: 06/14/2017 12:00 am	Sample Type:

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	14.9	µg/L	EPA 200.8	1.00	1	06/15/17	RPV	06/28/17 22:46	RPV
------	------	------	-----------	------	---	----------	-----	----------------	-----

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Report Generated On: 06/29/2017 3:00 pm 7062809  
STL\_Results Revision #1.6 Effective: 07/09/2014





**SUBURBAN**  
TESTING LABS

**Reviewed and Released By:**

Alana Kopicz  
Project Manager

Report Generated On: 06/29/2017 3:00 pm 7062809  
STL\_Results Revision #1.6 Effective: 07/09/2014





7062809  
Alana Kopicz

TAT(Check One):  Standard  24hr  48hr  72hr  Other  
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: \_\_\_\_\_

Client Name: Karl Environmental Group

Address: 20 Lauck Road  
Mohnton, PA 19540

Contact Name: Kelly Mays

Phone: 610-856-7700

Fax: 610-856-5040

Email: kmays@karlenv.com

Client Name: Allendale Board of Education

Address: Hillside School  
89 Hillside Avenue, Allendale, NJ

Payment / P.O. Info: 17-0662

Comments: NJ DOE Lead in Drinking Water Samples - First Draw

SWTL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
	HS-BLANK	6/13/2017	0510	DT	Lead	1	PW	G	P	H	Blank <i>pkd</i>
	HS-NS-NURSE	6/13/2017	0511	DT	Lead	1	PW	G	P	H	
	HS-WC-HALLRM2A-1	6/13/2017	0512	DT	Lead	1	PW	G	P	H	
	HS-WC-HALLRM2A-2	6/13/2017	0513	DT	Lead	1	PW	G	P	H	
	HS-TL-FAC	6/13/2017	0515	DT	Lead	1	PW	G	P	H	
	HS-WC-HALLRM3-1	6/13/2017	0517	DT	Lead	1	PW	G	P	H	
	HS-WC-HALLRM3-2	6/13/2017	0518	DT	Lead	1	PW	G	P	H	
	HS-FP-KITCH	6/13/2017	0521	DT	Lead	1	PW	G	P	H	

Relinquished By:	Date: <u>6-13-17</u>	Temp °C: _____ Acceptable: Y / N	Sample Conditions Submitted with COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N
<u>Darren Townsend</u>	Time: <u>10:00</u>		
Received By:	Date: <u>6-13-17</u>	Temp °C: _____ Acceptable: Y / N	Number of containers match number on COC? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N
<u>Kelly Mays</u>	Time: <u>1000</u>		
Relinquished By:	Date: <u>6-14-17</u>	Temp °C: _____ Acceptable: Y / N	All containers in tact? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N
<u>Kelly Mays</u>	Time: <u>1245</u>		
Received in Lab By:	Date: <u>6/14/17</u>	Temp °C: <u>8.9 on ice</u> Acceptable: <input checked="" type="checkbox"/> Y <input type="checkbox"/> N	Tests within holding times? <input checked="" type="checkbox"/> Y <input type="checkbox"/> N
<u>Louise Vats</u> (8)	Time: <u>12:45</u>		
			40 mL VOA vials free of headspace? <input type="checkbox"/> Y <input type="checkbox"/> N

Signing this form indicates your agreement with SWTL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.4 Effective Novemb  
Shaded areas are for SWTL use only.

## Suburban Testing Labs

Lab Date/Time: 12:50 6/14/17 Lab Temp: 8.9

Number of containers/coolers match number on COC?  Y  N  
Sample labels and COC are free of discrepancies?  Y  N  
All Containers in tact?  Y  N  
Received in lab within acceptable temperature limits?  Y  N  
40mL VOA vials free of headspace?  Y  N

Relinquished by: Louise Vats (8)

Received in Lab by: [Signature] 6/14/17

*pkd ✓ M 6/14/17*