

## Water Testing Results - BCTN House

### Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
	20880006-001KF	2/1/2021	2.19
	20880006-002BF	2/2/2021	3.46
	20880006-003SH	2/3/2021	4.68
	20880006-004OS	2/4/2021	1.6

ND = Non Detect - Lead level is below the set detection limits of X ppb

Lab Sheets reporting in ug/L \*\*\* ug/L = ppb