

July 2018

**Results to date and any action taken:**

R = Reportable, lead level is 15 parts per billion or greater at one sampling on site

NR = Non-reportable, lead level is below 15 parts per billion at all samplings on site

TBD = To be determined following testing by the City of Clovis

<b>CLOVIS UNIFIED SCHOOL</b>	<b>WATER AGENCY</b>	<b>TEST RESULT</b>	<b>ACTION TAKEN</b>
Boris Elementary	Fresno	--	Exempt school
Bud Rank Elementary	Clovis	NR	
Cedarwood Elementary	Clovis	NR	
Century Elementary	Clovis	NR	
Cole Elementary	Clovis	NR	
Community Day School	Clovis	NR	
Copper Hills Elementary	Fresno	NR	
Dry Creek Elementary	Clovis	NR	
Fancher Creek Elementary	Fresno	NR	
Fort Washington Elem.	Fresno	NR	
Freedom Elementary	Clovis	NR	
Fugman Elementary	Fresno	NR	
Garfield Elementary	Clovis	NR	
Gettysburg Elementary	Clovis	NR	
Jefferson Elementary	Clovis	NR	
Liberty Elementary	Fresno	NR	
Lincoln Elementary	Fresno	NR	
Maple Creek Elementary	Fresno	NR	
Mickey Cox Elementary	Clovis	NR	
Miramonte Elementary	Clovis	NR	
Mountain View Elem.	Fresno	R	1 fixture replaced. CUSD Retest confirmed NR.
Nelson Elementary	Pinedale	R	1 fixture replaced. CUSD Retest confirmed NR.
Online/Enterprise	Clovis	NR	
Oraze Elementary	Fresno	---	Exempt school
Pinedale Elementary	Pinedale	NR	
Reagan Elementary	Clovis	NR	
Red Bank Elementary	Clovis	NR	
Riverview Elementary	Fresno	NR	
Sierra Vista Elementary	Clovis	NR	
Tarpey Elementary	Clovis	NR	
Temperance-Kutner Elem.	Fresno	NR	
Valley Oak Elementary	Fresno	NR	
Weldon Elementary	Clovis	NR	
Woods Elementary	Clovis	NR	

<b>SECONDARY SCHOOLS</b>			
Alta Sierra Intermediate	Clovis	NR	
Buchanan High	Clovis	NR	
CART	Clovis	NR	
Clark Intermediate	Clovis	NR	
Clovis High	Clovis	NR	
Clovis East High	Clovis	NR	
Clovis North High	Fresno	NR	
Clovis West High	Fresno	R	Fixture replaced. CUSD Retest confirmed NR.
Gateway High	Clovis	NR	
Granite Ridge Intermediate	Fresno	R	1 fixture replaced/removed from service
Kastner Intermediate	Fresno	NR	
Reyburn Intermediate	Clovis	NR	

Should you have any further questions, please contact Assistant Superintendent of Facility Services Kevin Peterson at 327-9262 or email [kevinpeterson@cusd.com](mailto:kevinpeterson@cusd.com).