



PROJECT: Pavement Maintenance at Various Sites

OWNER: Clovis Unified School District

ENGINEER: Blair, Church & Flynn

BID NO: 2984

Attention: Jenn Felix

BCF PROJECT NO. 222-0431

Tanairy Barrera

It will be the responsibility of the General Contractor to submit the information contained in this addendum to all its subcontractors and suppliers. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification. The following additions, deletions, and revisions to the Drawings and Project Manual are hereby made and do become a part of these Contract Documents.

TABLE OF CONTENTS

ADDITIONAL PROJECT INFORMATION

Bid Opening Date

Bidder Questions

ATTACHMENTS

None.

ADDITIONAL PROJECT INFORMATION

Bid Opening Date

The bid opening has been revised to 4/15/24 at 2:00 pm

Bidder Questions

Q1: Addendum No. 01 includes the Geotechnical Reports for each site. Therein, the recommended Asphalt and Base Rock thicknesses are shown for each. The recommendations do not match all of the thicknesses shown in the details for each site. Are we to provide a bid for installing the Asphalt and Base Rock in the thicknesses shown in the details for each site or those shown as recommendations in the Geotechnical Report?

A1: Bidders shall bid the pavement sections based on the details shown for each site, not the pavement recommendations shown in the Geotech reports. The pavement sections shown in the details consider the proposed use and existing conditions in addition to the Geotech recommendations.

Q2: The Geotechnical Reports show the existing Asphalt and Base Rock sections in their core data. The reports do not state that NEW Base Rock will be required, simply that it shall be moisture conditioned and compacted per the Geotechnical requirements. Please see excerpt below:

“Prior to paving, the subgrade should be prepared with at least the upper 12 inches of subgrade soils compacted to a minimum of 95% relative compaction. All aggregate base (AB) courses should be moisture conditioned to within 2% of optimum moisture content and compacted to a minimum of 95% relative compaction. The AC mix design(s) and installation requirements should be specified by the Project Civil Engineer.”

Are bidders to assume we have the option to reuse the existing Base Rock on each site or are we to assume that we are to provide NEW Base Rock for each site?

A2: Bidders shall assume they have the option to reuse the existing base rock on each site.