



2150 Smithtown Ave., Suite 3, Ronkonkoma, NY 11779  
T: 631.580.3191 • F: 631.580.3195 • W: [envirohealth.org](http://envirohealth.org)

August 28, 2020

Connetquot CSD  
Mr. John Allen  
780 Ocean Avenue  
Bohemia, NY 11716

Re: Lead in Water Testing

Enclosed you will find new updated charts and new lab results from your latest lead in water sampling. Please use these to add to the charts in your book. The lab results should be added to the back of each corresponding school appendix. In this way your book will continually be updated.

Thank you. If you have any questions, please feel free to contact us.

Sincerely,

Glenn Neuschwender  
President

Connetquot CSD  
Edward J. Bosti Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Men's Bathroom by Receiving	SK	App	6.74	4/1/2020	-	-	-	None	SIGN	-	-
1001-2	Custodial Closet by Receiving	SS	N/A		4/1/2020	-	-	-	Sign Required	-	-	-
1001-3	Women's Bathroom by Receiving	SK	N/A	21	4/1/2020				Sign Required	SIGN	16.2	7/15/20
1002-1	Kitchen 3-Bay @ A	SK	App	11.4	4/1/2020	-	-	-	None	-	-	-
1002-2	Kitchen 3-Bay @ B	SPY	App	7.91	4/1/2020	-	-	-	None	-	-	-
1002-3	Kitchen 3-Bay @ C	SK	App	16.3	4/1/2020				None	Fixture Replacement	13.3	6/23/20
1002-4	Kitchen Island	SK	App	17.1	4/1/2020				None	Fixture Replacement	13.3	6/23/20
1002-5	Kitchen Dishwash @ A	SK	App	27.8	4/1/2020				None	Fixture Replacement	11.4	7/15/20
1002-6	Kitchen Dishwash @ B	SK	App	9.61	4/1/2020	-	-	-	None	-	-	-
1002-7	Kitchen Dishwash	SPY	App	7.37	4/1/2020	-	-	-	None	-	-	-
1003-1	PE Office Bathroom	SK	App	5.21	4/1/2020	-	-	-	None	SIGN	-	-
1004-1	Boy's Locker Room	WF	App		4/1/2020	-	-	-	Non-functional Sampling Required	-	-	-
1005-1	Girl's Locker Room	WF	App		4/1/2020	-	-	-	Non-functional Sampling Required	-	-	-
1006-1	Room 127	SK	App	4.39	4/1/2020	-	-	-	None	-	-	-
1006-2	Room 127	WF	App	1.66	4/1/2020	-	-	-	None	-	-	-
1007-1	Room 126 Unit 1	SK	App	13.9	4/1/2020	-	-	-	None	-	-	-
1007-2	Room 126 Unit 2	SK	App	3.12	4/1/2020	-	-	-	None	-	-	-
1008-1	Room 125	SK	App	4.49	4/1/2020	-	-	-	None	-	-	-
1008-2	Room 125	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1009-1	Room 124	SK	App	2.14	4/1/2020	-	-	-	None	-	-	-

Connetquot CSD  
Edward J. Bosti Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1009-2	Room 124	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1010-1	Room 122	SK	App	4.4	4/1/2020	-	-	-	None	-	-	-
1010-2	Room 122	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1011-1	Custodial Closet by Room 120	SS	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1012-1	Room 120	SK	App	2.06	4/1/2020	-	-	-	None	-	-	-
1012-2	Room 120	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1013-1	Room 119	SK	App	14.8	4/1/2020	-	-	-	None	-	-	-
1013-2	Room 119	WF	App	4.61	4/1/2020	-	-	-	None	-	-	-
1014-1	Room 118	SK	App	1.13	4/1/2020	-	-	-	None	-	-	-
1015-1	Men's Faculty Bathroom by Room 117	SK	N/A		4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1016-1	Women's Faculty Bathroom by Room 116	SK	N/A		4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1017-1	Library Office	SK	App	12.9	4/1/2020	-	-	-	None	-	-	-
1018-1	Unisex Bathroom by Elevator	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1019-1	Custodial Closet by Elevator	SS	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1020-1	Kindergarten Atrium - left	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1020-2	Kindergarten Atrium - right	WF	App	1.29	4/1/2020	-	-	-	None	-	-	-
1021-1	Room 115	SK	App	1.7	4/1/2020	-	-	-	None	-	-	-
1021-2	Room 115	WF	App	1.94	4/1/2020	-	-	-	None	-	-	-
1022-1	Room 114	SK	App	1.18	4/1/2020	-	-	-	None	-	-	-
1022-2	Room 114	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-

Connetquot CSD  
Edward J. Bosti Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1023-1	Room 113	SK	App	1.91	4/1/2020	-	-	-	None	-	-	-
1023-2	Room 113	WF	App	1.93	4/1/2020	-	-	-	None	-	-	-
1024-1	Room 112	SK	App	4.98	4/1/2020	-	-	-	None	-	-	-
1024-2	Room 112	WF	App	3.22	4/1/2020	-	-	-	None	-	-	-
1025-1	Room 111	SK	App	1.41	4/1/2020	-	-	-	None	-	-	-
1025-2	Room 111	WF	App	1.6	4/1/2020	-	-	-	None	-	-	-
1026-1	Room 108	SK	App	4	4/1/2020	-	-	-	None	-	-	-
1026-2	Room 108	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1027-1	Room 107	SK	App	2.29	4/1/2020	-	-	-	None	-	-	-
1027-2	Room 107	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1028-1	Hall by Room 106	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1028-2	Hall by Room 106	BF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1029-1	Room 105	SK	App	1.79	4/1/2020	-	-	-	None	-	-	-
1029-2	Room 105	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1030-1	Women's Faculty Bathroom by Room 105	SK	N/A		4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1031-1	Men's Faculty Bathroom by Room 105	SK	N/A		4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1032-1	Room 104	SK	App	1.89	4/1/2020	-	-	-	None	-	-	-
1032-2	Room 104	WF	App	2.11	4/1/2020	-	-	-	None	-	-	-
1033-1	Custodial Closet by Room 128	SS	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1034-1	Room 128	SK	App	3.55	4/1/2020	-	-	-	None	-	-	-



Connetquot CSD  
Edward J. Bosti Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1034-2	Room 128	WF	App	1.76	4/1/2020	-	-	-	None	-	-	-
1035-1	Room 129	SK	App	5.59	4/3/2020	-	-	-	None	-	-	-
1035-2	Room 129	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1036-1	Room 102 Nurse's Office	SK	App	1.11	4/1/2020	-	-	-	None	-	-	-
1036-2	Room 102 Nurse's Office	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1036-3	Room 102 Nurse's Office Bathroom	SK	N/A	-	4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
<b>1037-1</b>	<b>Principal's Office Bathroom</b>	<b>SK</b>	<b>App</b>	<b>22.4</b>	<b>4/1/2020</b>	<b>2.81</b>	<b>1.82</b>	<b>7/22/2020</b>	<b>Additional Sampling Required</b>		<b>17.7</b>	<b>7/15/2020</b>
1038-1	Main Office	SK	App	7.96	4/1/2020	-	-	-	None	-	-	-
1038-2	Main Office Bathroom	SK	App	8.1	4/1/2020	-	-	-	None	-	-	-
1039-1	Cafetorium	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1039-2	Cafetorium	BF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1039-3	Cafetorium Stage	SK	App	12.9	4/1/2020	-	-	-	None	SIGN	-	-
1040-1	Boy's Bathroom by Cafetorium	SK	N/A	-	4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1041-1	Girl's Bathroom by Cafetorium @ A	SK	N/A	-	4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1041-2	Girl's Bathroom by Cafetorium @ B	SK	N/A	-	4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1042-1	Hall by Cafetorium - left	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1042-2	Hall by Cafetorium - right	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1043-1	Custodial Closet by Cafetorium	SS	N/A	-	4/1/2020	-	-	-	None	SIGN	-	-
2001-1	Hall by Room 203 - left	WF	App	-	4/1/2020	-	-	-	Non-functional Sampling Required	-	-	-
2001-2	Hall by Room 203 - right	WF	App	-	4/1/2020	-	-	-	Non-functional Sampling Required	-	-	-

Connetquot CSD  
Edward J. Bosti Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
2002-1	Bathrooms by Room 213 @ A	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
2002-2	Bathrooms by Room 213 @ B	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
2002-3	Bathrooms by Room 213 @ C	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
2002-4	Bathrooms by Room 213 @ D	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
2002-5	Bathrooms by Room 213 @ E	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
2003-1	Hall by Room 213 - left	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
2003-2	Hall by Room 213 - right	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
2004-1	Custodial Closet by Room 212	SS	N/A		4/1/2020	-	-	-	Sign Required	-	-	-
2005-1	Boy's Bathroom by Room 220 @ A	SK	N/A		4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2005-2	Boy's Bathroom by Room 220 @ B	SK	N/A		4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2006-1	Men's Faculty Bathroom by Room 220	SK	N/A		4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2007-1	Women's Faculty Bathroom by Room 220	SK	N/A		4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2008-1	Girls Bathroom by Room 220 @ A	SK	N/A		4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2008-2	Girls Bathroom by Room 220 @ B	SK	N/A		4/1/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-

**Laboratory Report**  
NYE Report #: 2202292-14726

June 29, 2020

Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Edward J. Bosti Elementary School, Connetquot, NY

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 26, 2020. New York Environmental analyzed the samples on June 26, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	23 Jun 2020
Date Received:	26 Jun 2020
Date Analyzed:	26 Jun 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200626J020	1	Women's Bathroom by Receiving-SK; Initial	1.00	93.8	µg/L	E,H
200626J021	2	Kitchen 3-Bay @ C-SK; Initial	1.00	13.3	µg/L	
200626J022	3	Kitchen Island-SK; Initial	1.00	13.3	µg/L	
200626J023	4	Kitchen Dishwash @ A-SK; Initial	1.00	91.5	µg/L	E,H
200626J024	5	Principal's Office Bathroom-SK; Initial	1.00	20.2	µg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

E: Sample result exceeds instrument calibration, value is estimated.

H: Sample result exceeds applicable regulatory limit.





**Laboratory Report**  
NYE Report #: 2202589-14904

July 17, 2020

Project Manager  
Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Edward J Bosti Elementary School Connetquot, NY

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on July 16, 2020. New York Environmental analyzed the samples on July 17, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



---

Li Tsang, Laboratory Director

Date Collected:	15 Jul 2020
Date Received:	16 Jul 2020
Date Analyzed:	17 Jul 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
200716Q005	1	Principal's Office Bathroom-SK, Initial	1.00	17.7	µg/L	H
200716Q006	2	Kitchen Dishwash @ A-SK, Initial	1.00	11.4	µg/L	
200716Q007	3	Women's Bathroom by Receiving-SK, Initial	1.00	16.2	µg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



**Laboratory Report**  
NYE Report #: 2202698-14970

July 24, 2020

Project Manager  
Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Edward J Bosti Elementary School Connetquot, NY

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on July 23, 2020. New York Environmental analyzed the samples on July 24, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

  
\_\_\_\_\_  
Li Tsang, Laboratory Director

Date Collected:	22 Jul 2020
Date Received:	23 Jul 2020
Date Analyzed:	24 Jul 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
200723K001	1	Principal's Office Bathroom-SK; 15 Sec Follow-up	1.00	2.81	µg/L	
200723K002	2	Principal's Office Bathroom-SK; 60 Sec Follow-up	1.00	1.82	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Connetquot CSD  
Cherokee Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Men's Bathroom by Receiving	SK	App	1.17	4/3/2020	-	-	-	None	-	-	-
1001-2	Custodial Closet by Receiving	SS	N/A		4/3/2020	-	-	-	None	SIGN	-	-
1001-3	Women's Bathroom by Receiving	SK	App	5.01	4/3/2020	-	-	-	None	-	-	-
1002-1	Kitchen 3-Bay @ A	SK	App	6.68	4/3/2020	-	-	-	None	-	-	-
1002-2	Kitchen 3-Bay @ B	SPY	App	1.5	4/3/2020	-	-	-	None	-	-	-
1002-3	Kitchen 3-Bay @ C	SK	App	2.85	4/3/2020	-	-	-	None	-	-	-
1002-4	Kitchen Dishwash @ A	SK	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1002-5	Kitchen Dishwash @ B	SPY	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1002-6	Kitchen Dishwash @ C	SK	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1002-7	Kitchen Handwash	SK	App	2.42	4/3/2020	-	-	-	None	-	-	-
1002-8	Kitchen Island	SK	App	3.41	4/3/2020	-	-	-	None	-	-	-
1003-1	Cafetorium -left	WF	App		4/3/2020	-	-	-	Non-functional Sampling Required	-	-	-
1003-2	Cafetorium - right	WF	App		4/3/2020	-	-	-	Non-functional Sampling Required	-	-	-
1003-3	Cafetorium Stage	SK	App	22	6/25/2020				None	CAPPED		
1004-1	Boy's Locker Room Bathroom @ A	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1004-2	Boy's Locker Room Bathroom @ B	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1005-1	Girl's Locker Room	WF	N/A		4/3/2020	-	-	-	Non-functional Sampling Required	-	-	-
1006-1	Bathroom by Gym	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1007-1	Custodial Closet by Room 128	SS	N/A		4/3/2020	-	-	-	Sign Required	-	-	-
1008-1	Hall by Room 128	WF	App	22.4	4/3/2020				Additional Sampling Required	Fixture Replacement	5.05	7/15/20



Connetquot CSD  
Cherokee Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1009-1	Boy's Bathroom by Room 128 @ A	SK	App	7.77	4/3/2020	-	-	-	None	-	-	-
1009-2	Boy's Bathroom by Room 128 @ B	SK	App	13	4/3/2020	-	-	-	None	-	-	-
1010-1	Girl's Bathroom by Room 128 @ A	SK	App	5.52	4/3/2020	-	-	-	None	-	-	-
1010-2	Girl's Bathroom by Room 128 @ B	SK	App	6.46	4/3/2020	-	-	-	None	-	-	-
1011-1	Room 128	SK	App	5.11	4/3/2020	-	-	-	None	-	-	-
1011-2	Room 128	WF	App	1.16	4/3/2020	-	-	-	None	-	-	-
1012-1	Room 129	SK	App	2.11	4/3/2020	-	-	-	None	-	-	-
1012-2	Room 129	WF	App	8.4	4/3/2020	-	-	-	None	-	-	-
1013-1	Room 130	SK	App	2.96	4/3/2020	-	-	-	None	-	-	-
1013-2	Room 130	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1014-1	Room 131	SK	App	4.48	4/3/2020	-	-	-	None	-	-	-
1014-2	Room 131	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1015-1	Room 132	SK	App	2.09	4/3/2020	-	-	-	None	-	-	-
1015-2	Room 132	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1016-1	Room 133	SK	App	18.3	4/3/2020	-	-	-	None	Fixture Replacement	9.68	6/25/20
1016-2	Room 133	WF	App	1.82	4/3/2020	-	-	-	None	-	-	-
1017-1	Room 134	SK	App	7.32	4/3/2020	-	-	-	None	-	-	-
1017-2	Room 134	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1018-1	Room 135	SK	App	4.18	4/3/2020	-	-	-	None	-	-	-
1018-2	Room 135	WF	App	1.42	4/3/2020	-	-	-	None	-	-	-

Connetquot CSD  
Cherokee Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1019-1	Room 136	SK	App	6	4/3/2020	-	-	-	None	-	-	-
1019-2	Room 136	WF	App	3.06	4/3/2020	-	-	-	None	-	-	-
1020-1	Room 127	SK	App	10.7	4/3/2020	-	-	-	None	-	-	-
1020-2	Room 127	WF	App	4.87	4/3/2020	-	-	-	None	-	-	-
1021-1	Room 126 Unit 1	SK	App	1.76	4/3/2020	-	-	-	None	-	-	-
1021-2	Room 126 Unit 2	WF	App	1.23	4/3/2020	-	-	-	None	-	-	-
1022-1	Room 125	SK	App	10.4	4/3/2020	-	-	-	None	-	-	-
1022-2	Room 125	WF	App	1.86	4/3/2020	-	-	-	None	-	-	-
1023-1	Room 124	SK	App	9.62	4/3/2020	-	-	-	None	-	-	-
1023-2	Room 124	WF	App	1.23	4/3/2020	-	-	-	None	-	-	-
1024-1	Room 123	SK	App	11.3	4/3/2020	-	-	-	None	-	-	-
1024-2	Room 123	WF	App	2.41	4/3/2020	-	-	-	None	-	-	-
1025-1	Custodial Closet by Room 121	SS	N/A		4/3/2020	-	-	-	None	SIGN	-	-
1026-1	Room 121	SK	App	4.43	4/3/2020	-	-	-	None	-	-	-
1026-2	Room 121	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1027-1	Room 120	SK	App	30.5	4/3/2020	-	-	-	None	Fixture Replacement	7.61	6/25/20
1027-2	Room 120	WF	App	2.97	4/3/2020	-	-	-	None	-	-	-
1028-1	Room 119	SK	App	4.6	4/3/2020	-	-	-	None	-	-	-
1029-1	Men's Bathroom by Room 118	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1030-1	Women's Bathroom by Room 117	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-

Connetquot CSD  
Cherokee Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1031-1	Bathroom by Elevator	SK	App	3.8	4/3/2020	-	-	-	None	-	-	-
1032-1	Custodial Closet by Elevator	SS	N/A		4/3/2020	-	-	-	None	SIGN	-	-
1033-1	Room 108	SK	App	10.3	4/3/2020	-	-	-	None	-	-	-
1033-2	Room 108	WF	App	4.17	4/3/2020	-	-	-	None	-	-	-
1034-1	Room 109	SK	App	10.9	4/3/2020	-	-	-	None	-	-	-
1034-2	Room 109	WF	App	3.58	4/3/2020	-	-	-	None	-	-	-
1035-1	Room 110	SK	App	6.91	4/3/2020	-	-	-	None	-	-	-
1035-2	Room 110	WF	App	2.81	4/3/2020	-	-	-	None	-	-	-
1036-1	Room 111	SK	App	10.4	4/3/2020	-	-	-	None	-	-	-
1036-2	Room 111	WF	App	5.08	4/3/2020	-	-	-	None	-	-	-
1037-1	Room 112	SK	App	11.7	4/3/2020	-	-	-	None	-	-	-
1037-2	Room 112	WF	App	3.52	4/3/2020	-	-	-	None	-	-	-
1038-1	Room 113	SK	App	13.9	4/3/2020	-	-	-	None	-	-	-
1038-2	Room 113	WF	App	2.41	4/3/2020	-	-	-	None	-	-	-
1039-1	Room 114	SK	App	10.6	4/3/2020	-	-	-	None	-	-	-
1039-2	Room 114	WF	App	3.54	4/3/2020	-	-	-	None	-	-	-
1040-1	Kindergarten Atrium - left	WF	App	1.38	4/3/2020	-	-	-	None	-	-	-
1040-2	Kindergarten Atrium - right	WF	App	4.78	4/3/2020	-	-	-	None	-	-	-
1041-1	Room 107	SK	App	25.9	4/3/2020	-	-	-	None	Fixture Replacement	11.6	6/25/20
1041-2	Room 107	WF	App	2.88	4/3/2020	-	-	-	None	-	-	-



Connetquot CSD  
Cherokee Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1042-1	Room 105	SK	App	19.3	4/3/2020				None	Fixture Replacement	3.85	6/25/20
1042-2	Room 105	WF	App	2.6	4/3/2020	-	-	-	None	-	-	-
1043-1	Hall by Room 106 -left	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1043-2	Hall by Room 106 - right	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1044-1	Room 104	SK	App	18.4	4/3/2020				None	Fixture Replacement	3.6	6/25/20
1044-2	Room 104	WF	App	3.48	4/3/2020	-	-	-	None	-	-	-
1045-1	Girl's Bathroom by Room 104	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1046-1	Boy's Bathroom by Room 104	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1047-1	Room 103	SK	App	17.4	4/3/2020				None	Fixture Replacement	3.61	6/25/20
1047-2	Room 103	WF	App	1.31	4/3/2020	-	-	-	None	-	-	-
1048-1	Room 101 Nurse's Office	SK	App	15	4/3/2020	-	-	-	None	-	-	-
1048-2	Room 101 Nurse's Office	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1048-3	Room 101 Nurse's Office BR	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1049-1	Custodial Closet by Room 138	SS	N/A		4/3/2020	-	-	-	None	SIGN	-	-
1050-1	Room 138	SK	App	3.09	4/3/2020	-	-	-	None	-	-	-
1050-2	Room 138	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1051-1	Room 137	SK	App	1.07	4/3/2020	-	-	-	None	-	-	-
1051-2	Room 137	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1052-1	Library Office	SK	App	67.7	4/3/2020				None	Fixture Replacement	7.36	6/25/20
1053--1	Main Office Bathroom	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-

Connetquot CSD  
Cherokee Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1053-2	Main Office	SK	App	3.64	4/3/2020	-	-	-	None	-	-	-
1054-1	Boy's Bathroom by Cafeterium	SK	N/A		4/3/2020	-	-	-	None	SIGN	-	-
1055-1	Girl's Bathroom by Cafeterium @ A	SK	N/A		4/3/2020	-	-	-	None	SIGN	-	-
1055-2	Girl's Bathroom by Cafeterium @ B	SK	N/A		4/3/2020	-	-	-	None	SIGN	-	-
1056-1	Hall by Cafeterium	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1056-2	Hall by Cafeterium	BF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
1057-1	Custodial Closet by Cafeterium	SS	N/A		4/3/2020	-	-	-	None	SIGN	-	-
2001-1	Hall by Room 204	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
2001-2	Hall by Room 204	BF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
2002-1	Bathrooms by Room 215 @ A	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2002-2	Bathrooms by Room 215 @ B	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2002-3	Bathrooms by Room 215 @ C	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2002-4	Bathrooms by Room 215 @ D	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2002-5	Bathrooms by Room 215 @ E	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2003-1	Hall by Room 215 - left	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
2003-2	Hall by Room 215 - right	WF	App	<1.0	4/3/2020	-	-	-	None	-	-	-
2004-1	Custodial Closet by Room 212	SS	N/A		4/3/2020	-	-	-	None	SIGN	-	-
2005-1	Boy's Bathroom by Room 223 @ A	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2005-2	Boy's Bathroom by Room 223 @ B	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2006-1	Men's Faculty Bathroom by Room 223	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-



Connetquot CSD  
Cherokee Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
2007-1	Women's Faculty Bathroom by Room 223	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2008-1	Girl's Bathroom by Room 223 @ A	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
2008-2	Girl's Bathroom by Room 223 @ B	SK	N/A		4/3/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-



**Laboratory Report**  
NYE Report #: 2202295-14729

June 29, 2020

Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Cherokee Elementary School, Connetquot, NY

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 26, 2020. New York Environmental analyzed the samples on June 26, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,

  
\_\_\_\_\_  
Li Tsang, Laboratory Director

Date Collected:	25 Jun 2020
Date Received:	26 Jun 2020
Date Analyzed:	26 Jun 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200626J031	1	Cafetorium Stage-SK; Initial	1.00	22.0	µg/L	H
200626J032	2	Hall by Room 128-WF; Initial	1.00	15.9	µg/L	H
200626J033	3	Room 133-SK; Initial	1.00	9.68	µg/L	
200626J034	4	Room 120-SK; Initial	1.00	7.61	µg/L	
200626J035	5	Room 107-SK; Initial	1.00	11.6	µg/L	
200626J036	6	Room 105-SK; Initial	1.00	3.85	µg/L	
200626J037	7	Room 104-SK; Initial	1.00	3.60	µg/L	
200626J038	8	Room 103-SK; Initial	1.00	3.61	µg/L	
200626J039	9	Library Office-SK; Initial	1.00	7.36	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



**Laboratory Report**  
NYE Report #: 2202591-14906

July 17, 2020

Project Manager  
Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Cherokee Street Elementary Connetquot, NY

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on July 16, 2020. New York Environmental analyzed the samples on July 17, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	15 Jul 2020
Date Received:	16 Jul 2020
Date Analyzed:	17 Jul 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
200716Q009	1	Hall by Room 128-WF, Initial	1.00	5.05	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation





Connetquot CSD  
Helen B. Duffield Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Kitchen Island Food Prep	SK	App	1.39	4/2/2020	-	-	-	None	-	-	-
1001-2	Kitchen Handwash by Ovens	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1001-3	Kitchen Handwash by Freezers	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1001-4	Kitchen Handwash by Dishwasher	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1001-5	Kitchen 3-Bay @ A	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1001-6	Kitchen 3-Bay @ B	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1001-7	Kitchen 3-Bay	SPY	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1002-1	Cafeteria	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1003-1	Faculty Room	SK	App	1.58	4/2/2020	-	-	-	None	-	-	-
1003-2	Faculty Room Bathroom	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1004-1	Unisex Bathroom	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1005-1	Boiler Room	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1006-1	Hall in Kindergarten Wing	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1007-1	Copy Room	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1008-1	Room 28	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1008-2	Room 28	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1009-1	Room 29	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1009-2	Room 29	WF	App	1.3	4/2/2020	-	-	-	None	-	-	-
1010-1	Room 30	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1010-2	Room 30	WF	App	2.89	4/2/2020	-	-	-	None	-	-	-

Connetquot CSD  
Helen B. Duffield Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1011-1	Room 31	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1011-2	Room 31	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1012-1	Girl's Bathroom by Room 24 @A	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1012-2	Girl's Bathroom by Room 24 @B	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1013-1	Custodial Closet by Room 24	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1014-2	Boy's Bathroom by Room 24 @B	#REF!	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1015-1	Hall of Grades 3-5-Left	WF	App	1.22	4/2/2020	-	-	-	None	-	-	-
1015-2	Hall of Grades 3-5-Right	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1016-1	Adults Bathroom in Hall of Grades 3-5	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1017-1	Room 21	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1018-1	Room 22	SK	App	1.6	4/2/2020	-	-	-	None	-	-	-
1019-1	Room 23	SK	App	1.21	4/2/2020	-	-	-	None	-	-	-
1020-1	Room 20	SK	App	9.97	4/2/2020	-	-	-	None	-	-	-
1020-2	Room 20	WF	App	1.66	4/2/2020	-	-	-	None	-	-	-
1021-1	Room 19	SK	App	5.1	4/2/2020	-	-	-	None	-	-	-
1021-2	Room 19	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1022-1	Room 18	SK	App	20.3	4/2/2020	-	-	-	None	Fixture Replacement	2.86	6/25/20
1022-2	Room 18	WF	App	5.19	4/2/2020	-	-	-	None	-	-	-
1023-1	Room 17	SK	App	3.5	4/2/2020	-	-	-	None	-	-	-
1023-2	Room 17	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-

Connetquot CSD  
Helen B. Duffield Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1024-1	Room 16	SK	App	4.41	4/2/2020	-	-	-	None	-	-	-
1024-2	Room 16	WF	App	1.02	4/2/2020	-	-	-	None	-	-	-
1025-1	Room 15	SK	App	5.76	4/2/2020	-	-	-	None	-	-	-
1025-2	Room 15	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1026-1	Room 14	SK	App	1.54	4/2/2020	-	-	-	None	-	-	-
1026-2	Room 14	WF	App	4.2	4/2/2020	-	-	-	None	-	-	-
1027-1	Room 13	SK	App	2.95	4/2/2020	-	-	-	None	-	-	-
1027-2	Room 13	WF	App	1.96	4/2/2020	-	-	-	None	-	-	-
1028-1	Hall to Gym	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1028-2	Hall to Gym	BF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1029-1	Unisex Student Bathroom by Gym	SK	App	3.07	4/2/2020	-	-	-	None	-	-	-
1030-1	Teacher's Bathroom by Gym	SK	N/A		4/2/2020	-	-	-	Sign Required	-	-	-
1031-1	Girl's Bathroom in Green Hall @A	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1031-2	Girl's Bathroom in Green Hall @B	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1031-3	Girl's Bathroom in Green Hall @C	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1032-1	Green Hall	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1033-1	Custodial Closet in Green Hall	SS	N/A		4/2/2020	-	-	-	Sign Required	-	-	-
1034-1	Boy's Bathroom in Green Hall @A	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1034-2	Boy's Bathroom in Green Hall @B	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1034-3	Boy's Bathroom in Green Hall @C	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-

Connnetquot CSD  
Helen B. Duffield Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1035-1	Unisex Bathroom in Main Hall	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1036-1	Faculty Bathroom in Main Hall	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1037-1	Principle's Office Bathroom	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1038-1	Main Hall	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1038-2	Main Hall	BF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1039-1	Custodial Closet in Main Hall	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1040-1	Room 6	SK	App	1.59	4/2/2020	-	-	-	None	-	-	-
1040-2	Room 6	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1041-1	Room 7	SK	App	1.34	4/2/2020	-	-	-	None	-	-	-
1041-2	Room 7	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1042-1	Room 8	SK	App	1.37	4/2/2020	-	-	-	None	-	-	-
1042-2	Room 8	WF	App	1.51	4/2/2020	-	-	-	None	-	-	-



**Laboratory Report**  
NYE Report #: 2202293-14727

June 29, 2020

Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Helen B Duffield Elementary, Connetquot, NY

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 26, 2020. New York Environmental analyzed the samples on June 26, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	25 Jun 2020
Date Received:	26 Jun 2020
Date Analyzed:	26 Jun 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
200626J025	1	Room 18-SK; Initial	1.00	2.86	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation



Connetquot CSD  
Idle Hour Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Boiler Room	SS	N/A		4/1/2020	-	-	-	Sign Required		-	-
1002-1	Main Office Break Room	SK	App	8.42	4/1/2020	-	-	-	None	-	-	-
1003-1	Nurse's Office	SK	App	7.67	4/1/2020	-	-	-	None	-	-	-
1003-2	Nurse's Office Bathroom	SK	App	4.2	4/1/2020	-	-	-	None	SIGN	-	-
1004-1	Unisex Bathroom by Receiving	SK	App	7.66	4/1/2020	-	-	-	None	-	-	-
1005-1	Kitchen Handwash @ A	SK	App	15.4	4/1/2020	-	-	-	None	Fixture Replacement	3.17	6/24/20
1005-2	Kitchen 3 Bay @ A	SK	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1005-3	Kitchen 3 Bay @ A	SPY	App	1.62	4/1/2020	-	-	-	None	-	-	-
1005-4	Kitchen 3 Bay @ B	SK	App	1.13	4/1/2020	-	-	-	None	-	-	-
1005-5	Kitchen Handwash @ B	SK	App	4.21	4/1/2020	-	-	-	None	-	-	-
1005-6	Kitchen Handwash @ C	SK	App	10.6	4/1/2020	-	-	-	None	-	-	-
1005-7	Kitchen Island	SK	App	5.23	4/1/2020	-	-	-	None	-	-	-
1005-8	Kitchen Bathroom	SK	App	22.8	4/1/2020	-	-	-	None	Fixture Replacement	5.78	7/15/20
1006-1	Custodial Closet by Cafetorium	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1007-1	Cafetorium	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1007-2	Cafetorium	BF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1008-1	Girl's BR by Room 1 @ A	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1008-2	Girl's BR by Room 1 @ B	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1008-3	Girl's BR by Room 1 @ C	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1009-1	Hall by Room 1 - left	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-





Connetquot CSD  
Idle Hour Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1009-2	Hall by Room 1 - right	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1010-1	Boy's Bathroom by Room 1 @ A	SK	App	3.08	4/1/2020	-	-	-	None	-	-	-
1010-2	Boy's Bathroom by Room 1 @ B	SK	App	3	4/1/2020	-	-	-	None	-	-	-
1010-3	Boy's Bathroom by Room 1 @ C	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1011-1	Room 1	SK	App	7.82	4/1/2020	-	-	-	None	-	-	-
1011-2	Room 1	WF	App	7.48	4/1/2020	-	-	-	None	-	-	-
1012-1	Room 2	SK	App	3.6	4/1/2020	-	-	-	None	-	-	-
1012-2	Room 2	WF	App	5.3	4/1/2020	-	-	-	None	-	-	-
1013-1	Physical Education Office	SK	App		4/1/2020	-	-	-	None	SIGN	-	-
1014-1	Room 3	SK	App	3.22	4/1/2020	-	-	-	None	-	-	-
1014-2	Room 3	WF	App	8.81	4/1/2020	-	-	-	None	-	-	-
1015-1	Room 4	SK	App	4.61	4/1/2020	-	-	-	None	-	-	-
1015-2	Room 4	WF	App	5.43	4/1/2020	-	-	-	None	-	-	-
1016-1	Room 5	SK	App	2.24	4/1/2020	-	-	-	None	-	-	-
1016-2	Room 5	WF	App	2.95	4/1/2020	-	-	-	None	-	-	-
1017-1	Room 6	SK	App	3.97	4/1/2020	-	-	-	None	-	-	-
1017-2	Room 6	WF	App	4.35	4/1/2020	-	-	-	None	-	-	-
1018-1	Room 7	SK	App	10.3	4/1/2020	-	-	-	None	-	-	-
1018-2	Room 7	WF	App	17.2	4/1/2020	-	-	-	None	Fixture Replacement	12.1	6/24/20
1019-1	Room 8	SK	App	22.6	4/1/2020	-	-	-	None	Fixture Replacement	7.39	6/24/20

Connetquot CSD  
Idle Hour Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1019-2	Room 8	WF	App	8.2	4/1/2020	-	-	-	None	-	-	-
1020-1	Room 9	SK	App	8.99	4/1/2020	-	-	-	None	-	-	-
1020-2	Room 9	WF	App	1.66	4/1/2020	-	-	-	None	-	-	-
1021-1	Room 10	SK	App	3.83	4/1/2020	-	-	-	None	-	-	-
1021-2	Room 10	WF	App	2.98	4/1/2020	-	-	-	None	-	-	-
1022-1	Room 11	SK	App	10.2	4/1/2020	-	-	-	None	-	-	-
1022-2	Room 11	WF	App	3.16	4/1/2020	-	-	-	None	-	-	-
1022-3	Room 11 Counter by Dishwasher	SK	App	21	4/1/2020	-	-	-	Additional Sampling Required	Fixture Replacement	8.41	6/24/20
1023-1	Room 12	SK	App	4.89	4/1/2020	-	-	-	None	-	-	-
1023-2	Room 12	WF	App	4.12	4/1/2020	-	-	-	None	-	-	-
1024-1	Kindergarten Atrium - left	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1024-2	Kindergarten Atrium - right	WF	App	<1.0	4/1/2020	-	-	-	None	-	-	-
1024-3	Kindergarten Atrium Custodial Closet	SS	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1025-1	Kindergarten Atrium Women's Bathroom	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1026-1	Kindergarten Atrium Men's Bathroom	SK	N/A		4/1/2020	-	-	-	None	SIGN	-	-
1027-1	Room 14	SK	App	5.29	4/1/2020	-	-	-	None	-	-	-
1027-2	Room 14	WF	App	7.64	4/1/2020	-	-	-	None	-	-	-
1028-1	Room 15	SK	App	9.3	4/1/2020	-	-	-	None	-	-	-
1028-2	Room 15	WF	App	3.03	4/1/2020	-	-	-	None	-	-	-
1029-1	Room 17	SK	App	2.11	4/1/2020	-	-	-	None	-	-	-

Connetquot CSD  
Idle Hour Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1029-2	Room 17	WF	App	2.26	4/1/2020	-	-	-	None	-	-	-
1030-1	Room 20	SK	App	13.4	4/1/2020	-	-	-	None	-	-	-
1030-2	Room 20	WF	App	14	4/1/2020	-	-	-	None	-	-	-
1031-1	Room 21	SK	App	4.42	4/1/2020	-	-	-	None	-	-	-
1031-2	Room 21	WF	App	2.89	4/1/2020	-	-	-	None	-	-	-
1032-1	Room 22	SK	App	4.37	4/1/2020	-	-	-	None	-	-	-
1032-2	Room 22	WF	App	11.9	4/1/2020	-	-	-	None	-	-	-
1033-1	Room 23	SK	App	16.5	4/1/2020	-	-	-	None	Fixture Replacement	10.6	6/24/20
1033-2	Room 23	WF	App	13.5	4/1/2020	-	-	-	None	-	-	-
1034-1	Room 24	SK	App	5.54	4/1/2020	-	-	-	None	-	-	-
1034-2	Room 24	WF	App	4.98	4/1/2020	-	-	-	None	-	-	-
1035-1	Room 25	SK	App	12.4	4/1/2020	-	-	-	None	-	-	-
1035-2	Room 25	WF	App	12.1	4/1/2020	-	-	-	None	-	-	-
1036-1	Room 26	SK	App	4.93	4/1/2020	-	-	-	None	-	-	-
1036-2	Room 26	WF	App	9.08	4/1/2020	-	-	-	None	-	-	-
1037-1	Room 27	SK	App	9.87	4/1/2020	-	-	-	None	-	-	-
1037-2	Room 27	WF	App	3.86	4/1/2020	-	-	-	None	-	-	-
1038-1	Room 28	SK	App	14	4/1/2020	-	-	-	None	-	-	-
1038-2	Room 28	WF	App	15.2	4/1/2020	-	-	-	None	Fixture Replacement	13.2	6/24/20
1039-1	Custodial Closet by Room 28	SS	N/A		4/1/2020	-	-	-	Sign Required			

Connetquot CSD  
Idle Hour Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	Latest 1 <sup>st</sup> Draw Results (ppb)	Latest 1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1040-1	Room 29	SK	App	12.3	4/1/2020	-	-	-	None	-	-	-
1040-2	Room 29	WF	App	17.1	4/1/2020	-	-	-	None	Fixture Replacement	3.79	6/24/20
1041-1	Room 30	SK	App	16.3	4/1/2020	-	-	-	None	Fixture Replacement	3.55	6/24/20
1041-2	Room 30	WF	App	10.7	4/1/2020	-	-	-	None	-	-	-
1042-1	Room 31	SK	App	5.44	4/1/2020	-	-	-	None	-	-	-
1042-2	Room 31	WF	App	4.99	4/1/2020	-	-	-	None	-	-	-
1043-1	Room 32	SK	App	14.7	4/1/2020	-	-	-	None	-	-	-
1043-2	Room 32	WF	App	12.7	4/1/2020	-	-	-	None	-	-	-
1044-1	Room 33	SK	App	19.3	4/1/2020	-	-	-	None	Fixture Replacement	11.1	6/24/20
1044-2	Room 33	WF	App	13.9	4/1/2020	-	-	-	None	-	-	-
1045-1	Room 34 Art Room	SK	App	3.71	4/1/2020	-	-	-	None	SIGN	-	-
1045-2	Room 34 Art Room	WF	App	4.92	4/1/2020	-	-	-	None	-	-	-
1046-1	Room 35 Teacher's Room	SK	App	6.7	4/1/2020	-	-	-	None	-	-	-
1047-1	Room 36 Reading Room	SK	App	14.2	4/1/2020	-	-	-	None	-	-	-
1047-2	Room 36 Reading Room	WF	App	14.4	4/1/2020	-	-	-	None	-	-	-
1048-1	Men's Bathroom by Room 37 @ A	SK	N/A	-	4/1/2020	-	-	-	None	SIGN	-	-
1048-2	Men's Bathroom by Room 37 @ B	SK	N/A	-	4/1/2020	-	-	-	None	SIGN	-	-
1049-1	Women's Bathroom by 37 @ A	SK	N/A	-	4/1/2020	-	-	-	None	SIGN	-	-
1049-2	Women's Bathroom by 37 @ B	SK	N/A	-	4/1/2020	-	-	-	None	SIGN	-	-



**Laboratory Report**  
NYE Report #: 2202291-14725

June 29, 2020

Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Idle Hour Elementary, Connetquot, NY

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 26, 2020. New York Environmental analyzed the samples on June 26, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	23 Jun 2020
Date Received:	26 Jun 2020
Date Analyzed:	26 Jun 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200626J010	1	Kitchen Handwash @ A-SK; Initial	1.00	3.17	µg/L	
200626J011	2	Kitchen Bathroom-SK; Initial	1.00	15.8	µg/L	H
200626J012	3	Room 7 -WF; Initial	1.00	12.1	µg/L	
200626J013	4	Room 8-SK; Initial	1.00	7.39	µg/L	
200626J014	5	Room 11 Counter by Dishwasher-SK; Initial	1.00	8.41	µg/L	
200626J015	6	Room 23-SK; Initial	1.00	10.6	µg/L	
200626J016	7	Room 28-SK; Initial	1.00	13.2	µg/L	
200626J017	8	Room 29-SK; Initial	1.00	3.79	µg/L	
200626J018	9	Room 30-SK; Initial	1.00	3.55	µg/L	
200626J019	10	Room 33-SK; Initial	1.00	11.1	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



**Laboratory Report**  
NYE Report #: 2202590-14905

July 17, 2020

Project Manager  
Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Idle Hour Elementary School Connetquot, NY

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on July 16, 2020. New York Environmental analyzed the samples on July 17, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



---

Li Tsang, Laboratory Director



Date Collected:	15 Jul 2020
Date Received:	16 Jul 2020
Date Analyzed:	17 Jul 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

<u>Lab ID</u>	<u>CID</u>	<u>Sample Location/Description</u>	<u>LOQ</u>	<u>Result</u>	<u>Units</u>	<u>Flag</u>
200716Q008	1	Kitchen Bathroom-SK, Initial	1.00	5.78	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

Connetquot CSD  
John Pearl Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Custodial Closet by Gymnasium	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1002-1	Men's Bathroom by Main Entrance	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1003-1	Women's Bathroom by Main Entrance	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1004-1	Room 1	SK	App	29.9	4/2/2020	-	-	-	None	Fixture Replacement	3.08	7/14/20
1005-1	Nurse's Office	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1005-2	Nurse's Office Bathroom	SK	App	4.15	4/2/2020	-	-	-	None	-	-	-
1006-1	Room 2	SK	App	7.43	4/2/2020	-	-	-	None	-	-	-
1006-2	Room 2	WF	App	2.06	4/2/2020	-	-	-	None	-	-	-
1006-3	Room 2 / Room 4 Bathroom	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1007-1	Room 3	SK	App	9.5	4/2/2020	-	-	-	None	-	-	-
1007-2	Room 3	WF	App	1.94	4/2/2020	-	-	-	None	-	-	-
1007-3	Room 3 / Room 5 Bathroom	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1008-1	Room 4	SK	App	8.25	4/2/2020	-	-	-	None	-	-	-
1008-2	Room 4	WF	App	1.65	4/2/2020	-	-	-	None	-	-	-
1008-3	Room 4 / Room 6 Bathroom	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1009-1	Room 5	SK	App	7.32	4/2/2020	-	-	-	None	-	-	-
1009-2	Room 5	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1009-3	Room 5 / Room 7 Bathroom	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1010-1	Room 6	SK	App	11.6	4/2/2020	-	-	-	None	-	-	-
1010-2	Room 6	WF	App	2.67	4/2/2020	-	-	-	None	-	-	-

Connetquot CSD  
John Pearl Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1010-3	Room 6 Bathroom	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1011-1	Room 7	SK	App	6.14	4/2/2020	-	-	-	None	-	-	-
1011-2	Room 7	WF	App	3.92	4/2/2020	-	-	-	None	-	-	-
1012-1	Custodial Closet by Room 7	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1013-1	Room 8	SK	App	7.91	4/2/2020	-	-	-	None	-	-	-
1013-2	Room 8	WF	App	3.02	4/2/2020	-	-	-	None	-	-	-
1014-1	Room 9	SK	App	4.24	4/2/2020	-	-	-	None	-	-	-
1014-2	Room 9	WF	App	2.51	4/2/2020	-	-	-	None	-	-	-
1015-1	Room 10	SK	App	3.7	4/2/2020	-	-	-	None	-	-	-
1015-2	Room 10	WF	App	2.17	4/2/2020	-	-	-	None	-	-	-
1016-1	Kindergarten Atrium - left	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1016-2	Kindergarten Atrium - right	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1017-1	Custodial Closet by Kindergarten Atrium	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1018-1	Bathroom by Kindergarten Atrium	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1019-1	Hall by Room 17 - left	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1019-2	Hall by Room 17 - right	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1020-1	Women's Bathroom by Room 17	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1021-1	Girls Bathroom by Room 17 @ A	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1021-2	Girls Bathroom by Room 17 @ B	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1021-3	Girls Bathroom by Room 17 @ C	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-

Connetquot CSD  
John Pearl Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1021-4	Girl's Bathroom by Room 17 @ D	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1022-1	Boy's Bathroom by Room 17 @ A	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1022-2	Boy's Bathroom by Room 17 @ B	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1022-3	Boy's Bathroom by Room 17 @ C	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1022-4	Boy's Bathroom by Room 17 @ D	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1023-1	Men's Bathroom by Room 17	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1024-1	Custodial Closet by Room 17	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1025-1	Room 19	SK	App	6.04	4/2/2020	-	-	-	None	-	-	-
1025-2	Room 19	WF	App	13.8	4/2/2020	-	-	-	None	-	-	-
1026-1	Room 20	SK	App	10.8	4/2/2020	-	-	-	None	-	-	-
1026-2	Room 20	WF	App	8.74	4/2/2020	-	-	-	None	-	-	-
1027-1	Room 22	SK	App	3.47	4/2/2020	-	-	-	None	-	-	-
1027-2	Room 22	WF	App	1.57	4/2/2020	-	-	-	None	-	-	-
1028-1	Room 21	SK	App	5.64	4/2/2020	-	-	-	None	-	-	-
1028-2	Room 21	WF	App	2.71	4/2/2020	-	-	-	None	-	-	-
1029-1	Room 24	SK	App	4.14	4/2/2020	-	-	-	None	-	-	-
1029-2	Room 24	WF	App	1.5	4/2/2020	-	-	-	None	-	-	-
1030-1	Room 23	SK	App	5.37	4/2/2020	-	-	-	None	-	-	-
1030-2	Room 23	WF	App	2.37	4/2/2020	-	-	-	None	-	-	-
1031-1	Room 26	SK	App	2.45	4/2/2020	-	-	-	None	-	-	-



Connetquot CSD  
John Pearl Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1031-2	Room 26	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1032-1	Room 27	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1033-1	Custodial Closet by Room 27	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1034-1	Hall by Cafeteria	WF	App	1.42	4/2/2020	-	-	-	None	-	-	-
1034-2	Hall by Cafeteria	WF	App	1.24	4/2/2020	-	-	-	None	-	-	-
1035-1	Cafeteria	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1035-2	Cafeteria	BF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1036-1	Kitchen Potfiller	PF	N/A		4/2/2020	-	-	-	None	CAPPED	-	-
1036-2	Kitchen Prep @ A	SPY	App	12.7	4/2/2020	-	-	-	None	-	-	-
1036-3	Kitchen Prep @ B	SK	App	23.9	4/2/2020	-	-	-	None	Fixture Replacement	6.26	7/14/20
1036-4	Kitchen Handwash	SK	App	6.47	6/23/2020	-	-	-	None	-	-	-
1036-5	Kitchen 3-Bay @ A	SPY	App	5.29	4/2/2020	-	-	-	None	-	-	-
1036-6	Kitchen 3-Bay @ B	SK	App	4.61	4/2/2020	-	-	-	None	-	-	-
1036-7	Kitchen by Disposal	SK	N/A	24.3	4/2/2020	-	-	-	None	SIGN	23.2	7/14/20
1036-8	Kitchen Island	SK	App	3.29	4/2/2020	-	-	-	None	-	-	-
1036-9	Kitchen Bathroom	SK	App	5.43	4/2/2020	-	-	-	None	-	-	-
1037-1	Women's Bathroom by Cafeteria	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1038-1	Men's Bathroom by Cafeteria	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1039-1	Library Office	SK	App	10.4	4/2/2020	-	-	-	None	-	-	-
1040-1	Faculty Room	SK	App	1.01	4/2/2020	-	-	-	None	-	-	-

Connetquot CSD  
John Pearl Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1041-1	Girl's Bathroom by Faculty Room @ A	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1041-2	Girl's Bathroom by Faculty Room @ B	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1042-1	Boy's Bathroom by Faculty Room	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1043-1	Hall by Main Office	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1043-2	Hall by Main Office	BF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
0001-1	Basement Bathroom	SK	App	101	4/2/2020				None	Fixture Replacement	7.41	7/14/20



**Laboratory Report**  
NYE Report #: 2202294-14728

June 29, 2020

Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: John Pearl Elementary, Connetquot, NY

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 26, 2020. New York Environmental analyzed the samples on June 26, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	23 Jun 2020
Date Received:	26 Jun 2020
Date Analyzed:	26 Jun 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200626J026	1	Room 1-SK; Initial	1.00	30.8	µg/L	H
200626J027	2	Kitchen Prep @ B-SK; Initial	1.00	30.3	µg/L	H
200626J028	3	Kitchen Handwash-SK; Initial	1.00	6.47	µg/L	
200626J029	4	Kitchen by Disposal-SK; Initial	1.00	26.2	µg/L	H
200626J030	5	Basement Bathroom-SK; Initial	1.00	20.2	µg/L	H

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



**Laboratory Report**  
NYE Report #: 2202587-14903

July 17, 2020

Project Manager  
Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: 19457 John Pearl Elementary School Connetquot, NY

Dear Project Manager,

Enclosed is the Laboratory Analytical Report for potable water sample(s) received on July 16, 2020. New York Environmental analyzed the samples on July 17, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



Li Tsang, Laboratory Director

Date Collected:	14 Jul 2020
Date Received:	16 Jul 2020
Date Analyzed:	17 Jul 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200716Q001	1	Room 1-SK, Initial	1.00	3.08	µg/L	
200716Q002	2	Kitchen Prep @ B-SK, Initial	1.00	6.26	µg/L	
200716Q003	3	Kitchen by Disposal, Initial	1.00	23.2	µg/L	H
200716Q004	4	Basement Bathroom, Initial	1.00	7.41	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation

H: Sample result exceeds applicable regulatory limit.



Connetquot CSD  
Slocum Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
0001-1	Basement - Old Teacher's Lounge	SK	App	47.7	4/2/2020				None	CAPPED		
1001-1	Kitchen Bathroom	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1001-2	Kitchen Handwash	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1001-3	Kitchen 3-Bay @ A	SK	App	1.6	4/2/2020	-	-	-	None	-	-	-
1001-4	Kitchen 3-Bay @ B	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1001-5	Kitchen 3-Bay	SPY	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1001-6	Kitchen Island Handwash	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1001-7	Kitchen Island Food Prep	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1002-1	Cafeteria	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1002-2	Cafeteria	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1003-1	Girl's Bathroom by Cafeteria @A	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1003-2	Girl's Bathroom by Cafeteria @B	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1003-3	Girl's Bathroom by Cafeteria @C	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1003-4	Girl's Bathroom by Cafeteria @D	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1004-1	Hall by Room 25	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1004-2	Hall by Room 25	BF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1005-1	Room 23	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1005-2	Room 23	WF	App	1.37	4/2/2020	-	-	-	None	-	-	-
1006-1	Room 21	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1006-2	Room 21	WF	App	1.3	4/2/2020	-	-	-	None	-	-	-

Connetquot CSD  
Slocum Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1007-1	Room 20	SK	App	1.08	4/2/2020	-	-	-	None	-	-	-
1007-2	Room 20	WF	App	1.36	4/2/2020	-	-	-	None	-	-	-
1008-1	Boy's Bathroom by Room 19 @A	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1008-2	Boy's Bathroom by Room 19 @B	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1008-3	Boy's Bathroom by Room 19 @C	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1008-4	Boy's Bathroom by Room 19 @D	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1009-1	Room 19	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1009-2	Room 19	WF	App	1.19	4/2/2020	-	-	-	None	-	-	-
1010-1	Room 17	SK	App		4/2/2020	-	-	-	Non-functioning Sampling Required	-	-	-
1010-2	Room 17	WF	App		4/2/2020	-	-	-	Non-functioning Sampling Required	-	-	-
1011-1	Library Lounge	SK	App	7.41	4/2/2020	-	-	-	None	-	-	-
1012-1	Room 16	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1012-2	Room 16	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1013-1	Room 15	SK	App	5.14	4/2/2020	-	-	-	None	-	-	-
1013-2	Room 15	WF	App	3.13	4/2/2020	-	-	-	None	-	-	-
1014-1	Boy's Bathroom by Room 10 @A	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1014-2	Boy's Bathroom by Room 10 @B	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1015-1	Custodial Closet by Room 10	SS	N/A		4/2/2020	-	-	-	Sign Required	-	-	-
1016-1	Girl's Bathroom by Room 11 @A	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1016-2	Girl's Bathroom by Room 11 @B	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-



Connetquot CSD  
Slocum Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1017-1	Room 12	SK	App	2.36	4/2/2020	-	-	-	None	-	-	-
1017-2	Room 12	WF	App	3.56	4/2/2020	-	-	-	None	-	-	-
1018-1	Room 14	SK	App	3.65	4/2/2020	-	-	-	None	-	-	-
1018-2	Room 14	WF	App	1.15	4/2/2020	-	-	-	None	-	-	-
1019-1	Room 13	SK	App	7.53	4/2/2020	-	-	-	None	-	-	-
1019-2	Room 13	WF	App	7.76	4/2/2020	-	-	-	None	-	-	-
1020-1	Room 11	SK	App	1.48	4/2/2020	-	-	-	None	-	-	-
1020-2	Room 11	WF	App	1.95	4/2/2020	-	-	-	None	-	-	-
1021-1	Room 9	WF	App	1.24	4/2/2020	-	-	-	None	-	-	-
1022-1	Boy's Bathroom by Room 6	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1023-1	Girl's Bathroom by Room 6 @A	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1023-2	Girl's Bathroom by Room 6 @B	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1024-1	ADA Bathroom by Gym	SK	App	1.98	4/2/2020	-	-	-	None	-	-	-
1025-1	Hall by Gym - left	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1025-2	Hall by Gym - right	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1026-1	Custodial Closet by Gym	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1027-1	Kindergarten Atrium	SK	App	6.18	4/2/2020	-	-	-	None	-	-	-
1027-2	Kindergarten Atrium	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1028-1	Room 4	SK	App	1.11	4/2/2020	-	-	-	None	-	-	-
1028-2	Room 4	WF	App	3.34	4/2/2020	-	-	-	None	-	-	-

Connetquot CSD  
Slocum Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1029-1	Room 3	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1029-2	Room 3	WF	App	2.71	4/2/2020	-	-	-	None	-	-	-
1030-1	Room 2	SK	App	2.88	4/2/2020	-	-	-	None	-	-	-
1030-2	Room 2	WF	App	5.87	4/2/2020	-	-	-	None	-	-	-
1031-1	Room 1	SK	App	1.49	4/2/2020	-	-	-	None	-	-	-
1031-2	Room 1	WF	App	1.68	4/2/2020	-	-	-	None	-	-	-
1032-1	Main Office Kitchen	SK	App	2.09	4/2/2020	-	-	-	None	-	-	-
1033-1	Men's Bathroom by Main Office @A	SK	App	3.97	4/2/2020	-	-	-	None	-	-	-
1033-2	Men's Bathroom by Main Office @B	SK	App	3.91	4/2/2020	-	-	-	None	-	-	-
1033-3	Men's Bathroom by Main Office @C	SK	App	3.23	4/2/2020	-	-	-	None	-	-	-
1034-1	Custodial Closet by Main Office	SS	N/A		4/2/2020	-	-	-	Sign Required	-	-	-
1035-1	Women's Bathroom by Main Office @A	SK	App	9.96	4/2/2020	-	-	-	None	-	-	-
1035-2	Women's Bathroom by Main Office @B	SK	App	1.86	4/2/2020	-	-	-	None	-	-	-
1035-3	Women's Bathroom by Main Office @C	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1036-1	Principal's Office Bathroom	SK	N/A		4/2/2020	-	-	-	Sign Required	-	-	-
1037-1	Art Room 31	SK	App	4.74	4/2/2020	-	-	-	None	-	-	-
1037-2	Art Room 31	SK	App	1.86	4/2/2020	-	-	-	None	-	-	-
1038-1	Nurse's Office	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1038-2	Nurse's Office Bathroom	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1039-1	Girl's Bathroom by Room 38 @A	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-

**Connetquot CSD  
Slocum Elementary School**

**School Water Outlet Inventory**

**Lead in School Drinking Water Program 2020**

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1039-2	Girl's Bathroom by Room 38 @B	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1039-3	Girl's Bathroom by Room 38 @C	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1040-1	Boy's Bathroom by Room 37 @A	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1040-2	Boy's Bathroom by Room 37 @B	SK	N/A		4/2/2020	-	-	-	Mixed Valve Sampling Not Required	-	-	-
1041-1	Faculty Room 36	SK	App	3.72	4/2/2020	-	-	-	None	-	-	-
1042-1	Hall by Basement Door - left	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1042-2	Hall by Basement Door - right	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1001-1	Kitchen 2-Bay @ A	SK	App	3.22	4/2/2020	-	-	-	None	-	-	-
1001-2	Kitchen 2-Bay @ B	SPY	App	4.32	4/2/2020	-	-	-	None	-	-	-
1001-3	Kitchen 3-Bay @ A	SK	App	21.7	4/2/2020				None	Fixture Replacement	11.8	6/24/20
1001-4	Kitchen 3-Bay @ B	SK	App	20.8	4/2/2020				None	Fixture Replacement	12.5	6/24/20
1001-5	Kitchen Bathroom	SK	App	5.64	4/2/2020	-	-	-	None	-	-	-
1002-1	Cafeteria by Storage C	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1002-2	Cafeteria by Storage B	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1002-3	Cafeteria Storage B	SP	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1002-4	Cafeteria Storage C	SS	N/A		4/2/2020	-	-	-	Sign Required	-	-	-
1003-1	Room 125 @ A	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1003-2	Room 125 @ B	SK	App	6.84	4/2/2020	-	-	-	None	SIGN	-	-
1003-3	Room 125 @ C	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1004-1	Boy's Locker Room	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1004-2	Boy's Locker Room Bathroom @ A	SK	App	25.9	4/2/2020				None	Fixture Replacement	8.56	6/24/20
1004-3	Boy's Locker Room Bathroom @ B	SK	App	30	4/2/2020				None	Fixture Replacement	11.3	6/24/20
1004-4	Boy's Locker Room Coach's Office	SK	App	1.73	4/2/2020	-	-	-	None	-	-	-
1005-1	Girl's Locker Room	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1005-2	Girl's Locker Room Bathroom @ A	SK	App	7.17	4/2/2020	-	-	-	None	-	-	-
1005-3	Girl's Locker Room Bathroom @ B	SK	App	10.1	4/2/2020	-	-	-	None	-	-	-
1005-4	Girl's Locker Room Coach's Office	SK	App	4.79	4/2/2020	-	-	-	None	-	-	-



Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1006-1	Men's Bathroom by Auditorium	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1007-1	Hall by Auditorium	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1007-2	Hall by Auditorium	BF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1008-1	Women's Bathroom by Auditorium	SK	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1009-1	Staff Room	SK	App	3.93	4/2/2020	-	-	-	None	-	-	-
1009-2	Staff Room	SPY	App	2.23	4/2/2020	-	-	-	None	-	-	-
1010-1	Main Office Conference Room	SK	App	1.46	4/2/2020	-	-	-	None	-	-	-
1010-2	Main Office Bathroom	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1011-1	Nurse's Office	SK	N/A	<1.0	4/2/2020	-	-	-	None	SIGN	-	-
1011-2	Nurse's Office by Cots	SK	App	6.9	4/2/2020	-	-	-	None	-	-	-
1011-3	Nurse's Office Bathroom	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1012-1	Custodial Closet by Custodial Office	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1013-1	Library Office	SK	App	11.6	4/2/2020	-	-	-	None	-	-	-
1014-1	Room 107	SK	App	3.08	4/2/2020	-	-	-	None	-	-	-
1014-2	Room 107	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1015-1	Room 108	SK	App	1.99	4/2/2020	-	-	-	None	-	-	-
1015-2	Room 108	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1016-1	Hall by Room 108 - left	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1016-2	Hall by Room 108 - right	BF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1017-1	Room 109	SK	App	3.19	4/2/2020	-	-	-	None	-	-	-

Connetquot CSD  
Sycamore Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1017-2	Room 109	WF	App	1.43	4/2/2020	-	-	-	None	-	-	-
1018-1	Boy's Bathroom by Library @ A	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1018-2	Boy's Bathroom by Library @ B	SK	App	1.97	4/2/2020	-	-	-	None	SIGN	-	-
1018-3	Boy's Bathroom by Library @ C	SK	App	4.99	4/2/2020	-	-	-	None	SIGN	-	-
1019-1	Girl's Bathroom by Library @ A	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1019-2	Girl's Bathroom by Library @ B	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1019-3	Girl's Bathroom by Library @ C	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1019-4	Girl's Bathroom by Library @ D	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1019-5	Girl's Bathroom by Library @ E	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1020-1	Room 110	SK	App	6.56	4/2/2020	-	-	-	None	-	-	-
1020-2	Room 110	WF	App	5.79	4/2/2020	-	-	-	None	-	-	-
1021-1	Room 111	SK	App	2.59	4/2/2020	-	-	-	None	-	-	-
1021-2	Room 111	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1022-1	Room 112	SK	App	5.05	4/2/2020	-	-	-	None	-	-	-
1022-2	Room 112	WF	App	1.2	4/2/2020	-	-	-	None	-	-	-
1023-1	Room 113	SK	App	6.41	4/2/2020	-	-	-	None	-	-	-
1023-2	Room 113	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1024-1	Room 114	SK	App	16.9	4/2/2020				None	Fixture Replacement	7.74	6/24/20
1024-2	Room 114	WF	App	21.2	4/2/2020				None	CAPPED		
1025-1	Room 115	SK	App	19.8	4/2/2020				None	Fixture Replacement	11.6	6/24/20



Connetquot CSD  
Sycamore Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1 <sup>st</sup> Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
1025-2	Room 115	WF	App	20.4	4/2/2020				None	CAPPED		
1026-1	Room 116	SK	App	9.7	4/2/2020	-	-	-	None	-	-	-
1026-2	Room 116	WF	App	1.18	4/2/2020	-	-	-	None	-	-	-
1027-1	Room 117	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1028-1	Bathroom by Elevator	SK	App	4.33	4/2/2020	-	-	-	None	-	-	-
1029-1	Custodial Closet by Elevator	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
1030-1	Room 120	SK	App	1.48	4/2/2020	-	-	-	None	-	-	-
1030-2	Room 120	SK	App	3.55	4/2/2020	-	-	-	None	-	-	-
1031-1	Room 121	SK	App	1.68	4/2/2020	-	-	-	None	-	-	-
1031-2	Room 121	SK	App	4.07	4/2/2020	-	-	-	None	-	-	-
1032-1	Room 122	SK	App	3.9	4/2/2020	-	-	-	None	-	-	-
1032-2	Room 122	SK	App	3.65	4/2/2020	-	-	-	None	-	-	-
1033-1	Room 123	SK	App	4.76	4/2/2020	-	-	-	None	-	-	-
1033-2	Room 123	SK	App	10	4/2/2020	-	-	-	None	-	-	-
1034-1	Room 124	SK	App	1.14	4/2/2020	-	-	-	None	-	-	-
1034-2	Room 124	SK	App	2.88	4/2/2020	-	-	-	None	-	-	-
1035-1	Kindergarten Atrium - left	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
1035-2	Kindergarten Atrium - right	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
2001-1	Custodial Closet by Room 201	SS	N/A		4/2/2020	-	-	-	None	SIGN	-	-
2002-1	Hall by Room 201	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-

Connetquot CSD  
Sycamore Elementary School

School Water Outlet Inventory

Lead in School Drinking Water Program 2020

Space #	Sample Location	Fixture Type	App or N/A	1 <sup>st</sup> Draw Results (ppb)	1st Draw Sampling Date	15 Second Draw Results (ppb)	60 Second Draw Results (ppb)	Flush Sampling Date	Remedial Recommendation	Remedial Response	Post Remedial Results (ppb)	Post Remedial Sampling Date
2002-2	Hall by Room 201	BF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
2003-1	Bathroom by Room 207	SK	App	4.9	4/2/2020	-	-	-	None	-	-	-
2004-1	Boy's Bathroom by Room 208 @ A	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
2004-2	Boy's Bathroom by Room 208 @ B	SK	App	6.81	4/2/2020	-	-	-	None	-	-	-
2004-3	Boy's Bathroom by Room 208 @ C	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
2005-1	Girl's Bathroom by bRoom 208 @ A	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
2005-2	Girl's Bathroom by bRoom 208 @ B	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
2005-3	Girl's Bathroom by bRoom 208 @ C	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
2005-4	Girl's Bathroom by bRoom 208 @ D	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
2005-5	Girl's Bathroom by bRoom 208 @ E	SK	N/A		4/2/2020	-	-	-	None	SIGN	-	-
2006-1	Hall by Room 216 - left	WF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
2006-2	Hall by Room 216 - right	BF	App	<1.0	4/2/2020	-	-	-	None	-	-	-
2007-1	Room 216 Unit 1	SK	App	5.17	4/2/2020	-	-	-	None	-	-	-
2007-2	Room 216 Unit 2	SK	App	3.59	4/2/2020	-	-	-	None	-	-	-

**Laboratory Report**  
NYE Report #: 2202290-14724

June 29, 2020

Enviroscience Consultants, Inc.  
2150 Smithtown Avenue  
Ronkonkoma, NY 11779

Project: Sycamore Elementary, Connetquot, NY

Dear Project Manager,


Enclosed is the Laboratory Analytical Report for potable water sample(s) received on June 26, 2020. New York Environmental analyzed the samples on June 26, 2020 for Lead (Pb) by EPA Method 200.9 Rev. 2.2.

If there are any questions regarding the analyses, please feel free to contact us at your convenience. New York Environmental is a NELAP accredited laboratory. Attached reported results meet the requirements of the NELAP standards unless otherwise noted.

Samples' analytical results relate only to the samples tested, in the condition received by the laboratory. This report shall not be reproduced except in its entirety without written approval of the laboratory.

We sincerely thank you for your business, and look forward to being of service for your future environmental testing needs.

Sincerely,



---

Li Tsang, Laboratory Director

Date Collected:	23 Jun 2020
Date Received:	26 Jun 2020
Date Analyzed:	26 Jun 2020

Analytical Method:	EPA 200.9 Rev. 2.2
Analyte, Matrix:	Lead, Potable Water

Lab ID	CID	Sample Location/Description	LOQ	Result	Units	Flag
200626J004	1	Kitchen 3-Bay @ A-SK; Initial	1.00	11.8	µg/L	
200626J005	2	Kitchen 3-Bay @ B-SK; Initial	1.00	12.6	µg/L	
200626J006	3	Boy's Locker Room Bathroom @ A-WF; Initial	1.00	8.56	µg/L	
200626J007	4	Boy's Locker Room Bathroom @ B-SK; Initial	1.00	11.3	µg/L	
200626J008	5	Room 114-SK; Initial	1.00	7.74	µg/L	
200626J009	6	Room 115-SK; Initial	1.00	11.6	µg/L	

Comment:

CID: Client ID LOQ: Limit of Quantitation