



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

Jim Eberts
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

2/3/2017

Phone: (856) 205-1077
Fax: (856) 205-0413

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 1/25/2017. The results are tabulated on the attached data pages for the following client designated project:

Delsea High School

The reference number for these samples is EMSL Order #011700712. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.
NELAP Certifications: NJ 03036, NY 10872, PA 68-00367, CA ELAP 187

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700712

CustomerID: EPIC62

CustomerPO: 16-4340

ProjectID:

Attn: **Jim Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 01/25/17 10:50 AM

Project: **Delsea High School****Analytical Results**

Client Sample Description DHS-FB
Field Blank
Collected: 1/22/2017 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-CS-01-C106
Room C-106 Sink
Collected: 1/22/2017 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.84	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-SO-01-MEDIA
Media Center Conf Rm
Collected: 1/22/2017 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-WC-02-HALL5
Hall by N203
Collected: 1/22/2017 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-WC-01-HALL3
Main Hall by Auditorium
Collected: 1/22/2017 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.77	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-SO-01-MNOFF
Main Office Kitchen
Collected: 1/22/2017 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.93	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-NS-01-NURSE2
Nurse's Office Restroom
Collected: 1/22/2017 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.89	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700712

CustomerID: EPIC62

CustomerPO: 16-4340

ProjectID:

Attn: **Jim Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 01/25/17 10:50 AM

Project: **Delsea High School****Analytical Results**

<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
DHS-NS-01-NURSE1 Nurse's Office		1/22/2017			0014			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	7.77	1.00	µg/L	1/27/2017	AE	1/27/2017	BB
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
DHS-WC-01-HALL2 Hall by Nurse's Office		1/22/2017			0016			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
DHS-WC-02-HALL4 Hall by S-205		1/22/2017			0018			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
DHS-WC-01-GYMLOB2 Gym Lobby Hall Center		1/22/2017			0020			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
DHS-WC-01-GYMLOB1 Gym Lobby Hall Left		1/22/2017			0022			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
DHS-SC-01-CONCES Concession Stand		1/22/2017			0024			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	1.14	1.00	µg/L	1/27/2017	AE	1/27/2017	BB
<i>Client Sample Description</i>		<i>Collected:</i>			<i>Lab ID:</i>			
DHS-WC-02-HALL3 Hall Right by Rm C216		1/22/2017			0026			
<i>Method</i>	<i>Parameter</i>	<i>Result</i>	<i>RL</i>	<i>Units</i>	<i>Prep Date</i>	<i>Analyst</i>	<i>Analysis Date</i>	<i>Analyst</i>
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700712

CustomerID: EPIC62

CustomerPO: 16-4340

ProjectID:

Attn: **Jim Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 01/25/17 10:50 AM

Project: **Delsea High School****Analytical Results**

Client Sample Description DHS-WC-02-HALL2
Hall Center by Rm C216
Collected: 1/22/2017 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-WC-01-WEIGHT1
Weight Room Left Side
Collected: 1/22/2017 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-WC-01-GYM2
Gym by Weight Room
Collected: 1/22/2017 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.97	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-WC-01-WEIGHT2
Weight Room Right Side
Collected: 1/22/2017 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-WC-01-HALL6
Hallway Right by E104
Collected: 1/22/2017 **Lab ID:** 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/30/2017	AE	1/30/2017	SM

Client Sample Description DHS-CS-01-E106
Room E106
Collected: 1/22/2017 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-WC-01-HALL4
Hallway by Cafeteria
Collected: 1/22/2017 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.94	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700712

CustomerID: EPIC62

CustomerPO: 16-4340

ProjectID:

Attn: **Jim Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 01/25/17 10:50 AM

Project: **Delsea High School****Analytical Results**

Client Sample Description DHS-IM-01-KITCH
Ice Machine - Kitchen
Collected: 1/22/2017 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-KC-01-KITCH3
Kitchen by Walk-In
Collected: 1/22/2017 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.36	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-KC-01-KITCH2
Kitchen Rear
Collected: 1/22/2017 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.35	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-KC-01-KITCH1
Kitchen by Ovens
Collected: 1/22/2017 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-SO-01-FACDIN
Faculty Dining Room
Collected: 1/22/2017 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.87	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-CS-01-E116
Room E116
Collected: 1/22/2017 **Lab ID:** 0051

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.95	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-SO-01-TRAIN
Trainer's Office
Collected: 1/22/2017 **Lab ID:** 0053

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011700712

CustomerID: EPIC62

CustomerPO: 16-4340

ProjectID:

Attn: **Jim Eberts**
Epic Environmental Services, LLC
1930 Brown Road
Newfield, NJ 08344

Phone: (856) 205-1077
 Fax: (856) 205-0413
 Received: 01/25/17 10:50 AM

Project: **Delsea High School****Analytical Results**

Client Sample Description DHS-WC-01-GLR
 Girl's Locker Room **Collected:** 1/22/2017 **Lab ID:** 0055

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-IM-01-HALL
 Ice Machine - Hall by Gym **Collected:** 1/22/2017 **Lab ID:** 0057

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-HB-01-HALL
 Hall by AD Office **Collected:** 1/22/2017 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.2	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Client Sample Description DHS-WC-01-GYM1
 Gym by Girl's Locker Rm **Collected:** 1/22/2017 **Lab ID:** 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	1/27/2017	AE	1/27/2017	BB

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)