



**Addendum #2**  
Sheldon Irrigation Pump and Mainline

Date: 5 May 2014  
To: Plan Holders  
Fr: Rex Redmon, DLA Inc.  
Re: **Addendum #2**

**CONTRACT CONDITIONS**

This addendum is issued to clarify, change and correct the contract documents dated 23 April 2014 and shall form part of the Contract.

**ITEM 1 – SPECIFICATIONS**

**SUPPLEMENTAL CONDITIONS – DOCUMENT 00 73 00**

1. **This project is to be bid BOLI Wages** – This project will be subject to the current prevailing wage rate in effect at the time the specifications are first advertised for bid.

**ITEM 2 – DRAWINGS**

**SHEET L1.1**

1. Additional 4” isolation valve manufacturer and model approved: Nibco F619-RW-SON.

**WELL AREA**

1. Pump motor to be 15 hp. 240 volt, 3 Phase. Manufactured by Hitachi or equal.

End of Addendum

