



ADDENDUM NO. 1
Page 1 of 2

M028.02

FROM: Systems West Engineers, Inc.
411 High Street
Eugene, Oregon 97401

TO: All Plan Holders of Record

PROJECT: Eugene School District 4j
Edgewood Elementary School
Switchboard Replacement
C.I.P. Project No. 420.780.040

DATE: June 25, 2014

This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated June 17, 2014 as noted below. Acknowledge receipt of this addendum in the space provided on the Quote Form. Failure to do so may subject the proposer to disqualification.

GENERAL

1. General. The District will be responsible for payment of any utility company charges associated with the project.

SPECIFICATIONS

Section 00 11 00 – Summary of Work

1. **ADD** 1.5.G. Provide continuous power to the Fire alarm system, Security system, Telephone system, Data system, and to lighting and receptacles in the main office. Contractor is responsible for providing the generator and fuel during construction operations.

Section 26 05 26 – Grounding and Bonding for Electrical Systems

2. **ADD** 1.02.C. Contractor shall provide new service grounding.

Section 26 24 13 - Switchboards


3. **ADD** 1.01.B. Copies of the switchboard purchase order are attached for reference.

DRAWINGS

Sheet E-121 – Electrical Room Plan

4. **REPLACE** Reference note 4 with the following: Waterproofing material will be installed behind the switchboard by the District. Coordinate schedule to allow sufficient time for installation.

END OF ADDENDUM NO. 1



Jeffrey L. Graper, PE

JLG:kaa

Enclosures: Switchboard Purchase Order/Shop Drawings

\\swe\company\Projects\M028.02\02 Specifications\Edgewood Elem\Addendum\Addenda 1 Edgewood 2014-06-25.docx