

From: School District No. 4J  
Facilities Management  
715 W. 4th Avenue  
Eugene, Oregon 97402

To: All Planholders of Record

**ADDENDUM NUMBER ONE**

**Adams Elementary School Boiler Replacement**

**Addendum date: February 20, 2015**

**Page 1 of 1**

This addendum is issued to clarify, change and correct the Project Manual and Contract Documents and shall form a part of the Contract. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

**GENERAL**

- 1) The Pre-bid tour was mandatory for prime bidders. A copy of the sign-in and plan holders list is attached.
- 2) Question at Pre-Bid meeting: "Is Aquatherm piping approved for new hydronic piping?" Answer: Yes, as specified in Section 23 21 13 paragraph 2.02 B.

**SPECIFICATIONS**

- 1) Section 22 10 05 paragraph 3.03 H: Replace entire paragraph with the following: "Prepare and apply primer to exposed, unfinished iron pipe, fittings, and supports, ready for finish painting. Provide oil-based primer and finish coating system meeting District 4J approval." This paragraph applies only to exterior natural gas piping from meter to exterior wall penetration.

**DRAWINGS**

- 1) Not used.

**END OF ADDENDUM #1**

