

From: School District No. 4J  
Facilities Management  
715 W. 4th Avenue  
Eugene, Oregon 97402

To: All Planholders of Record

**ADDENDUM NUMBER TWO**

**Adams Elementary School Boiler Replacement**

**Addendum date: February 23, 2015**

**Page 1 of 1**

This addendum is issued to clarify, change and correct the Project Manual and Contract Documents and shall form a part of the Contract. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

**GENERAL**

- 1) During the Pre-Bid Site Tour it was noted that the existing 4" HWS Header located approximately 7'AFF is supported on the existing two boilers. PRIOR TO REMOVING ANY PIPING OR EQUIPMENT, CONTRACTOR SHALL PROVIDE VERTICAL STEEL SUPPORT FOR THIS HWS PIPING. Support shall be 2" Schedule 80 steel pipe, welded continuously to a ¼"x 8"sq. steel plate at bottom, and to a saddle support matching the pipe size above. Pipe shall be supported by a calcium silicate insert sized for existing HWS header pipe, and vertical post shall be centered between the two new boilers at approximately the mid-point of the header. Neatly repair pipe insulation following support installation. Bolt base plate to (e)concrete slab using 4 3/8" bolts and epoxy anchors.
- 2) Remove existing ¼" steel checker-plate trench covers in front of existing boilers, level and compact existing crushed rock sub-base material, and pour new slab approximately 4" thick in place of original pipe trenches. Approximate concrete area is 20 square feet. Contractor to field verify existing conditions prior to pouring concrete.

**SPECIFICATIONS**

- 1) (no changes)

**DRAWINGS**

- 1) (no changes)

**END OF ADDENDUM #2**