

From: School District No. 4J
Facilities Management
715 W. 4th Avenue
Eugene, Oregon 97402

To: All Planholders of Record

ADDENDUM NUMBER THREE

Adams Elementary School Boiler Replacement

Addendum date: February 25, 2015

Page 1 of 1

This addendum is issued to clarify, change and correct the Project Manual and Contract Documents and shall form a part of the Contract. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

GENERAL

- 1) Question: Can boiler venting be PVC? Answer: Yes, and the relevant specifications are already included in the Contract Documents (Section 23 51 00).

SPECIFICATIONS

- 1) (no changes)

DRAWINGS

- 1) Drawing M101, Note 6: Change flowmeter model from Coolpoint CP16 to Coolpoint CP32.

END OF ADDENDUM #3