

**FIRE & LIFE SAFETY IMPROVEMENTS - 2015**  
**EUGENE SCHOOL DISTRICT 4J**

Eugene, Oregon  
gLas Project No. 11041.15

**ADDENDUM NUMBER ONE**

March 18, 2015

Page 1 of 1


This addendum is issued to clarify, change, and correct the Project Manual and Contract Documents and shall form a part of the Contract.

**DRAWINGS**

- 1) Sheet A1, Building 31 Educations Center
  - a) At Door Hardware Schedule, add the following item number 2:  
“2. All surface mounted precisions vertical rods are to be less bottom rod (LBR) and are to be through bolted using precision hardware (SNB) screw package.”
  
- 2) Sheet A3, Building 33 Facilities Management Plan:
  - a) At first floor plan, change work item B33, Item 21, from “Add Handrail Extensions” to “Remove and Replace handrail each side per Detail A/502”.
  - b) At Barn First Floor plan, delete note which reads “B33, Item 23, At Shop Building Add Handrail Extensions.”
  - c) At Door Hardware Schedule, add the following item number 2:  
“2. All LCN overhead door closers are to be installed with the WMS Screw Pack. No self-tapping screws allowed.”

**SUBSTITUTION REQUESTS**

No Substitution Requests have been approved.



Walter R Gresl, AIA  
Principal

END OF ADDENDUM NUMBER ONE