

RODD HANSEN, ARCHITECT, L.L.C.
ARCHITECTURE AND PLANNING

Date: August 19, 2015
To: All Prime Bidders
RE: Eugene School District 4j
Adams Elementary School – Classroom Egress Remodel
C.I.P. No. 420.104.100



ADDENDUM #1:

YOU ARE HEREBY DIRECTED TO PERFORM THE FOLLOWING WORK AND INCLUDE THE FOLLOWING WORK IN YOUR BID.

- Item #1: The existing exterior door and all associated demolition and infill work shall be deleted from the contract. Relocating the card reader as shown shall remain in the contract.
- Item #2: The Contractor shall include all costs associated with providing 6' temporary chainlink construction fencing around the work area.
- Item #3: The stemwall thickness shall be revised from 6" thick to 8" thick.

END OF ADDENDUM #1