

RODD HANSEN, ARCHITECT, L.L.C.
ARCHITECTURE AND PLANNING

Date: August 24, 2015
To: All Prime Bidders
RE: Eugene School District 4j
Adams Elementary School – Classroom Egress Remodel
C.I.P. No. 420.104.100



ADDENDUM #2:

YOU ARE HEREBY DIRECTED TO PERFORM THE FOLLOWING WORK AND INCLUDE THE FOLLOWING WORK IN YOUR BID.

- Item #1: Detail 5 / A5.2: The vertical handrail supports shall be 1-1/2" dia. The vertical balusters shall be 1" dia. The handrail shall be 1-1/2" dia.
- Item #2: The entire railing assembly shall have a hot dip galvanized finish.

END OF ADDENDUM #2