

PARKER SIDING 2016
Parker School
C.I.P. No. 420.780.209

ROBERTSON/SHERWOOD/ARCHITECTS pc
132 E. Broadway - Suite 540
Eugene, Oregon
Project No. 1302



This Addendum forms a part of the Contract Documents and modifies the original Quote Documents dated April 4, 2016 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

PROJECT MANUAL

1. INVITATION TO BID – DOCUMENT 00 11 13
 - A. Pre-Quote Conference: A non-mandatory pre-quote conference was held at 9:30 AM on Thursday, April 7 at the site. List of attendees is attached to this Addendum.
2. SUMMARY OF WORK - SECTION 01 11 00
 - A. Article 1.5, Paragraph B: Add the following sentence:
"1. Contractor may use Owner's restroom facilities."
3. METAL WALL PANELS - SECTION 07 42 13
 - A. Article 2.1, Paragraph B: Change Sentences 5 and 6 to read:
"5. Panel Width: 16 inches.
6. Color: Match "Cool Weathered Copper" by AEP Span."
B. Article 2.1, Paragraph F: Add the following sentence:
"3. Versa-Span by Taylor Metal."
C. Article 2.4: Add the following paragraph:
"D. Form bottom of panels with hemmed edge."
4. SHEET METAL FLASHING AND TRIM - SECTION 07 62 00
 - A. Article 2.1, Paragraph B: Change Sentence 2b to read:
"b. Color 1: Match "Cool Weathered Copper" by AEP Span."
B. Article 2.1: Add the following paragraph:
"D. Perforated Sheet:
1. Perforated sheet, Zinalume coating. Coat with galvanized metal primer and two coats exterior alkyd enamel to match "Cool Weathered Copper" by AEP Span."

DRAWINGS

1. **DRAWING SHEET A4**

A. Add the following keynote:

"7. Provide sheet metal to close spaces between bottom of panel and recessed face of concrete masonry wall."

2. **DRAWING SHEET A5**

A. Detail A/A5: Change color of upper sheet metal flashing from "Koala Brown" to "Cool Weathered Copper."

3. **DRAWING SHEET A8**

A. Detail B/A8: Change of color upper sheet metal flashing from "Koala Brown" to "Cool Weathered Copper."

END OF ADDENDUM NO. 1

Sign up sheet:

NON- MANDATORY PRE-QUOTE WALK THRU

Parker Siding 2016

Eugene, Oregon CIP # 420.780.209

Thursday, April 7, 2016

Name	Company	Address	Phone and FAX and e-mail
Rick Kelso	Larrys Sheet Metal	1269 Ocean St. Eugene Oregon 97404	541-344-4823 fax 541-344-2146 larrysheetmetal@unwiredwest.net
Mack Landreth	Smith Sheet Metal	253 South 15th, Springfield Oregon 97477	541-726-9194 fax 541-726-9290 pm@smithsheetmetal.com
Brian Hamilton	Robertson Sherwood Arch.	132 East Broadway, Eugene OR 97402	541-342-8077 fax 541-345-4302 bhamilton@robertsonsherwood.com
Don Philpot	Eugene SD 4J	715 W, 4th Ave, Eugene, OR 97402	541-790-7430 fax 541-790-7420 philpot@4j.lane.edu