

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
César E. Chávez Elementary School											
Health Room Restroom	Sink	7/6/2016	CCES-I-001	1.74							
Office Area	Sink	7/6/2016	CCES-I-002	1.59							
Media Center Restroom	Sink	7/6/2016	CCES-I-003	2.88							
Media Center Upper Fixture	Fountain	7/6/2016	CCES-I-004	0.88							
Media Center Lower Fixture	Fountain	7/6/2016	CCES-I-005	0.71							
B Wing Common Area	Fountain	7/6/2016	CCES-I-006	2.18							
B Wing Common Area	Sink	7/6/2016	CCES-I-007	1.84							
Room B03	Fountain	7/6/2016	CCES-I-008	0.26							
Room B03	Sink	7/6/2016	CCES-I-009	1.09							
Room B04	Fountain	7/6/2016	CCES-I-010	ND							
Room B04	Sink	7/6/2016	CCES-I-011	1.37							
Room B05	Fountain	7/6/2016	CCES-I-012	0.35							
Room B05	Sink	7/6/2016	CCES-I-013	0.60							
Room B02	Fountain	7/6/2016	CCES-I-014	0.24							
Room B02	Sink	7/6/2016	CCES-I-015	0.80							
Room B01	Fountain	7/6/2016	CCES-I-016	0.67							
Room B01	Sink	7/6/2016	CCES-I-017	1.38							
Room B06	Fountain	7/6/2016	CCES-I-018	0.70							
Room B06	Sink	7/6/2016	CCES-I-019	0.80							
B Wing Boys Restroom	Sink	7/6/2016	CCES-I-020	3.01							
B Wing Girls Restroom	Sink	7/6/2016	CCES-I-021	7.27							
B Wing Staff Restroom	Sink	7/6/2016	CCES-I-022	2.32							
Room A04	Fountain	7/6/2016	CCES-I-023	0.68							
Room A04	Sink	7/6/2016	CCES-I-024	1.25							
Room A03	Fountain	7/6/2016	CCES-I-025	0.46							
Room A03	Sink	7/6/2016	CCES-I-026	1.13							
A Wing Common Area	Fountain	7/6/2016	CCES-I-027	1.71							
A Wing Common Area	Sink	7/6/2016	CCES-I-028	2.53							
Room A05	Fountain	7/6/2016	CCES-I-029	0.53							
Room A05	Sink	7/6/2016	CCES-I-030	1.79							
Room A02	Fountain	7/6/2016	CCES-I-031	0.93							
Room A02	Sink	7/6/2016	CCES-I-032	1.41							
Room A06	Fountain	7/6/2016	CCES-I-033	0.52							
Room A06	Sink	7/6/2016	CCES-I-034	1.30							
Room A01	Fountain	7/6/2016	CCES-I-035	1.11							
Room A01	Sink	7/6/2016	CCES-I-036	0.37							
A Wing Girls Restroom	Sink	7/6/2016	CCES-I-037	5.59							
A Wing Boys Restroom	Sink	7/6/2016	CCES-I-038	3.85							
A Wing Staff Restroom	Sink	7/6/2016	CCES-I-039	2.40							
Room E23	Sink	7/6/2016	CCES-I-040	3.40							
C Wing Common Area	Fountain	7/6/2016	CCES-I-041	2.19							
C Wing Common Area	Sink	7/6/2016	CCES-I-042	2.03							
Room C04	Fountain	7/6/2016	CCES-I-043	0.29							

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
César E. Chávez Elementary School											
Room C04	Sink	7/6/2016	CCES-I-044	0.73							
Room C03	Fountain	7/6/2016	CCES-I-045	0.21							
Room C03	Sink	7/6/2016	CCES-I-046	0.89							
Room C05	Fountain	7/6/2016	CCES-I-047	0.38							
Room C05	Sink	7/6/2016	CCES-I-048	1.06							
Room C02	Fountain	7/6/2016	CCES-I-049	0.39							
Room C02	Sink	7/6/2016	CCES-I-050	2.16							
Room C06	Fountain	7/6/2016	CCES-I-051	0.38							
Room C06	Sink	7/6/2016	CCES-I-052	0.67							
Room C01	Fountain	7/6/2016	CCES-I-053	0.79							
Room C01	Sink	7/6/2016	CCES-I-054	0.56							
C Wing Girls Restroom	Sink	7/6/2016	CCES-I-055	5.28							
C Wing Boys Restroom	Sink	7/6/2016	CCES-I-056	5.01							
C Wing Staff Restroom	Sink	7/6/2016	CCES-I-057	3.56							
Room C12	Sink	7/6/2016	CCES-I-058	2.58							
Room D04	Fountain	7/6/2016	CCES-I-059	0.48							
Room D04	Sink	7/6/2016	CCES-I-060	0.77							
Room D03	Fountain	7/6/2016	CCES-I-061	0.68							
Room D03	Sink	7/6/2016	CCES-I-062	0.93							
D Wing Common Area	Fountain	7/6/2016	CCES-I-063	4.28							
D Wing Common Area	Sink	7/6/2016	CCES-I-064	3.31							
Room D05	Fountain	7/6/2016	CCES-I-065	1.13							
Room D05	Sink	7/6/2016	CCES-I-066	0.54							
Room D02	Fountain	7/6/2016	CCES-I-067	0.80							
Room D02	Sink	7/6/2016	CCES-I-068	1.28							
Room D01	Fountain	7/6/2016	CCES-I-069	1.07							
Room D01	Sink	7/6/2016	CCES-I-070	1.12							
Room D06	Fountain	7/6/2016	CCES-I-071	0.57							
Room D06	Sink	7/6/2016	CCES-I-072	0.79							
D Wing Girls Restroom	Sink	7/6/2016	CCES-I-073	4.37							
SD Wing Boys Restroom	Sink	7/6/2016	CCES-I-074	3.70							
D Wing Staff Restroom	Sink	7/6/2016	CCES-I-075	0.39							
Room E-53	Sink	7/6/2016	CCES-I-076	1.92							
E Wing Boys Restroom (West Fixture)	Sink	7/6/2016	CCES-I-077	4.40							
E Wing Boys Restroom (East Fixture)	Sink	7/6/2016	CCES-I-078	7.46							
E Wing Girls Restroom (East Fixture)	Sink	7/6/2016	CCES-I-079	5.00							
E Wing Girls Restroom (West Fixture)	Sink	7/6/2016	CCES-I-080	3.87							
E Wing staff Restroom	Sink	7/6/2016	CCES-I-081	1.21							
Room E45 (Dishwashing Room)	Sink	7/6/2016	CCES-I-082	1.18							
Kitchen (Handwashing Fixture)	Sink	7/6/2016	CCES-I-083	2.93							
Kitchen (Produce Sink - North)	Sink	7/6/2016	CCES-I-084	0.87							
Kitchen (Produce Sink - South)	Sink	7/6/2016	CCES-I-085	0.78							
Kitchen (Prep Area - Handwash Fixture)	Sink	7/6/2016	CCES-I-086	12.60							

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location		First Draw			Flushed Draw			New Fixture First Draw			
César E. Chávez Elementary School	Fixture Type	Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
Gym Entry Vestibule (Upper Fixture)	Fountain	7/6/2016	CCES-I-087	0.48							
Gym Entry Vestibule (Lower Fixture)	Fountain	7/6/2016	CCES-I-088	0.38							
East Wing Stage	Sink	9/6/2016	CCES-I-092	2.14							
East Wing Stage	Fountain	9/6/2016	CCES-I-091	ND							
Staff Room E-53	Insta-Hot	9/6/2016	CCES-I-090	ND							
E22	Sink	9/6/2016	CCES-I-089	3.29							

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.