

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
Pathfinder/Bldg 2120											
Time Out/School Store	Fountain	7/11/2016	PATS-I-001	12.30							
Time Out/School Store	Sink	7/11/2016	PATS-I-002	2.27							
Classroom 1	Fountain	7/11/2016	PATS-I-003	5.34							
Classroom 1	Sink	7/11/2016	PATS-I-004	2.02							
Classroom 2	Fountain	7/11/2016	PATS-I-005	5.59							
Classroom 2	Sink	7/11/2016	PATS-I-006	0.88							
Room 3 Recreation	Fountain	7/11/2016	PATS-I-007	1.51							
Room 3 Recreation	Sink	7/11/2016	PATS-I-008	0.71							
Women's Restroom (Left)	Sink	7/11/2016	PATS-I-009	0.64							
Women's Restroom (Right)	Sink	7/11/2016	PATS-I-010	1.17							
Men's Restroom	Sink	7/11/2016	PATS-I-011	1.08							
Main Hallway	Fountain	7/11/2016	PATS-I-012	ND							
Cafeteria South Wall	Fountain	7/11/2016	PATS-I-013	21.40	8/30/2016	PATS-F-017	12.20	9/1/2016	10/13/2016	PATS-I-019	ND
Cafeteria South Wall	Sink	7/11/2016	PATS-I-014	3.61							
Transition Room	Fountain	7/11/2016	PATS-I-015	23.60	8/30/2016	PATS-F-018	6.97	9/1/2016	10/13/2016	PATS-I-020	1.74
Transition Room	Sink	7/11/2016	PATS-I-016	0.99							

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.