

Eugene School District 4J  
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw			
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
<b>Spring Creek Elementary School</b>											
Kitchen Dishwashing Area	Sprayer	6/22/2016	SCES-I-001	0.83							
Kitchen West Sink	S	6/22/2016	SCES-I-002	12.20							
Kitchen Food Sink (West)	Sink	6/22/2016	SCES-I-003	1.48							
Kitchen Food Sink (East)	Sink	6/22/2016	SCES-I-004	4.00							
Cafeteria Server	Fountain	6/22/2016	SCES-I-005	2.14							
Cafeteria Bldg Girls Restroom (East)	Sink	6/22/2016	SCES-I-006	0.81							
Cafeteria Bldg Girls Restroom (West)	Sink	6/22/2016	SCES-I-007	1.32							
Gymnasium	Fountain	6/22/2016	SCES-I-008	ND							
Cafeteria Bldg Boys Restroom (East)	Sink	6/22/2016	SCES-I-009	1.36							
Cafeteria Bldg Boys Restroom (West)	Sink	6/22/2016	SCES-I-010	1.82							
Cafeteria Bldg East Exterior	Fountain	6/22/2016	SCES-I-011	0.60							
Room 12	Sink	6/22/2016	SCES-I-012	<b>80.90</b>	8/13/2016	SCES-F-065	4.46	8/15/2016	8/15/2016	SCES-I-066	2.79
Room 12	Fountain	6/22/2016	SCES-I-013	0.72							
Room 11	Sink	6/22/2016	SCES-I-014	2.43							
Room 11	Fountain	6/22/2016	SCES-I-015	1.23							
Room 10	Sink	6/22/2016	SCES-I-016	2.18							
Room 10	Fountain	6/22/2016	SCES-I-017	5.91							
Room 9	Sink	6/22/2016	SCES-I-018	2.20							
Room 9	Fountain	6/22/2016	SCES-I-019	2.11							
Building 2 Boys Restroom	Sink	6/22/2016	SCES-I-020	1.92							
Building 2 Girls Restroom	Sink	6/22/2016	SCES-I-021	1.51							
Building 2 Corridor	Fountain	6/22/2016	SCES-I-022	1.20							
Room 8	Sink	6/22/2016	SCES-I-023	0.82							
Room 8	Fountain	6/22/2016	SCES-I-024	11.70							
Room 7	Sink	6/22/2016	SCES-I-025	2.28							
Room 7	Fountain	6/22/2016	SCES-I-026	2.76							
Room 6	Sink	6/22/2016	SCES-I-027	1.00							
Room 6	Fountain	6/22/2016	SCES-I-028	5.82							
Room 5	Sink	6/22/2016	SCES-I-029	3.36							
Room 5	Fountain	6/22/2016	SCES-I-030	0.78							
Room 4	Sink	6/22/2016	SCES-I-031	1.44							
Room 4	Fountain	6/22/2016	SCES-I-032	2.74							
Room 3	Sink	6/22/2016	SCES-I-033	4.73							
Room 3	Fountain	6/22/2016	SCES-I-034	2.76							
Room 2	Sink	6/22/2016	SCES-I-035	2.77							
Room 2	Fountain	6/22/2016	SCES-I-036	3.48							
Room 1	Sink	6/22/2016	SCES-I-037	1.30							
Room 1	Fountain	6/22/2016	SCES-I-038	1.95							
Building 6 Women's Restroom	Sink	6/22/2016	SCES-I-039	3.33							
Building 6 Men's Restroom	Sink	6/22/2016	SCES-I-040	5.84							
Building 6 Administrative Women's Restroom	Sink	6/22/2016	SCES-I-041	1.83							
Building 6 Staff Room	Sink	6/22/2016	SCES-I-042	0.87							
Building 6 Staff Room	Insta-Hot	6/22/2016	SCES-I-043	0.64							

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J  
Water Quality: Lead Testing Results

Eugene School District 4J - Location		First Draw			Flushed Draw			New Fixture First Draw			
Spring Creek Elementary School	Fixture Type	Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)
Building 6 Nurses Office	Sink	6/22/2016	SCES-I-044	1.98							
Building 4 Girls Restroom	Sink	6/22/2016	SCES-I-045	ND							
Building 4 Boys Restroom	Sink	6/22/2016	SCES-I-046	1.20							
Building 4 Corridor	Fountain	6/22/2016	SCES-I-047	1.78							
Room 16	Sink	6/22/2016	SCES-I-048	4.02							
Room 16	Fountain	6/22/2016	SCES-I-049	0.34							
Room 15	Sink	6/22/2016	SCES-I-050	16.20							
Room 15	Fountain	6/22/2016	SCES-I-051	0.21							
Room 14	Sink	6/22/2016	SCES-I-052	2.81							
Room 14	Fountain	6/22/2016	SCES-I-053	1.14							
Room 13	Sink	6/22/2016	SCES-I-054	9.59							
Room 13	Fountain	6/22/2016	SCES-I-055	1.46							
Room 17	Sink	6/22/2016	SCES-I-056	1.43							
Room 17	Fountain	6/22/2016	SCES-I-057	0.21							
Room 18	Sink	6/22/2016	SCES-I-058	6.91							
Room 18	Fountain	6/22/2016	SCES-I-059	0.71							
Room 19	Sink	6/22/2016	SCES-I-060	1.40							
Room 19	Fountain	6/22/2016	SCES-I-061	0.87							
Room 20	Sink	6/22/2016	SCES-I-062	0.71							
Room 20	Fountain	6/22/2016	SCES-I-063	ND							
Restroom West of Kitchen	Sink	8/3/2016	SCES-I-064	12.50							

Using EPA's water sampling method for schools, action level is >20 parts per billion (ppb). Samples that tested above the action level are highlighted.