

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Use	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw					
			Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)
Gym	Drinking Fountain	Fountain	7/13/16	CDES-I-001	1.30													
Kitchen Produce Sink	Sink	Food Preparation	7/13/16	CDES-I-002	4.10													
Kitchen Hand Wash Sink	Sink	Food Preparation	7/13/16	CDES-I-003	3.73													
Cafeteria	Drinking Fountain	Fountain	7/13/16	CDES-I-004	0.42													
Staff Lounge	Other Human Consumption	Sink	7/13/16	CDES-I-005	1.57													
Staff Lounge	Drinking Fountain	Insta-Hot	7/13/16	CDES-I-006	0.27													
Instructional Materials Center	Other Human Consumption	Sink	7/13/16	CDES-I-007	38.90	9/1/16	CDES-F-039	6.48	9/28/16	9/30/16	CDES-I-054	30.80	1. 12/28/16: Removed Tee in Cold Supply. 2. 3/22/17: Replaced angle stops & nipples. 3. 8/17/17: Permanent Label Installed.	1. 2/2/2017 2. 7/13/2017	1. 2/3/2017 2. 7/14/2017	1. 2/10/2017 2. 7/21/2017	1. CDES-I-058 2. CDES-I-062	1. 35.00 2. 154.00
Office Work Room	Other Human Consumption	Sink	7/13/16	CDES-I-008	1.72													
Office Work Room	Drinking Fountain	Fountain	7/13/16	CDES-I-009	1.44													
Office West Restroom	Other Human Consumption	Sink	7/13/16	CDES-I-010	1.32													
Office East Restroom	Other Human Consumption	Sink	7/13/16	CDES-I-011	1.56													
Computer Room	Drinking Fountain	Fountain	7/13/16	CDES-I-012	0.78													
Computer Room	Other Human Consumption	Sink	7/13/16	CDES-I-013	2.75													
Music Room	Other Human Consumption	Sink	7/13/16	CDES-I-014	1.24													
Music Room	Drinking Fountain	Fountain	7/13/16	CDES-I-015	0.25													
Room 9	Drinking Fountain	Fountain	7/13/16	CDES-I-016	0.71													
Room 9	Other Human Consumption	Sink	7/13/16	CDES-I-017	2.39													
C-7 through C9 Workroom	Other Human Consumption	Sink	7/13/16	CDES-I-018	1.54													
C-7 through C9 Workroom East Restroom	Other Human Consumption	Sink	7/13/16	CDES-I-019	1.11													
C-7 through C9 Workroom West Restroom	Other Human Consumption	Sink	7/13/16	CDES-I-020	1.38													
Room 7	Drinking Fountain	Fountain	7/13/16	CDES-I-021	1.05													
Room 7	Other Human Consumption	Sink	7/13/16	CDES-I-022	5.75													
Room 8	Drinking Fountain	Fountain	7/13/16	CDES-I-023	0.89													
Room 8	Other Human Consumption	Sink	7/13/16	CDES-I-024	6.66													
Cluster B Workroom	Drinking Fountain	Fountain	7/13/16	CDES-I-025	1.16													
Cluster B Workroom West Restroom	Other Human Consumption	Sink	7/13/16	CDES-I-026	3.78													
Cluster B Workroom East Restroom	Other Human Consumption	Sink	7/13/16	CDES-I-027	1.25													
Playground Girls Restroom	Other Human Consumption	Sink	7/13/16	CDES-I-028	4.84													
Cluster A Workroom	Drinking Fountain	Fountain	7/13/16	CDES-I-029	1.27													
Cluster A Workroom West Restroom	Other Human Consumption	Sink	7/13/16	CDES-I-030	1.79													
Cluster A Workroom East Restroom	Other Human Consumption	Sink	7/13/16	CDES-I-031	2.10													
Room A3	Other Human Consumption	Sink	7/13/16	CDES-I-032	1.11													
Room A3	Drinking Fountain	Fountain	7/13/16	CDES-I-033	1.14													
Portable P-1	Other Human Consumption	Sink	7/13/16	CDES-I-034	24.90	9/1/16	CDES-F-051	4.10	9/28/16	9/30/16	CDES-I-055	2.30						
Portable P-1	Drinking Fountain	Fountain	7/13/16	CDES-I-035	9.60													
Portable P-2 Restroom	Other Human Consumption	Sink	7/13/16	CDES-I-036	6.20													
Portable P-2	Drinking Fountain	Fountain	7/13/16	CDES-I-037	31.70	9/1/16	CDES-F-052	2.79	9/28/16	9/30/16	CDES-I-056	1.58						
Portable P-2	Other Human Consumption	Sink	7/13/16	CDES-I-038	2070.00	9/1/16	CDES-F-053	5.13	9/28/16	9/30/16	CDES-I-057	6.67						
Room B6	Drinking Fountain	Fountain	9/1/16	CDES-I-040	10.00													
Room B6	Other Human Consumption	Sink	9/1/16	CDES-I-041	6.14													
Room B5	Drinking Fountain	Fountain	9/1/16	CDES-I-042	4.35													
Room B5	Other Human Consumption	Sink	9/1/16	CDES-I-043	9.53													
Room B4	Drinking Fountain	Fountain	9/1/16	CDES-I-044	2.89													
Room B4	Other Human Consumption	Sink	9/1/16	CDES-I-045	2.67													
Room A2	Drinking Fountain	Fountain	9/1/16	CDES-I-046	2.01													
Room A2	Other Human Consumption	Sink	9/1/16	CDES-I-047	2.83													
Room A1	Drinking Fountain	Fountain	9/1/16	CDES-I-048	ND													
Room A1	Other Human Consumption	Sink	9/1/16	CDES-I-049	2.84													
Portable P-1 Front North Restroom	Other Human Consumption	Sink	9/1/16	CDES-I-050	2.81													
Gym Restroom Boys (Fan Faucet replaced w/ std faucet)	Other Human Consumption	Sink	2/3/17	CDES-I-060	ND													
Gym Restroom Girls (Fan Faucet replaced w/ std faucet)	Other Human Consumption	Sink	2/3/17	CDES-I-059	ND													
Playground Boys RR (Fan Faucet replaced w/ std faucet)	Other Human Consumption	Sink	2/3/17	CDES-I-061	ND													