

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location		Fixture Type	First Draw					Flushed Draw					New Fixture First Draw					Follow Up - New Fixture Draw									
Room	Fixture Use		Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	Work Order Date	W.O. #	Fixture Replaced	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	Additional Action	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	
Gilham Elementary School																											
Room F103	Drinking Fountain	Fountain	10/6/16	10/7/16	10/21/16	GILES-1129	ND																				
Room F103	Other Human Consumption	Sink	10/6/16	10/7/16	10/21/16	GILES-1130	1.30																				
Room F102	Drinking Fountain	Fountain	10/6/16	10/7/16	10/21/16	GILES-1131	ND																				
Room F102	Other Human Consumption	Sink	10/6/16	10/7/16	10/21/16	GILES-1132	ND																				
Room F101	Drinking Fountain	Fountain	10/6/16	10/7/16	10/21/16	GILES-1133	3.73																				
Room F101	Other Human Consumption	Sink	10/6/16	10/7/16	10/21/16	GILES-1134	ND																				
Unit E Boys Restroom Left	Other Human Consumption	Sink	11/3/16	11/4/16	11/21/16	GILES-1135	2.53																				
Unit E Boys Restroom Right	Other Human Consumption	Sink	11/3/16	11/4/16	11/21/16	GILES-1136	ND																				
Unit E Girls Restroom Left	Other Human Consumption	Sink	11/3/16	11/4/16	11/21/16	GILES-1137	1.27																				
Unit E Girls Restroom Right	Other Human Consumption	Sink	11/3/16	11/4/16	11/21/16	GILES-1138	1.45																				
Room C124 Multi Purpose Room Left	Other Human Consumption	Sink	11/3/16	11/4/16	11/21/16	GILES-1139	ND																				
Room C124 Multi Purpose Room Left	Drinking Fountain	Fountain	11/3/16	11/4/16	11/21/16	GILES-1140	ND																				
Room C124 Multi Purpose Room Right	Other Human Consumption	Sink	11/3/16	11/4/16	11/21/16	GILES-1141	1.98																				
Room C124 Multi Purpose Room Utility	Other Human Consumption	Sink	11/3/16	11/4/16	11/21/16	GILES-1142	ND																				
Room B128 Community	Other Human Consumption	Sink	11/3/16	11/4/16	11/21/16	GILES-1143	1.53																				
Room B128 Community	Drinking Fountain	Fountain	11/3/16	11/4/16	11/21/16	GILES-1144	ND																				
Room B116A - Single Occ Restroom	Other Human Consumption	Sink	11/3/16	11/4/16	11/21/16	GILES-1145	2.50																				
Room B119A - Single Occ Restroom	Other Human Consumption	Sink	11/3/16	11/4/16	11/21/16	GILES-1146	2.68																				

Using EPA's water sampling method for schools, action level is 20 parts per billion (ppb). Samples that tested above the action level are highlighted.