

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw			Follow Up - New Fixture Draw					
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Flushed	Date Sampled	Sample ID #	Result (ppb)
South Eugene High School																
Big Gym Lobby (west)	Fountain	7/14/16	SEHS-001	1.69												
Big Gym Lobby (East)	Fountain	7/14/16	SEHS-002	1.87												
Big Gym Men's Lobby Restroom (West)	Sink	7/14/16	SEHS-003	11.60												
Big Gym Lobby Men's Restroom (center)	Sink	7/14/16	SEHS-004	6.45												
Big Gym Lobby Men's Restroom (East)	Sink	7/14/16	SEHS-005	4.05												
Big Gym Lobby Women's Restroom (East)	Sink	7/14/16	SEHS-006	12.00												
Big Gym Lobby Women's Restroom (center)	Sink	7/14/16	SEHS-007	7.25												
Big Gym Lobby Women's Restroom (West)	Sink	7/14/16	SEHS-008	3.87												
Big Gym Lobby Concession	Sink	7/14/16	SEHS-009	6.28												
Big Gym Northwest Corner	Fountain	7/14/16	SEHS-010	1.61												
Big Gym Northeast Corner	Fountain	7/14/16	SEHS-011	ND												
Big Gym Southwest Corner	Fountain	7/14/16	SEHS-012	1.01												
Big Gym Southeast Corner	Fountain	7/14/16	SEHS-013	ND												
Boys Locker Room West Corridor	Fountain	7/14/16	SEHS-014	3.62												
Boys Locker Room West Restroom	Sink	7/14/16	SEHS-015	4.69												
Boys Locker Room East Corridor	Fountain	7/14/16	SEHS-016	2.07												
Boys Locker Room Officials Room	Sink	7/14/16	SEHS-017	4.93												
Wrestling Gym	Fountain	7/14/16	SEHS-018	15.70												
Girls PE Office Corridor	Fountain	7/14/16	SEHS-019	6.48												
Girls PE Office Shower Room	Sink	7/14/16	SEHS-020	4.73												
Small Gym	Fountain	7/14/16	SEHS-021	4.79												
Girls Locker Room Restroom (West)	Sink	7/14/16	SEHS-022	7.26												
Girls Locker Room Restroom (East)	Sink	7/14/16	SEHS-023	8.51												
Girls Locker Room	Fountain	7/14/16	SEHS-024	4.47												
Room 113	Sink	7/14/16	SEHS-025	6.56												
Health Room Restroom	Sink	7/14/16	SEHS-026	2.72												
Health room Lounge	Sink	7/14/16	SEHS-027	20.00												
Health Room Exam Room	Sink	7/14/16	SEHS-028	9.17												
Health Room Exam Room	Insta-Hot	7/14/16	SEHS-029	2.54												
Clinic Lobby	Sink	7/14/16	SEHS-030	15.00												
Clinic Exam Room	Sink	7/14/16	SEHS-031	15.60												
100 Hall West End	Fountain	7/14/16	SEHS-032	2.49												
Training Room Tub Sink (Left)	Sink	7/14/16	SEHS-033	18.30												
Training Room Slop Sink	Sink	7/14/16	SEHS-034	193.00	9/8/16	SEHS-F-202	7.32	9/27/16	9/28/16	SEHS-4-213	139.00	10/31/2016 12/5 - Replaced 2" brass valve in line 1/11 - Replaced additional inline ice valve	10/31/2016 2/2/2017 2/3/2017	SEHS-1-224 SEHS-1-225 SEHS-1-226	39.90 35.40 18.60	
Training Room Tub Sink (right)	Sink	7/14/16	SEHS-035	34.40	9/8/16	SEHS-F-203	ND	9/27/16	9/28/16	SEHS-4-214	2.18		7/18/2017 7/18/2017			
Corridor outside Training Room	Fountain	7/14/16	SEHS-036	ND												
Training Room	Ice Machine	7/14/16	SEHS-037	ND												
Girls Restroom near Training Room (west)	Sink	7/14/16	SEHS-038	4.37												
Girls Restroom near Training Room (East)	Sink	7/14/16	SEHS-039	4.56												
Restroom at Athletes Directors Office	Sink	7/14/16	SEHS-040	1.93												
Cafeteria Northwest Corner (lower)	Fountain	7/14/16	SEHS-041	3.66												
Cafeteria Northwest Corner (Upper)	Fountain	7/14/16	SEHS-042	3.19												
Staff Lounge	Sink	7/14/16	SEHS-043	1.02												
Snack Bar Prep Sink	Sink	7/14/16	SEHS-044	ND												
Snack Bar Handwash Sink	Sink	7/14/16	SEHS-045	2.33												
Cafeteria Northwest Corner (lower)	Fountain	7/14/16	SEHS-046	ND												
Cafeteria Northwest Corner (Upper)	Fountain	7/14/16	SEHS-047	ND												
Cafeteria Southeast Corner (Upper)	Fountain	7/14/16	SEHS-048	ND												
Cafeteria Southeast Corner (lower)	Fountain	7/14/16	SEHS-049	ND												
Cafeteria Salsa Bar	Sink	7/14/16	SEHS-050	1.70												
Kitchen Dish Room (North)	Sink	7/14/16	SEHS-051	5.12												
Kitchen Dish Room (South)	Sink	7/14/16	SEHS-052	4.53												
Kitchen Dish Room	Sprayer	7/14/16	SEHS-053	ND												
Kitchen Hand Wash	Sink	7/14/16	SEHS-054	4.63												
Kitchen Staff Restroom	Sink	7/14/16	SEHS-055	2.30												
Kitchen Braising Pan	Sink	7/14/16	SEHS-056	18.30												
Kitchen Prep	Sink	7/14/16	SEHS-057	ND												
Kitchen Island Sink	Sprayer	7/14/16	SEHS-058	3.12												
Kitchen Island Sink	Sink	7/14/16	SEHS-059	2.71												
Kitchen East Hand Wash	Sink	7/14/16	SEHS-060	2.22												
Corridor North of Cafeteria	Fountain	7/14/16	SEHS-061	ND												
Hall 300 at Cafeteria Girls Restroom (East)	Sink	7/14/16	SEHS-062	2.31												
Hall 300 at Cafeteria Girls Restroom (West)	Sink	7/14/16	SEHS-063	1.98												
Hall 300 at Cafeteria Boys Restroom (East)	Sink	7/14/16	SEHS-064	2.64												
Hall 300 at Cafeteria Boys Restroom (West)	Sink	7/14/16	SEHS-065	1.54												
Custodial Services	Sink	7/14/16	SEHS-066	ND												
Hall 300 Corridor South End	Fountain	7/14/16	SEHS-067	5.44												
Hall 300 North End	Fountain	7/14/16	SEHS-068	3.88												
Corridor outside Office	Fountain	7/14/16	SEHS-069	ND												
Office Kitchen	Sink	7/14/16	SEHS-070	2.98												
Corridor outside Room 13	Fountain	7/14/16	SEHS-071	1.65												
Girls Restroom outside Library (South)	Sink	7/14/16	SEHS-072	2.38												
Girls Restroom outside Library (South)	Sink	7/14/16	SEHS-073	2.62												
Corridor outside Library	Fountain	7/14/16	SEHS-074	1.07												
Boys Restroom outside Library (South)	Sink	7/14/16	SEHS-075	3.63												
Boys Restroom outside Library (North)	Sink	7/14/16	SEHS-076	1.65												
Library Staff Women's Restroom	Sink	7/14/16	SEHS-077	17.90												
Library Work Room	Sink	7/14/16	SEHS-078	3.94												
AV Room	Sink	7/14/16	SEHS-079	7.68												
Corridor outside English Office	Fountain	7/14/16	SEHS-080	17.74												
Room 411 Demonstration table	Sink	7/14/16	SEHS-081	26.40	9/8/16	SEHS-F-205	2.39	9/27/16	9/28/16	SEHS-1-216	3.20					
Room 411 North Wall	Sink	7/14/16	SEHS-082	30.30	9/8/16	SEHS-F-206	1.80	9/27/16	9/28/16	SEHS-1-217	0.14					
Hall 400	Fountain	7/14/16	SEHS-083	3.10												
Hall 400 Former Boys Restroom	Sink	7/14/16	SEHS-084	2.31												
Room 414	Sink	7/14/16	SEHS-085	6.65												
Room 414L Center Island	Sink	7/14/16	SEHS-086	2.38												
Room 414L Utility Sink	Sink	7/14/16	SEHS-087	9.30												
Room 415L	Sink	7/14/16	SEHS-088	3.51												
Room 415L	Sink	7/14/16	SEHS-089	3.08												
Staff Restroom adjoining Room 415B	Sink	7/14/16	SEHS-090	6.14												
Room 422 RC	Sink	7/14/16	SEHS-091	3.18												
Room 422S	Sink	7/14/16	SEHS-092	ND												
Room 422S	Sink	7/14/16	SEHS-093	ND												
Room 416	Sink	7/14/16	SEHS-094	6.44												
Room 417	Sink	7/14/16	SEHS-095	4.13												
Room 418L East Island (North)	Sink	7/14/16	SEHS-096	23.80	9/8/16	SEHS-F-208	3.88	9/27/16	9/28/16	SEHS-1-218	7.55					
Room 418L Center Island (North)	Sink	7/14/16	SEHS-097	17.00												

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw				
		Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Flushed	Date Sampled	Sample ID #	Result (ppb)
South Eugene High School																
500 Hall Men's Restroom	Sink	7/14/16	SEHS-134	2.07												
500 Hall Women's Restroom	Sink	7/14/16	SEHS-135	10.60												
Night School Office	Sink	7/14/16	SEHS-136	6.65												
Room 531	Sink	7/14/16	SEHS-137	2.51												
Room 527 Tub Sink	Sink	7/14/16	SEHS-138	1.97												
Room 527 South Wall	Sink	7/14/16	SEHS-139	1.40												
Room 527 West Storage Room	Sink	7/14/16	SEHS-140	6.88												
500 Hall Near Room 524	Sink	7/14/16	SEHS-141	1.66												
500 Hall Men's Restroom near Room 523	Sink	7/14/16	SEHS-142	2.88												
Room 523	Sink	7/14/16	SEHS-143	2.17												
500 Hall Girls Restroom near Room 521	Sink	7/14/16	SEHS-144	ND												
500 Hall near Room 521	Sink	7/14/16	SEHS-145	1.56												
Girls Restroom across from Little Theatre (West)	Sink	7/14/16	SEHS-146	1.23												
Girls Restroom across from Little Theatre (East)	Sink	7/14/16	SEHS-147	2.13												
Room 517C	Sink	7/14/16	SEHS-148	4.76												
Back Stage Paint Sink	Sink	7/14/16	SEHS-149	8.28												
Theatre Corridor	Sink	7/14/16	SEHS-150	1.85												
Theatre Corridor West Unisex Restroom	Sink	7/14/16	SEHS-151	27.30	9/8/16	SEHS-F-211	1.13	9/27/16	9/28/16	SEHS-1-222	2.00					
Theatre Corridor East Unisex Restroom	Sink	7/14/16	SEHS-152	4.23												
Band Room	Fountain	7/14/16	SEHS-153	2.65												
Choir Room	Fountain	7/14/16	SEHS-154	1.71												
Hall 500 Boys Restroom near Auditorium (West)	Sink	7/14/16	SEHS-155	2.01												
Hall 500 Boys Restroom near Auditorium (East)	Sink	7/14/16	SEHS-156	1.87												
Auditorium Corridor	Fountain	7/14/16	SEHS-157	5.31												
Auditorium Lobby Men's Restroom (West)	Sink	7/14/16	SEHS-158	2.58												
Auditorium Lobby Men's Restroom (Center)	Sink	7/14/16	SEHS-159	1.93												
Auditorium Lobby Men's Restroom (East)	Sink	7/14/16	SEHS-160	13.70												
Auditorium Lobby West	Fountain	7/14/16	SEHS-161	4.19												
Auditorium Lobby East	Fountain	7/14/16	SEHS-162	6.56												
Auditorium Women's Restroom (West)	Sink	7/14/16	SEHS-163	7.65												
Auditorium Women's Restroom (Center)	Sink	7/14/16	SEHS-164	1.52												
Auditorium Women's Restroom (East)	Sink	7/14/16	SEHS-165	ND												
Staff Unisex Restroom near Room 31	Sink	7/14/16	SEHS-166	6.57												
Corridor outside Room 31	Fountain	7/14/16	SEHS-167	2.03												
Men's Restroom across from Room 29 (South)	Sink	7/14/16	SEHS-168	5.14												
Men's Restroom across from Room 29 (North)	Sink	7/14/16	SEHS-169	1.56												
Women's Restroom across from Room 27 (South)	Sink	7/14/16	SEHS-170	2.10												
Women's Restroom across from Room 27 (North)	Sink	7/14/16	SEHS-171	3.55												
Corridor outside Room 304	Fountain	7/14/16	SEHS-172	10.30												
Room 729	Sink	7/14/16	SEHS-173	12.80												
Upper Level Men's Restroom East Side (South)	Sink	7/14/16	SEHS-174	4.42												
Upper Level Men's Restroom East Side (North)	Sink	7/14/16	SEHS-175	1.40												
Upper Level Women's Restroom East Side (South)	Sink	7/14/16	SEHS-176	68.90	9/8/16	SEHS-F-212	1.78	9/27/16	9/28/16	SEHS-1-223	9.34					
Upper Level Women's Restroom East Side (North)	Sink	7/14/16	SEHS-177	6.22												
Room 721	Sink	7/14/16	SEHS-178	2.69												
Upper Level Corridor at Room 716	Fountain	7/14/16	SEHS-179	2.16												
Upper Level Corridor near Room 710A	Fountain	7/14/16	SEHS-180	1.19												
Upper Level Men's Restroom West Side (South)	Sink	7/14/16	SEHS-181	2.78												
Upper Level Men's Restroom West Side (North)	Sink	7/14/16	SEHS-182	1.23												
Upper Level Women's Restroom West Side (East)	Sink	7/14/16	SEHS-183	1.35												
Upper Level Women's Restroom West Side (West)	Sink	7/14/16	SEHS-184	4.46												
Upper Level Corridor near Room 706	Fountain	7/14/16	SEHS-185	1.09												
Cym Balcory Northwest Corner	Fountain	7/14/16	SEHS-186	7.43												
Cym Balcory Southwest Corner	Fountain	7/14/16	SEHS-187	3.00												
Room 204 East Wall (North)	Sink	7/19/16	SEHS-188	ND												
Room 204 East Wall (Middle)	Sink	7/19/16	SEHS-189	ND												
Room 204 East Wall (South)	Sink	7/19/16	SEHS-190	1.62												
Room 204 West Wall (South)	Sink	7/19/16	SEHS-191	1.86												
Room 204 West Wall (middle)	Sink	7/19/16	SEHS-192	ND												
Room 204 West Wall (north)	Sink	7/19/16	SEHS-193	ND												
Room 348 Home Ec Dish Room East Wall	Sink	7/19/16	SEHS-194	10.90												
Room 348 Home Ec Dish Room Sprayer West Wall	Sprayer	7/19/16	SEHS-195	2.95												
Restroom in Hallway near Room 209	Sink	7/19/16	SEHS-196	2.42												
Room 207 Office North Wall	Sink	7/19/16	SEHS-197	11.00												
Room 205 South Wall Upper Left	Sink	7/19/16	SEHS-198	34.80	9/8/16	SEHS-F-204	1.08	9/27/16	9/28/16	SEHS-1-215	ND					
Room 205 South Wall Lower Right	Sink	7/19/16	SEHS-199	1.14												
Room 411 East Wall Sink	Sink	7/19/16	SEHS-200	20.30	9/8/16	SEHS-F-207	1.68	9/27/16	9/28/16	SEHS-1-218	7.55					
Room 419 West Wall	Sink	7/19/16	SEHS-201	4.46												