

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location		Fixture Use	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw						
				Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)	
Cafeteria Corridor	Drinking Fountain	Fountain		6/27/16	PARES-I-001	3.46														
Kitchen Dishwasher Area	Food Preparation	Sprayer		6/27/16	PARES-I-002	4.22														
Kitchen Handwashing Area	Sink			6/27/16	PARES-I-003	3.54														
Cafeteria Wing - Women's Restroom (South)	Other Human Consumption	Sink		6/27/16	PARES-I-004	3.57														
Cafeteria Wing - Women's Restroom (North)	Other Human Consumption	Sink		6/27/16	PARES-I-005	3.37														
Cafeteria Wing-Men's Restroom (South)	Other Human Consumption	Sink		6/27/16	PARES-I-006	3.39														
Cafeteria Wing-Men's Restroom (North)	Other Human Consumption	Sink		6/27/16	PARES-I-007	3.76														
Room 10 (East)	Other Human Consumption	Sink		6/27/16	PARES-I-008	1.69														
Room 10 (West)	Other Human Consumption	Sink		6/27/16	PARES-I-009	6.41														
Room 10 Restroom	Other Human Consumption	Sink		6/27/16	PARES-I-010	7.83														
Room 9 (North)	Other Human Consumption	Sink		6/27/16	PARES-I-011	56.10	8/18/16	PARES-F-078	1.67	8/26/16	8/26/16	PARES-I-104	342.00	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	1. 11/3/2016 2. 2/2/2017	1. 11/4/2016 2. 2/3/2017	1. 11/10/2016 2. 2/10/2017	1. PARES-I-121 2. PARES-I-133	1. 26.20 2. 3.32	
Room 9 (South)	Other Human Consumption	Sink		6/27/16	PARES-I-012	46.10	8/18/16	PARES-F-079	1.65	8/26/16	8/26/16	PARES-I-105	35.60	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	1. 11/3/2016 2. 2/2/2017	1. 11/4/2016 2. 2/3/2017	1. 11/10/2016 2. 2/10/2017	1. PARES-I-124 2. PARES-I-134	1. 24.00 2. 11.40	
Room 8	Other Human Consumption	Sink		6/27/16	PARES-I-013	37.20	8/18/16	PARES-F-080	1.61	8/26/16	8/26/16	PARES-I-106	17.40	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	1. 11/3/2016 2. 2/2/2017	1. 11/4/2016 2. 2/3/2017	1. 11/10/2016 2. 2/10/2017	1. PARES-I-125 2. PARES-I-135	1. 26.00 2. 18.80	
North Wing Girls Restroom (East)	Other Human Consumption	Sink		6/27/16	PARES-I-014	47.00	8/18/16	PARES-F-081	4.18	8/26/16	8/26/16	PARES-I-107	22.50	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	1. 11/3/2016 2. 2/2/2017	1. 11/4/2016 2. 2/3/2017	1. 11/10/2016 2. 2/10/2017	1. PARES-I-126 2. PARES-I-136	1. 26.00 2. 18.80	
North Wing Girls Restroom (West)	Other Human Consumption	Sink		6/27/16	PARES-I-015	30.40	8/18/16	PARES-F-082	2.56	8/26/16	8/26/16	PARES-I-108	50.50	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	11/3/16 11/4/16	11/10/16	PARES-I-127	14.90		
North Wing Boys Restroom (East)	Other Human Consumption	Sink		6/27/16	PARES-I-016	29.70	8/18/16	PARES-F-083	5.45	8/26/16	8/26/16	PARES-I-110	16.50	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	11/3/16 11/4/16	11/10/16	PARES-I-128	18.10		
North Wing Boys Restroom (West)	Other Human Consumption	Sink		6/27/16	PARES-I-017	38.00	8/18/16	PARES-F-084	2.80	8/26/16	8/26/16	PARES-I-111	58.20	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	11/3/16 11/4/16	11/10/16	PARES-I-129	18.10		
North Wing Restroom Vestibule	Drinking Fountain	Fountain		6/27/16	PARES-I-018	60.90	8/18/16	PARES-F-085	8.65	8/26/16	8/26/16	PARES-I-109	167.00	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples 3. System Flush 4. Replaced with Elkay Unit (DF & BF)	1. 11/3/2016 2. 2/2/2017 3. 7/13/2017 4. 9/11/2017	1. 11/4/2016 2. 2/3/2017 3. 7/14/2017 4. 9/12/2017	1. 11/10/2016 2. 2/10/2017	1. PARES-I-128 2. PARES-I-136 3. PARES-I-139 4. PARES-I-141 4. NO PARES-I-142	1. 40.20 2. 30.40 3. 68.30 4. NO ND	
Room 7	Other Human Consumption	Sink		6/27/16	PARES-I-019	53.00	8/18/16	PARES-F-086	5.27	8/26/16	8/26/16	PARES-I-112	37.30	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	1. 11/3/2016 2. 2/2/2017	1. 11/4/2016 2. 2/3/2017	1. 11/10/2016 2. 2/10/2017	1. PARES-I-129 2. PARES-I-137	1. 81.70 2. 17.30	
Room 7	Drinking Fountain	Fountain		6/27/16	PARES-I-020	15.20														
Room 6	Other Human Consumption	Sink		6/27/16	PARES-I-021	53.10	8/18/16	PARES-F-087	2.57	8/26/16	8/26/16	PARES-I-113	86.50	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	11/3/16 11/4/16	11/10/16	PARES-I-130	9.81		
Room 6	Drinking Fountain	Fountain		6/27/16	PARES-I-022	6.18														
3A workroom	Other Human Consumption	Sink		6/27/16	PARES-I-023	127.00	8/18/16	PARES-F-088	20.70	8/26/16	8/26/16	PARES-I-114	64.50	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples 3. System Flush 4. Sink Decommissioned	1. 11/3/2016 2. 2/2/2017 3. 7/13/2017	1. 11/4/2016 2. 2/3/2017 3. 7/14/2017	1. 11/10/2016 2. 2/10/2017 3. 7/21/2017	1. PARES-I-132 2. PARES-I-138 3. PARES-I-140	1. 264.00 2. 57.20 3. 22.10	
Room 3 Restroom	Other Human Consumption	Sink		6/27/16	PARES-I-024	7.40														
Room 3	Drinking Fountain	Fountain		6/27/16	PARES-I-025	1.91														
Room 3	Other Human Consumption	Sink		6/27/16	PARES-I-026	379.70	8/18/16	PARES-F-091	4.31	8/26/16	8/26/16	PARES-I-115	36.40	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	10/26/16 10/27/16	11/7/16	PARES-I-118	16.10		
Room 4	Other Human Consumption	Sink		6/27/16	PARES-I-027	41.90	8/18/16	PARES-F-092	1.89	8/26/16	8/26/16	PARES-I-117	76.10	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	10/26/16 10/27/16	11/7/16	PARES-I-119	4.73		
Room 4	Drinking Fountain	Fountain		6/27/16	PARES-I-028	3.45														
Room 5	Other Human Consumption	Sink		6/27/16	PARES-I-029	36.60	8/18/16	PARES-F-090	ND	8/26/16	8/26/16	PARES-I-115	2360.00	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	11/3/16 11/4/16	11/10/16	PARES-I-131	3.25		
Room 5	Drinking Fountain	Fountain		6/27/16	PARES-I-030	13.90	8/18/16	PARES-F-089	1.15	10/19/16	10/27/16	PARES-I-120	13.00							
Room 2 Restroom	Other Human Consumption	Sink		6/27/16	PARES-I-031	2.40														
Room 2	Drinking Fountain	Fountain		6/27/16	PARES-I-032	6.38														
Room 2	Other Human Consumption	Sink		6/27/16	PARES-I-033	8.97														
Room 1	Drinking Fountain	Fountain		6/27/16	PARES-I-034	13.80														
Room 1 Restroom	Other Human Consumption	Sink		6/27/16	PARES-I-035	8.42														
Room 1	Other Human Consumption	Sink		6/27/16	PARES-I-036	10.30														
Library	Other Human Consumption	Sink		6/27/16	PARES-I-037	7.66														
Administrative Copy Room	Other Human Consumption	Sink		6/27/16	PARES-I-038	6.11														
Administrative Staff Restroom	Other Human Consumption	Sink		6/27/16	PARES-I-039	9.53														
Staff Lounge	Drinking Fountain	Insta-Hot		6/27/16	PARES-I-040	0.90														
Staff Lounge	Other Human Consumption	Sink		6/27/16	PARES-I-041	3.91														
Central Corridor - Staff Restroom	Other Human Consumption	Sink		6/27/16	PARES-I-042	40.20	8/22/16	PARES-F-093	ND	8/26/16	8/26/16	PARES-I-094	12.60							
Room 11	Drinking Fountain	Fountain		6/27/16	PARES-I-043	18.60														
Room 11	Other Human Consumption	Sink		6/27/16	PARES-I-044	35.90	8/18/16	PARES-F-073	3.71	8/26/16	8/26/16	PARES-I-098	9.43							
Room 12	Drinking Fountain	Fountain		6/27/16	PARES-I-045	8.21														
Room 12	Other Human Consumption	Sink		6/27/16	PARES-I-046	18.00														
Room 13	Drinking Fountain	Fountain		6/27/16	PARES-I-047	9.19														
Room 13	Other Human Consumption	Sink		6/27/16	PARES-I-048	20.30	8/18/16	PARES-F-071	1.10	8/26/16	8/26/16	PARES-I-097	4.39							
Center Wing Boys Restroom (East)	Other Human Consumption	Sink		6/27/16	PARES-I-049	4.21														
Center Wing Boys Restroom (West)	Other Human Consumption	Sink		6/27/16	PARES-I-050	5.36														
Center Wing Girls Restroom (East)	Other Human Consumption	Sink		6/27/16	PARES-I-051	10.20														
Center Wing Girls Restroom (West)	Other Human Consumption	Sink		6/27/16	PARES-I-052	22.60	8/18/16	PARES-F-070	1.90	8/26/16	8/26/16	PARES-I-096	7.72							
Center Wing Restroom Vestibule	Drinking Fountain	Fountain		6/27/16	PARES-I-053	13.80														
Room 14	Drinking Fountain	Fountain		6/27/16	PARES-I-054	38.00	8/18/16	PARES-F-069	7.87	8/26/16	8/26/16	PARES-I-095	13.70							
Room 14	Other Human Consumption	Sink		6/27/16	PARES-I-055	9.84														
Room 18	Drinking Fountain	Fountain		6/27/16	PARES-I-056	72.20	8/18/16	PARES-F-073	12.40	8/26/16	8/26/16	PARES-I-099	16.60							
Room 18	Other Human Consumption	Sink		6/27/16	PARES-I-057	244.00	8/18/16	PARES-F-074	6.63	8/26/16	8/26/16	PARES-I-100	13.10							
Lower Level Boys Restroom (West)	Other Human Consumption	Sink		6/27/16	PARES-I-058	5.93														
Lower Level Boys Restroom (East)	Other Human Consumption	Sink		6/27/16	PARES-I-059	7.88														
Lower Level Girls Restroom (West)	Other Human Consumption	Sink		6/27/16	PARES-I-060	5.90														
Lower Level Girls Restroom (East)	Other Human Consumption	Sink		6/27/16	PARES-I-061	5.45														
Lower Level Restroom Vestibule	Drinking Fountain	Fountain		6/27/16	PARES-I-062	13.40														
Room 17	Drinking Fountain	Fountain		6/27/16	PARES-I-063	7.81														
Room 17	Other Human Consumption	Sink		6/27/16	PARES-I-064	24.30	8/18/16	PARES-F-075	2.01	8/26/16	8/26/16	PARES-I-101	35.60	1. Replaced building main brass water mains / 2. Replaced tunnel valves, stops and nipples	10/26/16 10/27/16	11/7/16	PARES-I-121	1.95		
Room 16	Drinking Fountain	Fountain		6/27/16	PARES-I-0															