



Eugene School District 4J  
 Water Quality: Lead Testing Results

Eugene School District 4J - Location	Fixture Use	Fixture Type	First Draw			Flushed Draw			New Fixture First Draw				Follow Up - New Fixture Draw					
			Date Sampled	Sample ID #	Result (ppb)	Date Sampled	Sample ID #	Result (ppb)	Fixture Replaced	Date Sampled	Sample ID #	Result (ppb)	Additional Action	Date Flushed	Date Sampled	Date Received	Sample ID #	Result (ppb)
<b>Awbrey Park Elementary School</b>																		
Blue Hall Girls Restroom (Right)	Other Human Consumption	Sink	6/28/2016	APES-I-067	1.04													
In Hallway between Blue & Green Halls	Drinking Fountain	Fountain	6/28/2016	APES-I-068	1.22													
Green Hall Boys Restroom (Left)	Other Human Consumption	Sink	6/28/2016	APES-I-069	2.02													
Green Hall Boys Restroom (Right)	Other Human Consumption	Sink	6/28/2016	APES-I-070	1.59													
Green Hall Girls Restroom (Left)	Other Human Consumption	Sink	6/28/2016	APES-I-071	2.11													
Green Hall Girls Restroom (Right)	Other Human Consumption	Sink	6/28/2016	APES-I-072	1.37													
Media Center	Other Human Consumption	Sink	6/28/2016	APES-I-073	0.58													
Boys Restroom by Gym (Left)	Other Human Consumption	Sink	6/28/2016	APES-I-074	3.46													
Boys Restroom by Gym (Right)	Other Human Consumption	Sink	6/28/2016	APES-I-075	3.34													
Girls Restroom by Gym (Left)	Other Human Consumption	Sink	6/28/2016	APES-I-076	1.63													
Girls Restroom by Gym (Right)	Other Human Consumption	Sink	6/28/2016	APES-I-077	0.79													
Gym	Drinking Fountain	Fountain	6/28/2016	APES-I-078	0.94													
Kitchen Produce Sink West Wall (Left)	Food Preparation	Sink	6/28/2016	APES-I-079	16.20													
Kitchen Handwash Sink West Wall (Right)	Food Preparation	Sink	6/28/2016	APES-I-080	2.78													
Kitchen East Wall (Left)	Food Preparation	Sink	6/28/2016	APES-I-081	4.32													
Kitchen East Wall (Right)	Food Preparation	Sink	6/28/2016	APES-I-082	0.32													
Conference Room by Main Office	Other Human Consumption	Sink	6/28/2016	APES-I-083	5.71													
Staff Room Refrigerator - In Door	Drinking Fountain	Dispencer	10/8/2016	APES-I-092	ND													
Staff Room Refrigerator - In Door	Drinking Fountain	Ice Machine	10/8/2016	APES-I-093	ND													

Using EPA's water sampling method for schools, action level is > 20 parts per billion (ppb). Samples that tested above the action level are highlighted.