

Radon test result report for:

CHARLEMAGNE AT PARKER

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9133569	1	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	0.9 ± 0.3	2018-12-04
9133587	10	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	< 0.3	2018-12-04
9133590	15	2018-11-26 @ 6:00 am	2018-11-29 @ 9:00 pm	< 0.3	2018-12-04
9133585	16	2018-11-26 @ 6:00 am	2018-11-29 @ 9:00 pm	< 0.3	2018-12-04
9133591	17	2018-11-26 @ 6:00 am	2018-11-29 @ 9:00 pm	< 0.3	2018-12-04
9133589	18	2018-11-26 @ 6:00 am	2018-11-29 @ 9:00 pm	< 0.3	2018-12-04
9133594	19	2018-11-26 @ 6:00 am	2018-11-29 @ 9:00 pm	< 0.3	2018-12-04
9133570	2	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	< 0.3	2018-12-04
9133582	3	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	1.1 ± 0.3	2018-12-04
9133598	3A	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	< 0.3	2018-12-04
9133583	4	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	0.6 ± 0.3	2018-12-04
9133581	5	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	1.2 ± 0.3	2018-12-04
9133597	6	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	< 0.3	2018-12-04
9133579	7	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	0.9 ± 0.3	2018-12-04
9133586	8	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	1.0 ± 0.3	2018-12-04
9133588	9	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	0.6 ± 0.3	2018-12-04
9133414	BLANK	2018-12-01 @ 11:00 am	2018-12-03 @ 4:00 pm	< 0.3	2018-12-04
9133415	BLANK	2018-12-01 @ 11:00 am	2018-12-03 @ 4:00 pm	< 0.3	2018-12-04
9133595	CAFETERIA	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	0.6 ± 0.3	2018-12-04
9133600	CAFETERIA	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	< 0.3	2018-12-04
9133593	CUSTODIAN OFFICE	2018-11-26 @ 6:00 am	2018-11-29 @ 9:00 pm	0.8 ± 0.3	2018-12-04
9133599	GYM	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	< 0.3	2018-12-04
9133096	GYM	2019-01-08 @ 6:00 am	2019-01-11 @ 6:00 am	< 0.3	2019-01-12
9133571	LIBRARY	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	1.0 ± 0.3	2018-12-04
9133577	OFFICE	2018-11-26 @ 6:00 am	2018-11-30 @ 1:00 am	< 0.3	2018-12-04
9133575	PRINCIPAL OFFICE	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	< 0.3	2018-12-04
9133574	SCHOOL COUNSELOR	2018-11-26 @ 6:00 am	2018-11-29 @ 8:00 pm	< 0.3	2018-12-04

January 18, 2019

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**CHARLEMAGNE AT PARKER
MAIN BUILDING**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9133580	7	2018-11-26 @ 3:00 am	2018-11-29 @ 5:00 pm	0.8 ± 0.4	2018-12-05
9133576	OFFICE	2018-11-26 @ 3:00 am	2018-11-29 @ 6:00 pm	< 0.3	2018-12-05

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498