

Radon test result report for:**Building 2120**

<b>Kit #</b>	<b>Room Id</b>	<b>Started</b>	<b>Ended</b>	<b>pCi/L</b>	<b>Analyzed</b>
9158369	1	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158375	2	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158377	3	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158382	BLANK 1	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 pm	< 0.3	2019-01-21
9158370	CAFETERIA	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158335	COMPUTER LAB	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158373	MAIN OFFICE	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158367	OFFICE 1	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158368	OFFICE 2	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158336	OFFICE 3	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158364	OFFICE 4	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158374	TIME OUT	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158376	TRANSITION ROOM	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21
9158381	TRANSITION ROOM	2019-01-14 @ 3:00 am	2019-01-18 @ 2:00 am	< 0.3	2019-01-21