

**MULTISITE ROOFING 2019 – RE-BID**  
South Eugene High School  
Kennedy Middle School  
C.I.P. No. 420.780.209

**ROBERTSON/SHERWOOD/ARCHITECTS pc**  
132 E. Broadway - Suite 540  
Eugene, Oregon  
Project No. 1901



This Addendum forms a part of the Contract Documents and modifies the original Bid Documents dated May 2, 2019 as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

### **PROJECT MANUAL**

1. DOCUMENT 00 11 16 – INVITATION BID

- A. Pre-Bid Conference: A non-mandatory pre-bid conference was held at 10:00 AM on May 7, 2019. South Eugene High School and Kennedy Middle School roofs were toured by attendees. A list of attendees is attached to this Addendum.

### **DRAWINGS**

2. DRAWING SHEET 201

- A. Delete Keyed Note 1. Clarification: Owner will replace broken glass plumbing vent.

3. DRAWING SHEET 211


- A. Replace Detail A6/211 with new Detail A6 attached to this addendum. Clarification: Revised detail eliminates welding anchors to existing steel beams.

### **ATTACHMENTS**

Pre-Bid Conference List of Attendees  
Detail A6/A211

**END OF ADDENDUM NO. 1**





## FALL PROTECTION ANCHOR

1-1/2" = 1'-0"

DETAIL A6/211 REVISED

© 2019 Robertson | Sherwood | Architects pc

Drawn By BDH	ADDENDUM NO. 1	Robertson   Sherwood   Architects pc				AD1 1
Checked		132 East Broadway, Suite 540 Eugene, Oregon 97401	P 541   342.8077 F 541   345.4302	www.robertsonsherwood.com		
Date 5/13/19	RE-BID	MULTISITE ROOFING 2019 - C.I.P. #420.780.209				
Project 1901		South Eugene High School & Kennedy Middle School				