

Education Center****LABORATORY ANALYSIS REPORT******June 26, 2020****Long Term - Alpha Track Radon Testing**

Kit Number	Start Date	End Date	Building	Room	Project ID	Floor	Result (pCi/L)
403801	8/1/2019	6/19/2020	Education Center	Douglas Conference Room	School District 4J	1	7.9
403802	8/1/2019	6/19/2020	Education Center	Douglas Conference Room	School District 4J	1	8.2
403804	8/1/2019	6/19/2020	Education Center	TSS Office	School District 4J	1	1.9
403812	8/1/2019	6/19/2020	Education Center	TSS Office	School District 4J	1	2.1
403805	8/1/2019	6/19/2020	Education Center	Grounds Shop	School District 4J	1	6.0
403806	8/1/2019	6/19/2020	Education Center	Grounds Shop	School District 4J	1	4.3