

NEHS

****LABORATORY ANALYSIS REPORT****

June 26, 2020

Long Term - Alpha Track Radon Testing

Kit Number	Start Date	End Date	Building	Room	Project ID	Floor	Result (pCi/L)
403803	9/3/2019	6/19/2020	North Eugene High School	Room 600	School District 4J	1	1.8
403816	9/3/2019	6/19/2020	North Eugene High School	Room 600	School District 4J	1	1.8
403807	9/3/2019	6/19/2020	North Eugene High School	Room 312	School District 4J	1	2.5
403810	9/3/2019	6/19/2020	North Eugene High School	Room 312	School District 4J	1	3.4