

Spring Creek Elementary **LABORATORY ANALYSIS REPORT**

June 26, 2020

Long Term - Alpha Track Radon Testing

Kit Number	Start Date	End Date	Building	Room	Project ID	Floor	Result (pCi/L)
403811	9/3/2019	6/19/2020	Spring Creek Elementary	Staff Break Room	School District 4J	1	6.7
403813	9/3/2019	6/19/2020	Spring Creek Elementary	Staff Break Room	School District 4J	1	7.6