## 2022 Multisite Wood Floor Refinishing FIP#2216

## **ADDENDUM NO. 1**

February 17, 2022

This addendum is being issued for clarification and/ or revision of the Contract Documents as noted. This document is hereby made a part of the Contract Documents to the extent as though it was originally included herein.

Bidder shall notify all sub-bidders of this addendum, and shall acknowledge receipt of this addendum by inserting the above addendum number in the space provided on the bid form prior to submitting bids. Failure to acknowledge receipt of any addendum will subject the bidder to disqualification.

## The following are clarifications to the Contract Documents:

Item	Reference	Description
1.00	Section 09 64 66 Athletic Flooring	Part 1 GENERAL  1.2 QUALITY INSURANCE  Current text:  C. The District may perform a series of scratch tests to verify dry film thickness of each coat. Should the dry film thickness per coat prove to be less than 2 mils, application of additional coats will be required.  Change to:  C. The District may perform a series of scratch tests to verify dry film thickness of each coat. Should the dry film thickness per coat prove to be less than 1.5 mil, application of additional coats may be required. (Note: The anticipated per coat dry film thickness of 1.5 mil or more applies only to the specific finish products identified in Part 2. Dry film thickness of substituted products may differ, possibly requiring additional applications.)
		process, requiring accumentation approximation