

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw		
	Fixture Use	Fixture Type	Date Sampled	2020-21 Sample ID #	2021 Result (ppb)
Churchill High School					
Kitchen Produce Sink	Food Preparation	Sink	5/27/2021	20822300-066KF	0.25
Kitchen - Snack Room	Other Human Consumption	Sink	8/11/2021	20822300-067KF	0.87
Kitchen Handwash	Food Preparation	Sink	5/27/2021	20822300-065KF	0.64
Kitchen Office Restroom	Food Preparation	Sink	5/27/2021	20822300-061BF	0.25
Kitchen Dishwashing Area (Wash)	Food Preparation	Sink	5/27/2021	20822300-055KF	1.12
Kitchen Dishwashing Area (Rinse)	Food Preparation	Sprayer	5/27/2021	20822300-054KF	0.43
Kitchen Dishwashing Area (Sanitize)	Food Preparation	Sink	5/27/2021	20822300-053KF	1.38
Kitchen Dishwashing Area (Eyewash)	Food Preparation	Sink	5/27/2021	20822300-052KF	3.63
Kitchen Dish Room East Wall	Food Preparation	Sprayer	9/8/2021	20822300-056KF	5.16
Kitchen Dish Room West Wall	Food Preparation	Sprayer	8/11/2021	20822300-058KF	2.95
Kitchen - Steam Kettle	Other Human Consumption	Hose	5/27/2021	20822300-274KF	2.56
Kitchen Area Staff Lounge	Food Preparation	Sink	5/27/2021	20822300-069SF	1.76
Kitchen South Side of Middle Partition	Drinking Fountain	Ice Machine	5/27/2021	20822300-057IM	ND
Custodian Office Restroom	Other Human Consumption	Sink	5/27/2021	20822300-070BF	ND
Cafeteria (West) Drinking Fountain	Drinking Fountain	Fountain	5/27/2021	20822300-068DW	0.47
Cafeteria (East) Drinking Fountain	Drinking Fountain	Fountain	5/27/2021	20822300-059DW	ND
Cafeteria (East) Bottle Filler	Other Human Consumption	Elkay Bottle F.	5/27/2021	20822300-060WB	ND
Gym East Drinking Fountain	Drinking Fountain	Fountain	5/27/2021	20822300-078DW	ND
Gym East Drinking Fountain	Drinking Fountain	Fountain	5/27/2021	20822300-079DW	ND
Gym East Bottle Filler	Other Human Consumption	Elkay Bottle F.	5/27/2021	20822300-080WB	ND
Men's Locker Room	Drinking Fountain	Fountain	5/27/2021	20822300-084DW	0.65
Men's Locker Room Restroom (East)	Other Human Consumption	Sink	5/27/2021	20822300-087BF	ND
Men's Locker Room Restroom (West)	Other Human Consumption	Sink	5/27/2021	20822300-088BF	0.99
Men's Locker Room Coaches Shower Restroom	Other Human Consumption	Sink	5/27/2021	20822300-104BF	7.50
Gym West End (North)	Drinking Fountain	Fountain	5/27/2021	20822300-110DW	0.90
Training Room	Other Human Consumption	Staff Faucet	5/27/2021	20822300-108SF	0.81
Training Room Ice Machine	Drinking Fountain	Ice Machine	5/27/2021	20822300-115IM	0.27
Athletic Equipment Area Restroom	Other Human Consumption	Sink	5/27/2021	20822300-111BF	0.27
Athletic Equipment Area	Drinking Fountain	Fountain	5/27/2021	20822300-113DW	1.38
Gym West End (South)	Drinking Fountain	Fountain	5/27/2021	20822300-109DW	0.53
Women's Locker Room (North)	Drinking Fountain	Fountain	4/26/2022	20822300-114DW	6.39
Women's Locker Room North Wall (West)	Other Human Consumption	Sink	5/27/2021	20822300-122BF	1.20
Women's Locker Room North Wall (East)	Other Human Consumption	Sink	5/27/2021	20822300-123BF	3.17
Women's Locker Room South Wall (East)	Other Human Consumption	Sink	5/27/2021	20822300-124BF	0.34
Women's Locker Room South Wall (West)	Other Human Consumption	Sink	5/27/2021	20822300-125BF	3.37
Women's Locker Room (South)	Drinking Fountain	Fountain	5/27/2021	20822300-120DW	1.67
Women's Locker Room Coaches Office Restroom	Other Human Consumption	Sink	5/27/2021	20822300-119BF	2.08
Gym Snack Shop	Other Human Consumption	Sink	5/27/2021	20822300-140SF	4.38
Library IMC	Other Human Consumption	Sink	5/27/2021	20822300-179SF	0.32
Corridor outside Library (North)	Drinking Fountain	Fountain	5/27/2021	20822300-273DW	0.40
Corridor outside Library (South)	Drinking Fountain	Fountain	5/27/2021	20822300-272DW	0.63
Girls Restroom Between Library and F Wing (South)	Other Human Consumption	Sink	5/27/2021	20822300-266BF	0.44
Girls Restroom Between Library and F Wing (North)	Other Human Consumption	Sink	5/27/2021	20822300-265BF	0.40
Boys Restroom between Library and F Wing (South)	Other Human Consumption	Sink	5/27/2021	20822300-263BF	0.44
Boys Restroom between Library and F Wing (South)	Other Human Consumption	Sink	5/27/2021	20822300-264BF	0.33
Corridor at West end of F wing Drinking Fountain (North unit)	Drinking Fountain	Fountain	5/27/2021	20822300-268DW	ND
Corridor at West end of F wing Drinking Fountain (South unit)	Drinking Fountain	Fountain	5/27/2021	20822300-267DW	0.78
Corridor at West end of F wing Bottle Filler (South unit)	Other Human Consumption	Elkay Bottle F.	5/27/2021	20822300-269WB	ND
J Wing North Corridor	Drinking Fountain	Fountain	5/27/2021	20822300-180DW	ND
Room J24	Other Human Consumption	Sink	5/27/2021	20822300-275CF	2.03
Student Store	Other Human Consumption	Sink	8/11/2021	20822300-191SF	1.32
Corridor East of J Wing (North)	Drinking Fountain	Fountain	5/27/2021	20822300-187DW	0.30
Corridor East of J Wing (South)	Drinking Fountain	Fountain	5/27/2021	20822300-186DW	0.35
J Wing South Corridor Drinking Fountain	Drinking Fountain	Fountain	5/27/2021	20822300-182DW	ND
J Wing South Corridor Bottle Filler	Other Human Consumption	Elkay Bottle F.	5/27/2021	20822300-183WB	ND
International High School Staff	Other Human Consumption	Sink	5/27/2021	20822300-181SF	ND
H Wing South Corridor	Drinking Fountain	Fountain	5/27/2021	20822300-202DW	0.44
H Wing Math Office	Other Human Consumption	Sink	5/27/2021	20822300-214SF	1.40
H Wing Science Office	Other Human Consumption	Sink	5/27/2021	20822300-277CF	0.63
F Wing Computer Services	Other Human Consumption	Sink	5/27/2021	20822300-243SF	0.61
F Wing South Corridor	Drinking Fountain	Fountain	5/27/2021	20822300-229DW	0.61
Room F44 South Wall	Other Human Consumption	Sink	5/27/2021	20822300-243SF	0.61
F Wing 2nd Language Office	Other Human Consumption	Sink	5/27/2021	20822300-230SF	6.82
Room F55	Other Human Consumption	Sink	5/27/2021	20822300-231SF	5.59
Laundry Room adjoining Room F55	Other Human Consumption	Sink	5/27/2021	20822300-232CF	2.10
Room F49 North Wall	Other Human Consumption	Sink	5/27/2021	20822300-239CF	3.72
Room F49 North Island (North)	Other Human Consumption	Sink	5/27/2021	20822300-238CF	3.13
Room F49 North Island (South)	Other Human Consumption	Sink	5/27/2021	20822300-237CF	4.67
Room F49 South Island (North)	Other Human Consumption	Sink	5/27/2021	20822300-236CF	3.37
Room F49 South Island (South)	Other Human Consumption	Sink	5/27/2021	20822300-235CF	2.82
Room F49 South Wall	Other Human Consumption	Sink	5/27/2021	20822300-234CF	3.22
Room F49 West Wall	Other Human Consumption	Sink	5/27/2021	20822300-233CF	2.82
Room F49 Office	Other Human Consumption	Sink	5/27/2021	20822300-240SF	2.40
Room F37	Other Human Consumption	Sink	5/27/2021	20822300-242CF	ND

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw		
	Fixture Use	Fixture Type	Date Sampled	2020-21 Sample ID #	2021 Result (ppb)
Churchill High School					
F Wing North Corridor	Drinking Fountain	Fountain	5/27/2021	20822300-246DW	0.92
Administrative Wing Staff Lounge	Drinking Fountain	Filtered Faucet	4/26/2022	20822300-279SF	ND
Administrative Wing Staff Lounge	Other Human Consumption	Sink	5/27/2021	20822300-247SF	ND
Health Center	Other Human Consumption	Sink	5/27/2021	20822300-256NS	0.59
Health Center North Restroom	Other Human Consumption	Sink	5/27/2021	20822300-257BF	1.09
Health Center North Exam Room	Other Human Consumption	Sink	5/27/2021	20822300-259NS	2.81
Health Center South Restroom	Other Human Consumption	Sink	5/27/2021	20822300-258BF	2.65
Health Center South Exam Room	Other Human Consumption	Sink	5/27/2021	20822300-261NS	3.95
Administrative Staff All Gender Restroom (North)	Other Human Consumption	Sink	5/27/2021	20822300-254BF	0.53
Administrative Staff All Gender Restroom (South)	Other Human Consumption	Sink	5/27/2021	20822300-255BF	0.21
Administrative Staff Women's Restroom (South)	Other Human Consumption	Sink	5/27/2021	20822300-252BF	0.61
Administrative Staff Women's Restroom (North)	Other Human Consumption	Sink	5/27/2021	20822300-253BF	0.44
Administrative Wing Corridor	Drinking Fountain	Fountain	5/27/2021	20822300-251DW	1.15
Administrative Wing Work Room	Other Human Consumption	Sink	5/27/2021	20822300-250SF	0.24
A Wing Women's Restroom (North)	Other Human Consumption	Sink	5/27/2021	20822300-043BF	1.09
A Wing Women's Restroom (South)	Other Human Consumption	Sink	5/27/2021	20822300-044BF	0.50
A Wing West Corridor	Drinking Fountain	Fountain	5/27/2021	20822300-041DW	0.59
A Wing Men's Restroom (West)	Other Human Consumption	Sink	5/27/2021	20822300-045BF	0.72
A Wing Men's Restroom (East)	Other Human Consumption	Sink	5/27/2021	20822300-046BF	1.01
Room DB	Drinking Fountain	Fountain	5/27/2021	20822300-047DW	1.01
Room D2	Drinking Fountain	Fountain	5/27/2021	20822300-049DW	2.16
Room D2	Other Human Consumption	Sink	5/27/2021	20822300-048CF	3.80
Band/Choir Room D2 Office	Other Human Consumption	Sink	5/27/2021	20822300-050SF	5.71
Hallway Drinking Fountain near B1	Drinking Fountain	Fountain	5/27/2021	20822300-037DW	ND
Hallway Water Bottle Filler near B1	Other Human Consumption	Elkay Bottle F.	5/27/2021	20822300-038WB	ND
Room B1 (West)	Other Human Consumption	Sink	9/8/2021	20822300-031CF	5.16
Room B1 (East)	Other Human Consumption	Sink	5/27/2021	20822300-032CF	2.01
Room B4 (East)	Other Human Consumption	Sink	5/27/2021	20822300-029CF	1.43
Room B4 (West)	Other Human Consumption	Sink	5/27/2021	20822300-030CF	0.30
Room near hallway adjacent to B17	Other Human Consumption	Sink	5/27/2021	20822300-026CF	4.03
B4 / B1 Shared East Commons Room	Other Human Consumption	Sink	5/27/2021	20822300-028SF	13.30
Restroom near hallway adjacent to B17	Other Human Consumption	Sink	5/27/2021	20822300-033BF	0.87
Restroom near hallway adjacent to B17	Other Human Consumption	Sink	5/27/2021	20822300-036BF	2.74
Room C9 Sink Island (Southwest)	Other Human Consumption	Sink	5/27/2021	20822300-018CF	0.53
Room C9 Sink Island (Center)	Other Human Consumption	Sink	5/27/2021	20822300-019CF	ND
Room C9 Sink Island (Center)	Other Human Consumption	Sink	5/27/2021	20822300-022CF	0.47
Room C9 Sink Island (Southeast)	Other Human Consumption	Sink	5/27/2021	20822300-021CF	1.56
Room C8 Near Door	Other Human Consumption	Sink	5/27/2021	20822300-016CF	3.95
Room C8 Northeast of Door	Other Human Consumption	Sink	5/27/2021	20822300-017CF	2.91
C Wing Corridor	Drinking Fountain	Fountain	5/27/2021	20822300-278DW	0.82
STEM Wing South Corridor (Upper)	Drinking Fountain	Fountain	5/27/2021	20822300-011DW	ND
STEM Wing South Corridor (Lower)	Drinking Fountain	Fountain	5/27/2021	20822300-012WB	ND
STEM Wing Women's Restroom (East)	Other Human Consumption	Sink	5/27/2021	20822300-007BF	1.35
STEM Wing Women's Restroom (center)	Other Human Consumption	Sink	5/27/2021	20822300-008BF	ND
STEM Wing Women's Restroom (West)	Other Human Consumption	Sink	5/27/2021	20822300-009BF	0.72
STEM Wing Men's Restroom (East)	Other Human Consumption	Sink	5/27/2021	20822300-006BF	0.27
STEM Wing Men's Restroom (center)	Other Human Consumption	Sink	5/27/2021	20822300-005BF	ND
STEM Wing Men's Restroom (West)	Other Human Consumption	Sink	5/27/2021	20822300-004BF	0.32
STEM Wing Meeting Room	Other Human Consumption	Sink	5/27/2021	20822300-002SF	0.30
STEM Wing Room 112-By entrance to Room 118	Other Human Consumption	Sink	5/27/2021	20822300-001CF	ND
STEM Wing Room 112	Other Human Consumption	Sink	5/27/2021	20822300-010CF	0.22
STEM Greenhouse Sink	Other Human Consumption	Sink	4/26/2022	20822300-013OT	4.96
Health Clinic Restroom	Other Human Consumption	Sink	5/27/2021	20822300-225BF	ND
Health Clinic Kitchen	Food Preparation	Sink	5/27/2021	20822300-227NS	4.40
Health Clinic Sink Sprayer	Other Human Consumption	Sprayer	5/27/2021	20822300-276OT	0.45
Health Clinic North Exam Room	Other Human Consumption	Sink	5/27/2021	20822300-228NS	1.09
Health Clinic South Exam Room-West Side	Other Human Consumption	Sink	5/27/2021	20822300-223NS	0.97
Health Clinic South Exam Room-East Side	Other Human Consumption	Sink	5/27/2021	20822300-224NS	3.61
Corridor West of H Wing South Fixture	Drinking Fountain	Fountain	5/27/2021	20822300-196DW	0.45
Corridor West of H Wing North Fixture	Drinking Fountain	Fountain	5/27/2021	20822300-197DW	1.18
H Wing Staff Women's Restroom North Fixture	Other Human Consumption	Sink	5/27/2021	20822300-207BF	1.48
H Wing Staff Women's Restroom South Fixture	Other Human Consumption	Sink	5/27/2021	20822300-206BF	1.13
H Wing Staff Men's Restroom South Fixture	Other Human Consumption	Sink	5/27/2021	20822300-204BF	1.28
H Wing Staff Men's Restroom North Fixture	Other Human Consumption	Sink	5/27/2021	20822300-203BF	5.55
Science Lab Storage Room	Other Human Consumption	Sink	5/27/2021	20822300-213SF	12.30
Science Lab Chemical Storage Room	Other Human Consumption	Sink	5/27/2021	20822300-216SF	12.10
Science Lab Textbook Storage Room	Other Human Consumption	Sink	5/27/2021	20822300-217SF	5.42
Room H20	Other Human Consumption	Sink	5/27/2021	20822300-208CF	9.37
Room H19 South Wall	Other Human Consumption	Sink	5/27/2021	20822300-201CF	3.82
Site (outside of building) CHS Stadium Hydrant	Other Human Consumption	Hose Bibb	4/26/2022	20822300-282OT	1.00
Site (outside of building) Tennis Courts Fountain - City of Eugene Owned	Drinking Fountain	Fountain	5/27/2021	20822300-280DW	0.35
<u>Fixture Types:</u>					
DF= Drinking Fountain S= Sink IH= Instahot FR= Fridge HB= Hose Bibb					

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.