

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw		
Family School (Crest Drive)	Fixture Use	Fixture Type	Date Sampled	2020-21 Sample ID #	2021 Result (ppb)
Kitchen Produce Sink	Food Preparation	Sink	6/8/2021	20822800-045KF	3.00
Kitchen Hand Wash Sink	Food Preparation	Sink	6/8/2021	20822800-046KF	2.80
Kitchen-Dishes Sprayer	Other Human Consumption	Sink	6/8/2021	20822800-047KF	0.92
Cafeteria Drinking Fountain	Drinking Fountain	Fountain	6/8/2021	20822800-066DW	ND
Cafeteria Bottle Filler	Other Human Consumption	Sink	6/8/2021	20822800-067WB	ND
Gym Restroom Boys	Other Human Consumption	Sink	6/8/2021	20822800-048BF	0.36
Gym Restroom Girls	Other Human Consumption	Sink	6/8/2021	20822800-053BF	ND
Gym - Drinking Fountain	Drinking Fountain	Fountain	6/8/2021	20822800-055DW	ND
Gym - Bottle Filler	Other Human Consumption	Bottle Filler	6/8/2021	20822800-056WB	ND
Staff Lounge	Other Human Consumption	Sink	6/8/2021	20822800-054SF	2.20
Staff Lounge-Insta-Hot	Drinking Fountain	Insta-Hot	2/24/2022	20822800-068OT	0.47
Office Work Room	Other Human Consumption	Sink	6/8/2021	20822800-059SF	1.32
Office Work Room	Drinking Fountain	Fountain	6/8/2021	20822800-060DW	1.83
Office West Restroom	Other Human Consumption	Sink	6/8/2021	20822800-064BF	0.69
Office East Restroom	Other Human Consumption	Sink	6/8/2021	20822800-065BF	0.49
Computer Room	Drinking Fountain	Fountain	6/8/2021	20822800-062DW	1.08
Computer Room	Other Human Consumption	Sink	6/8/2021	20822800-061SF	2.56
Music Room	Other Human Consumption	Sink	6/8/2021	20822800-051DW	0.68
Music Room	Drinking Fountain	Fountain	6/8/2021	20822800-052NS	0.89
Room 9	Drinking Fountain	Fountain	6/8/2021	20822800-050DW	3.09
Room 9	Other Human Consumption	Sink	6/8/2021	20822800-049CF	4.32
C-7 through C9 Workroom	Other Human Consumption	Sink	6/8/2021	20822800-040DW	1.85
C-7 through C9 Workroom East Restroom	Other Human Consumption	Sink	6/8/2021	20822800-038BF	3.48
C-7 through C9 Workroom West Restroom	Other Human Consumption	Sink	6/8/2021	20822800-039BF	0.53
Room 7	Drinking Fountain	Fountain	6/8/2021	20822800-037CF	2.24
Room 7	Other Human Consumption	Sink	6/8/2021	20822800-036DW	1.87
Room 8	Drinking Fountain	Fountain	6/8/2021	20822800-042CF	1.89
Room 8	Other Human Consumption	Sink	6/8/2021	20822800-041DW	8.97
Cluster B Workroom	Drinking Fountain	Fountain	6/8/2021	20822800-022DW	1.71
Cluster B Workroom West Restroom	Other Human Consumption	Sink	6/8/2021	20822800-025BF	0.97
Cluster B Workroom East Restroom	Other Human Consumption	Sink	6/8/2021	20822800-026BF	2.91
Playground Boys Restroom	Other Human Consumption	Sink	6/8/2021	20822800-031SF	0.26
Playground Girls Restroom	Other Human Consumption	Sink	6/8/2021	20822800-032BF	1.14
Cluster A Workroom	Drinking Fountain	Fountain	6/8/2021	20822800-010DW	1.95
Cluster A Workroom West Restroom	Other Human Consumption	Sink	6/8/2021	20822800-011BF	0.69
Cluster A Workroom East Restroom	Other Human Consumption	Sink	6/8/2021	20822800-012BF	0.90
Room A3	Other Human Consumption	Sink	6/8/2021	20822800-016CF	0.78
Room A3	Drinking Fountain	Fountain	6/8/2021	20822800-015DW	0.81
Portable P-1	Other Human Consumption	Sink	6/8/2021	20822800-003CF	0.49
Portable P-1	Drinking Fountain	Fountain	6/8/2021	20822800-004DW	2.74
Portable P-1 Front North Restroom	Other Human Consumption	Sink	6/8/2021	20822800-006BF	0.49
Portable P-2 Restroom	Other Human Consumption	Sink	6/8/2021	20822800-005BF	0.30
Portable P-2	Drinking Fountain	Fountain	6/8/2021	20822800-001CF	0.28
Portable P-2	Other Human Consumption	Sink	6/8/2021	20822800-002DW	1.45
Room B6	Drinking Fountain	Fountain	6/8/2021	20822800-029DW	3.95
Room B6	Other Human Consumption	Sink	6/8/2021	20822800-028CF	2.19
Room B5	Drinking Fountain	Fountain	6/8/2021	20822800-024DW	1.25
Room B5	Other Human Consumption	Sink	6/8/2021	20822800-023CF	2.66
Room B4	Drinking Fountain	Fountain	6/8/2021	20822800-021DW	2.22
Room B4	Other Human Consumption	Sink	6/8/2021	20822800-020CF	0.54
Room A2	Drinking Fountain	Fountain	6/8/2021	20822800-014DW	1.24
Room A2	Other Human Consumption	Sink	6/8/2021	20822800-013CF	0.61
Room A1	Drinking Fountain	Fountain	6/8/2021	20822800-008DW	0.52
Room A1	Other Human Consumption	Sink	6/8/2021	20822800-009CF	1.42
Fixture Types: DF= Drinking Fountain S= Sink IH= Instahot FR= Fridge					

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.