

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw		
Pathfinder/Bldg 2120	Fixture Use	Fixture Type	Date Sampled	2020-21 Sample ID #	2021 Result (ppb)
Time Out/School Store	Drinking Fountain	Fountain	6/9/2021	20824000-016DW	10.30
Time Out/School Store	Food Preparation	Sink	6/9/2021	20824000-015CF	0.50
Classroom 1	Drinking Fountain	Fountain	8/11/2021	20824000-006DW	0.87
Classroom 1	Other Human Consumption	Sink	6/9/2021	20824000-005CF	2.06
Classroom 2	Drinking Fountain	Fountain	6/9/2021	20824000-002DW	11.70
Classroom 2	Other Human Consumption	Sink	6/9/2021	20824000-001CF	1.10
Room 3 Recreation	Drinking Fountain	Fountain	6/9/2021	20824000-004DW	0.30
Room 3 Recreation	Other Human Consumption	Sink	6/9/2021	20824000-003CF	0.30
Women's Restroom (Left)	Other Human Consumption	Sink	6/9/2021	20824000-011BF	ND
Women's Restroom (Right)	Other Human Consumption	Sink	6/9/2021	20824000-010BF	0.85
Men's Restroom	Other Human Consumption	Sink	6/9/2021	20824000-014BF	1.18
Main Hallway Drinking Fountain	Drinking Fountain	Fountain	6/9/2021	20824000-012DW	ND
Main Hallway Bottle Filler	Other Human Consumption	Bottle Filler	6/9/2021	20824000-013WB	ND
Cafeteria South Wall	Food Preparation	Sink	6/9/2021	20824000-017SF	1.17
Transition Room	Drinking Fountain	Fountain	6/9/2021	20824000-019DW	1.81
Transition Room	Other Human Consumption	Sink	6/9/2021	20824000-018CF	ND
Fixture Types:					
DF= Drinking Fountain S= Sink IH= Instahot FR= Fridge HB= Hose Bib					

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.