

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location		First Draw			
	Fixture Use	Fixture Type	Date Sampled	2020-21 Sample ID #	2021 Result (ppb)
Twin Oaks Elementary School					
Main Entry Hallway - Drinking Fountain	Drinking Fountain	Fountain	6/9/2021	20821700-062DW	ND
Main Entry Hallway - Bottle Filler	Other Human Consumption	Bottle Filler	6/9/2021	20821700-063WB	ND
Principal Office	Other Human Consumption	Sink	6/9/2021	20821700-059SF	4.45
Health Room	Other Human Consumption	Sink	6/9/2021	20821700-057NS	1.62
Health Room Sink Sprayer	Other Human Consumption	Sprayer	6/9/2021	20821700-058OT	2.54
Health Room Restroom	Other Human Consumption	Sink	6/9/2021	20821700-061BF	2.02
Staff Lounge Insta-Hot	Drinking Fountain	Insta-Hot	6/9/2021	20821700-055OT	0.76
Staff Lounge Sink	Other Human Consumption	Sink	6/9/2021	20821700-054SF	1.21
Staff Lounge Sink Sprayer	Other Human Consumption	Sprayer	6/9/2021	20821700-056OT	0.96
Staff Lounge Restroom	Other Human Consumption	Sink	6/9/2021	20821700-064BF	1.27
Boys Restroom Main Level	Other Human Consumption	Sink	6/9/2021	20821700-046BF	0.64
Boys Restroom Main Level	Other Human Consumption	Sink	6/9/2021	20821700-047BF	0.58
Boys Restroom Main Level	Other Human Consumption	Sink	6/9/2021	20821700-048BF	0.56
Girls Restroom Main Level	Other Human Consumption	Sink	6/9/2021	20821700-051BF	0.98
Girls Restroom Main Level	Other Human Consumption	Sink	6/9/2021	20821700-052BF	0.76
Room 1	Other Human Consumption	Sink	6/9/2021	20821700-076CF	1.83
Room 1	Drinking Fountain	Fountain	6/9/2021	20821700-049DW	3.41
Room 2	Drinking Fountain	Fountain	6/9/2021	20821700-045DW	3.35
Room 2	Other Human Consumption	Sink	6/9/2021	20821700-044CF	1.97
Room 3	Other Human Consumption	Sink	6/9/2021	20821700-042CF	7.54
Room 3	Drinking Fountain	Fountain	6/9/2021	20821700-043DW	5.32
Room 4	Other Human Consumption	Sink	6/9/2021	20821700-040CF	3.08
Room 4	Drinking Fountain	Fountain	6/9/2021	20821700-041DW	8.93
Room 4 Restroom West	Other Human Consumption	Sink	6/9/2021	20821700-038BF	1.78
Room 4 Restroom East	Other Human Consumption	Sink	6/9/2021	20821700-039BF	1.42
Room 5	Other Human Consumption	Sink	6/9/2021	20821700-016CF	1.60
Room 5	Drinking Fountain	Fountain	6/9/2021	20821700-037DW	2.87
Room 6	Other Human Consumption	Sink	6/9/2021	20821700-036CF	4.32
Room 6	Drinking Fountain	Fountain	6/9/2021	20821700-035DW	2.61
Room 6 West Restroom	Other Human Consumption	Sink	6/9/2021	20821700-033BF	4.87
Room 6 East Restroom	Other Human Consumption	Sink	6/9/2021	20821700-034BF	2.01
Room 7	Other Human Consumption	Sink	6/9/2021	20821700-018CF	0.71
Room 7	Drinking Fountain	Fountain	6/9/2021	20821700-019DW	4.08
Room 8	Other Human Consumption	Sink	6/9/2021	20821700-031CF	0.84
Room 8	Drinking Fountain	Fountain	6/9/2021	20821700-024DW	12.50
Room 8 West Restroom	Other Human Consumption	Sink	6/9/2021	20821700-023BF	0.68
Room 8 East Restroom	Other Human Consumption	Sink	6/9/2021	20821700-022BF	1.47
Room 9	Drinking Fountain	Fountain	6/9/2021	20821700-020DW	2.02
Room 9	Other Human Consumption	Sink	6/9/2021	20821700-021CF	1.31
Room 10	Drinking Fountain	Fountain	6/9/2021	20821700-029DW	0.79
Room 10	Other Human Consumption	Sink	6/9/2021	20821700-030CF	0.69
Room 10 West Restroom	Other Human Consumption	Sink	6/9/2021	20821700-026BF	1.50
Room 10 East Restroom	Other Human Consumption	Sink	6/9/2021	20821700-028BF	1.38
Classroom Wing - West End	Drinking Fountain	Fountain	6/9/2021	20821700-025DW	2.12
Instructional Materials Center	Other Human Consumption	Sink	6/9/2021	20821700-077SF	10.80
Cafeteria - Drinking Fountain	Drinking Fountain	Fountain	6/9/2021	20821700-074DW	ND
Cafeteria - Bottle Filler	Other Human Consumption	Bottle Filler	6/9/2021	20821700-075WB	ND
Kitchen North Faucet	Food Preparation	Sink	6/9/2021	20821700-065KF	1.01
Kitchen Sink Sprayer	Other Human Consumption	Sprayer	6/9/2021	20821700-066OT	4.49
Kitchen SouthEast Faucet	Food Preparation	Sink	6/9/2021	20821700-071KF	0.78
Kitchen West Faucet	Food Preparation	Sink	6/9/2021	20821700-072KF	1.23
Kitchen Restroom	Other Human Consumption	Sink	6/9/2021	20821700-070BF	2.34
Room 11	Drinking Fountain	Fountain	6/9/2021	20821700-002DW	3.80
Room 11	Other Human Consumption	Sink	6/9/2021	20821700-003CF	2.64
Room 12	Drinking Fountain	Fountain	6/9/2021	20821700-004DW	1.05
Room 12	Other Human Consumption	Sink	6/9/2021	20821700-005CF	4.05
Lower Hallway Outside Room 12	Drinking Fountain	Fountain	6/9/2021	20821700-008DW	2.17
Lower Hallway Staff Restroom outside room 12	Other Human Consumption	Sink	6/9/2021	20821700-010BF	0.55
Room 13	Drinking Fountain	Fountain	6/9/2021	20821700-006DW	3.08
Room 13	Other Human Consumption	Sink	6/9/2021	20821700-007CF	1.36
Fixture Types: DF= Drinking Fountain S= Sink IH= Instahot FR= Fridge HB= Hose Bib					

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.