

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw		
Willard	Fixture Use	Fixture Type	Date Sampled	Sample ID #	2020 Result (ppb)
Portable 5	Drinking Fountain	Fountain	11/9/2020	20820040-001DW20A	4.72
Portable 5	Other Human Consumption	Sink	11/9/2020	20820040-002CF20A	9.24
Portable 5-Bathroom	Other Human Consumption	Sink	11/9/2020	20820040-003BF20A	2.38
Portable 6-Bathroom	Other Human Consumption	Sink	11/9/2020	20820040-004BF20A	2.58
Portable 6	Other Human Consumption	Sink	11/9/2020	20820040-005CF20A	2.63
Portable 6	Drinking Fountain	Fountain	11/9/2020	20820040-006DW20A	1.13
Portable 4	Other Human Consumption	Sink	11/9/2020	20820040-007CF20A	2.87
Portable 4	Drinking Fountain	Fountain	11/9/2020	20820040-008DW20A	1.00
Portable 4-Bathroom	Other Human Consumption	Sink	11/9/2020	20820040-009BF20A	1.16
Portable 3-Bathroom	Other Human Consumption	Sink	11/9/2020	20820040-010BF20A	1.85
Portable 3	Other Human Consumption	Sink	11/9/2020	20820040-011CF20A	1.16
Portable 3	Drinking Fountain	Fountain	11/9/2020	20820040-012DW20A	0.81
Portable 1	Drinking Fountain	Fountain	11/9/2020	20820040-013DW20A	1.78
Portable 1	Other Human Consumption	Sink	11/9/2020	20820040-014CF20A	2.67
Portable 1-Bathroom	Other Human Consumption	Sink	11/9/2020	20820040-015BF20A	1.87
Portable 2-Bathroom	Other Human Consumption	Sink	11/9/2020	20920040-016BF20A	0.80
Portable 2	Drinking Fountain	Fountain	11/9/2020	20820040-017DW20A	0.71
Portable 2	Other Human Consumption	Sink	11/9/2020	20820040-018CF20A	0.90
Cafeteria handwash sink (North)	Other Human Consumption	Sink	11/9/2020	20820040-019OT20A	2.10
Cafeteria handwash sink (South)	Other Human Consumption	Sink	11/9/2020	20820040-020OT20A	2.29
SW Office	Other Human Consumption	Sink	11/9/2020	20820040-022SF20A	2.27
Kitchen	Food Preparation	Sink	11/9/2020	20820040-023IM20A	ND
Kitchen	Food Preparation	Sink	11/9/2020	20820040-024KF20A	2.63
Kitchen	Food Preparation	Sink	11/9/2020	20820040-025KF20A	0.82
Kitchen	Food Preparation	Sink	11/9/2020	20820040-026KF20A	0.83
Kitchen Sprayer	Food Preparation	Sink	12/14/2020	20820040-079OT	0.50
Cafeteria Drinking Fountain	Drinking Fountain	Fountain	11/9/2020	20820040-027DW20A	ND
Cafeteria Bottle Filler	Other Human Consumption	Bottle Filler	12/14/2020	20820040-028WB	ND
Cafeteria	Drinking Fountain	Fountain	11/9/2020	20820040-029DW20A	ND
Bathroom, Outside Of Library	Other Human Consumption	Sink	11/9/2020	20820040-030BF20A	0.78
Bathroom, Outside Of Library	Other Human Consumption	Sink	11/9/2020	20820040-031BF20A	1.54
Bathroom, Outside Of Library	Other Human Consumption	Sink	11/9/2020	20820040-032BF20A	0.63
Classroom 10	Other Human Consumption	Sink	11/9/2020	20820040-033CF20A	1.89
Classroom 10	Drinking Fountain	Fountain	11/9/2020	20820040-034DW20A	1.30
Health Room Office Restroom	Other Human Consumption	Sink	11/9/2020	20820040-042NS20A	0.74
Main Office, Bathroom	Other Human Consumption	Sink	11/9/2020	20820040-044BF20A	1.34
Main Office, 110	Other Human Consumption	Sink	11/9/2020	20820040-045CF20A	1.60
Main Office, 110	Drinking Fountain	Fountain	11/9/2020	20820040-046DW20A	1.56
Classroom 9	Other Human Consumption	Sink	11/9/2020	20820040-047CF20A	2.04
Classroom 9	Drinking Fountain	Fountain	11/9/2020	20820040-048DW20A	1.93
Classroom 8	Other Human Consumption	Sink	11/9/2020	20820040-049CF20A	1.52
Classroom 8	Drinking Fountain	Fountain	11/9/2020	20820040-050DW20A	1.09
Classroom 7	Other Human Consumption	Sink	11/9/2020	20820040-051CF20A	1.76
Classroom 7	Drinking Fountain	Fountain	11/9/2020	20820040-052DW20A	2.68
Classroom 1	Other Human Consumption	Sink	11/9/2020	20820040-053CF20A	0.96
Classroom 1	Drinking Fountain	Fountain	11/9/2020	20820040-054DW20A	1.27
Classroom 2	Other Human Consumption	Sink	11/9/2020	20820040-056CF20A	1.70
Classroom 2	Drinking Fountain	Fountain	11/9/2020	20820040-057DW20A	1.66
Classroom 6	Other Human Consumption	Sink	11/9/2020	20820040-058CF20A	3.00
Classroom 6	Drinking Fountain	Fountain	11/9/2020	20820040-059DW20A	2.85
Classroom 5	Other Human Consumption	Sink	11/9/2020	20820040-061CF20A	2.08
Classroom 5	Drinking Fountain	Fountain	11/9/2020	20820040-062DW20A	1.52
Classroom 4	Other Human Consumption	Sink	11/9/2020	20820040-063CF20A	2.68
Classroom 4	Drinking Fountain	Fountain	11/9/2020	20820040-064DW20A	1.18
Classroom 3	Other Human Consumption	Sink	11/9/2020	20820040-066CF20A	2.48
Classroom 3	Drinking Fountain	Fountain	11/9/2020	20820040-067DW20A	1.25
Gym Bathroom	Other Human Consumption	Sink	11/9/2020	20820040-071BF20A	1.78
Gym Bathroom	Other Human Consumption	Sink	11/9/2020	20820040-072BF20A	2.79

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location		First Draw			
Willard	Fixture Use	Fixture Type	Date Sampled	Sample ID #	2020 Result (ppb)
Gym bottle filler	Other Human Consumption	Bottle Filler	11/9/2020	20820040-073WB20A	4.53
Gym	Drinking Fountain	Fountain	11/9/2020	20820040-074DW20A	4.48
Gym	Drinking Fountain	Fountain	11/9/2020	20820040-078DW20A	5.19
Fixture Types: DF= Drinking Fountain S= Sink IH= Instahot FR=					

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.

Report Date: 4/13/2022