

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw		
	Fixture Use	Fixture Type	Date Sampled	Sample ID #	2021-22 Result (ppb)
Room 603	Other Human Consumption	Sink	12/7/2021	20820300-119CF	3.37
Room 603	Drinking Fountain	Fountain	12/7/2021	20820300-118DW	0.32
Room 602	Other Human Consumption	Sink	12/7/2021	20820300-117CF	3.28
Room 602	Drinking Fountain	Fountain	12/7/2021	20820300-116DW	ND
Room 601	Other Human Consumption	Sink	12/7/2021	20820300-121CF	6.33
Room 601	Drinking Fountain	Fountain	12/7/2021	20820300-120DW	0.32
Room 604	Other Human Consumption	Sink	12/7/2021	20820300-157CF	3.62
Room 604	Drinking Fountain	Fountain	12/7/2021	20820300-158DW	0.88
2nd Floor Corridor (Upper)	Drinking Fountain	Fountain	12/7/2021	20820300-128DW	0.30
2nd Floor Corridor (Lower)	Drinking Fountain	Fountain	12/7/2021	20820300-129DW	ND
Room 608	Other Human Consumption	Sink	12/7/2021	20820300-138SF	0.94
Room 608	Drinking Fountain	Insta-Hot	12/7/2021	20820300-137OT	0.22
Room 707	Other Human Consumption	Sink	12/7/2021	20820300-141CF	4.99
Room 707	Drinking Fountain	Fountain	12/7/2021	20820300-140DW	0.22
2nd Floor Student Restroom	Other Human Consumption	Sink	12/7/2021	20820300-139BF	0.51
2nd Floor Staff Restroom	Other Human Consumption	Sink	12/7/2021	20820300-142BF	0.21
Room 706	Other Human Consumption	Sink	12/7/2021	20820300-144CF	0.73
Room 706	Drinking Fountain	Fountain	12/7/2021	20820300-143DW	ND
Room 701	Other Human Consumption	Sink	12/7/2021	20820300-146CF	2.93
Room 701	Drinking Fountain	Fountain	12/7/2021	20820300-145DW	ND
Room 702	Other Human Consumption	Sink	12/7/2021	20820300-150CF	3.42
Room 702	Drinking Fountain	Fountain	12/7/2021	20820300-149DW	ND
Room 705	Other Human Consumption	Sink	12/7/2021	20820300-148CF	0.79
Room 705	Drinking Fountain	Fountain	12/7/2021	20820300-147DW	ND
Room 704	Other Human Consumption	Sink	12/7/2021	20820300-154CF	3.25
Room 704	Drinking Fountain	Fountain	12/7/2021	20820300-153DW	ND
Room 703	Other Human Consumption	Sink	12/7/2021	20820300-152CF	4.75
Room 703	Drinking Fountain	Fountain	12/7/2021	20820300-151DW	ND
Room 203	Other Human Consumption	Sink	12/7/2021	20820300-113CF	0.35
Room 203	Drinking Fountain	Fountain	12/7/2021	20820300-114DW	ND
Room 202	Other Human Consumption	Sink	12/7/2021	20820300-111CF	3.38
Room 202	Drinking Fountain	Fountain	12/7/2021	20820300-112DW	ND
Room 201	Other Human Consumption	Sink	12/7/2021	20820300-103CF	0.35
Room 201	Drinking Fountain	Fountain	12/7/2021	20820300-104DW	ND
Room 204 North Wall (West)	Other Human Consumption	Sink	12/7/2021	20820300-110CF	1.98
Room 204 North Wall (Center)	Other Human Consumption	Sink	12/7/2021	20820300-109CF	0.98
Room 204 North Wall (East)	Other Human Consumption	Sink	12/7/2021	20820300-105CF	4.63
Room 204 North Wall	Drinking Fountain	Fountain	12/7/2021	20820300-106DW	ND
Room 204 South Wall (East)	Other Human Consumption	Sink	12/7/2021	20820300-107CF	0.58
Room 204 South Wall (West)	Other Human Consumption	Sink	12/7/2021	20820300-108CF	0.35
1st Floor Central Corridor (Upper)-Elkay	Drinking Fountain	Bottle Filler	12/7/2021	20820300-102WB	ND
1st Floor Central Corridor (Lower)-Elkay	Drinking Fountain	Fountain	12/7/2021	20820300-101DW	ND
1st Floor Central Corridor Men's Restroom	Other Human Consumption	Sink	12/7/2021	20820300-087BF	1.60
Media Center Office	Other Human Consumption	Sink	12/7/2021	20820300-084SF	1.10
Room 214 South Wall	Other Human Consumption	Sink	12/7/2021	20820300-159CF	1.34
Room 214 East Wall	Other Human Consumption	Sink	12/7/2021	20820300-085CF	1.64
Room 214 East Wall	Drinking Fountain	Fountain	12/7/2021	20820300-086DW	ND
Room 208 North Wall (West)	Other Human Consumption	Sink	12/7/2021	20820300-078CF	3.89
Room 208 North Wall (West)	Drinking Fountain	Fountain	12/7/2021	20820300-079DW	ND
Science Prep Room	Other Human Consumption	Sink	12/7/2021	20820300-156SF	2.71
Science Prep Between Room 208 & 209 Refrigerator	Other Human Consumption	Ice Machine	2/24/2022	20820300-162IM	1.10
Room 213 Large sink	Drinking Fountain	Fountain	12/7/2021	20820300-160DW	0.66
Room 213 Large sink	Other Human Consumption	Sink	4/27/2022	20820300-164CF	6.86
Room 213 Large sink	Other Human Consumption	Sink	4/27/2022	20820300-165CF	2.76
Room 213 Large sink	Other Human Consumption	Sink	4/27/2022	20820300-166CF	3.28
Room 213 North West Corner Fixture	Other Human Consumption	Sink	12/7/2021	20820300-081CF	4.11
Room 212	Other Human Consumption	Sink	12/7/2021	20820300-067CF	2.35
Room 212	Drinking Fountain	Fountain	12/7/2021	20820300-068DW	ND
Room 209 North Wall (West)	Other Human Consumption	Sink	12/7/2021	20820300-064CF	3.77
Room 209 North Wall (West)	Drinking Fountain	Fountain	12/7/2021	20820300-063DW	ND
Room 210 North Wall (West)	Other Human Consumption	Sink	12/7/2021	20820300-058CF	1.68
Room 210 North Wall (West)	Drinking Fountain	Fountain	12/7/2021	20820300-059DW	ND
Room 211 West Wall	Other Human Consumption	Sink	12/7/2021	20820300-066CF	3.65
Room 211 West Wall	Drinking Fountain	Fountain	12/7/2021	20820300-155DW	ND
Room 211 East Wall	Other Human Consumption	Sink	12/7/2021	20820300-051CF	5.93
Room 211 East Wall	Drinking Fountain	Fountain	12/7/2021	20820300-050DW	ND
Room 301	Other Human Consumption	Sink	12/7/2021	20820300-055CF	3.81
Room 301	Drinking Fountain	Fountain	12/7/2021	20820300-056DW	ND
Room 302	Other Human Consumption	Sink	12/7/2021	20820300-053CF	4.87
Room 302	Drinking Fountain	Fountain	12/7/2021	20820300-052DW	ND
Cafeteria 410 (Lower)-Elkay	Drinking Fountain	Fountain	12/7/2021	20820300-032DW	ND

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.

Eugene School District 4J
Water Quality: Lead Testing Results

Eugene School District 4J - Location		First Draw			
Cal Young Middle School	Fixture Use	Fixture Type	Date Sampled	Sample ID #	2021-22 Result (ppb)
Cafeteria 410 (Upper)-Elkay	Drinking Fountain	Bottle Filler	12/7/2021	20820300-033WB	ND
Kitchen Dishwasher Area	Food Preparation	Sink	12/7/2021	20820300-030KF	0.25
Kitchen Area Staff Restroom	Food Preparation	Sink	12/7/2021	20820300-023BF	0.70
Kitchen Produce Sink	Food Preparation	Sink	12/7/2021	20820300-025KF	0.52
Kitchen Sink Sprayer	Food Preparation	Sprayer	12/7/2021	20820300-031OT	0.38
Kitchen Sink Sprayer	Food Preparation	Sprayer	12/7/2021	20820300-026OT	0.76
Girls Locker Room Coaches Office Restroom	Other Human Consumption	Sink	12/7/2021	20820300-021BF	8.99
Gym Corridor North End (Upper)-Elkay	Drinking Fountain	Fountain	12/7/2021	20820300-011WB	ND
Gym Corridor North End (Lower)-Elkay	Drinking Fountain	Fountain	12/7/2021	20820300-012DW	ND
Boys Locker Room Coaches Office Restroom	Other Human Consumption	Sink	12/7/2021	20820300-002BF	1.82
Administrative Staff Men's Restroom	Other Human Consumption	Sink	12/7/2021	20820300-043BF	0.74
Administrative Staff Women's Restroom	Other Human Consumption	Sink	12/7/2021	20820300-036BF	1.84
Staff Lounge	Other Human Consumption	Sink	12/7/2021	20820300-041SF	0.44
Staff Lounge	Drinking Fountain	Insta-Hot	12/7/2021	20820300-042OT	ND
Staff Room Refrigerator - South	Other Human Consumption	Ice Machine	2/24/2022	20820300-161IM	0.91
Staff Room Refrigerator - North	Other Human Consumption	Ice Machine	2/24/2022	20820300-160IM	3.73
Health Room Restroom	Other Human Consumption	Sink	12/7/2021	20820300-044BF	4.61
Health Room Restroom	Other Human Consumption	Sink	12/7/2021	20820300-045NS	2.88
Fixture Types: DF= Drinking Fountain S= Sink IH= Instahot FR= Fridge HB= Hose Bib					

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.