

Eugene School District 4J  
Water Quality: Lead Testing Results

Eugene School District 4J - Location			First Draw		
Monroe Middle School	Fixture Use	Fixture Type	Date Sampled	Sample ID #	2021-22 Result (ppb)
Main Entry Corridor-Drinking Fountain	Drinking Fountain	Fountain	11/30/2021	20821200-118DW	ND
Main Entry Corridor-Bottle Filler	Other Human Consumption	Bottle Filler	11/30/2021	20821200-117WB	ND
Kitchen Handwashing	Food Preparation	Sink	11/30/2021	20821200-109KF	0.23
Kitchen Produce	Food Preparation	Sink	11/30/2021	20821200-113KF	0.36
Kitchen Staff Room	Food Preparation	Sink	11/30/2021	20821200-112BF	2.27
Kitchen Dish Room	Food Preparation	Sprayer	11/30/2021	20821200-114KF	0.78
Room B3	Other Human Consumption	Sink	11/30/2021	20821200-111CF	0.23
Room B3	Drinking Fountain	Fountain	11/30/2021	20821200-110DW	3.85
Office Work Room	Other Human Consumption	Sink	11/30/2021	20821200-057SF	1.44
Staff Lounge	Other Human Consumption	Sink	11/30/2021	20821200-058SF	ND
Staff Lounge	Other Human Consumption	Insta-Hot	11/30/2021	20821200-059OT	ND
Staff Lounge - Ice Machine	Other Human Consumption	Ice Machine	11/30/2021	20821200-056IM	ND
Office Area Women's Restroom	Other Human Consumption	Sink	11/30/2021	20821200-052BF	1.06
Office Area Men's Restroom	Other Human Consumption	Sink	11/30/2021	20821200-054BF	1.25
Breezeway Between C-Wing and Cafeteria	Drinking Fountain	Fountain	11/30/2021	20821200-104DW	2.64
C Wing Central Corridor-Drinking Fountain	Drinking Fountain	Fountain	11/30/2021	20821200-096DW	ND
C Wing Central Corridor-Bottle Filler	Other Human Consumption	Bottle Filler	11/30/2021	20821200-095WB	ND
Room C5 at entry	Drinking Fountain	Fountain	11/30/2021	20821200-119DW	1.53
Room C5, Stainless Sink, South	Other Human Consumption	Sink	2/8/2022	20821200-088CF	2.67
Room C5, Stainless Sink, North	Other Human Consumption	Sink	11/30/2021	20821200-089CF	4.82
Room C5, Middle White Sink, South	Other Human Consumption	Sink	11/30/2021	20821200-090CF	0.40
Room C5, Middle White Sink, North	Other Human Consumption	Sink	11/30/2021	20821200-091CF	0.23
Room C5, North White Sink, South	Other Human Consumption	Sink	11/30/2021	20821200-092CF	0.52
Room C5, North White Sink, North	Other Human Consumption	Sink	11/30/2021	20821200-093CF	0.40
Room C6	Drinking Fountain	Fountain	11/30/2021	20821200-097DW	0.91
Room C6 Utility Sink	Other Human Consumption	Sink	11/30/2021	20821200-098CF	1.11
Room A5-A8 Prep Room	Other Human Consumption	Sink	11/30/2021	20821200-033SF	0.99
A Wing Staff Women	Other Human Consumption	Sink	11/30/2021	20821200-027BF	1.12
Room A6 East Wall - South Sink	Other Human Consumption	Sink	11/30/2021	20821200-050CF	0.41
Room A6 East Wall - South Sink	Drinking Fountain	Fountain	11/30/2021	20821200-051DW	0.52
Room A1A	Other Human Consumption	Sink	11/30/2021	20821200-028SF	0.79
A Wing Staff Men	Other Human Consumption	Sink	11/30/2021	20821200-023BF	0.65
Corridor outside Library-Drinking Fountain	Drinking Fountain	Fountain	11/30/2021	20821200-067DW	ND
Corridor outside Library-Bottle Filler	Other Human Consumption	Bottle Filler	11/30/2021	20821200-068WB	ND
Library Periodicals	Other Human Consumption	Sink	11/30/2021	20821200-020SF	0.43
Library Periodicals	Drinking Fountain	Fountain	11/30/2021	20821200-019DW	ND
Library Conference Room	Other Human Consumption	Sink	11/30/2021	20821200-021SF	2.99
Room E10	Drinking Fountain	Fountain	11/30/2021	20821200-011DW	0.89
Room E10	Other Human Consumption	Sink	11/30/2021	20821200-012CF	2.36
Room E9	Drinking Fountain	Fountain	11/30/2021	20821200-009DW	0.85
Room E9	Other Human Consumption	Sink	11/30/2021	20821200-010CF	2.27
Room E8	Drinking Fountain	Fountain	11/30/2021	20821200-004DW	ND
Room E8	Other Human Consumption	Sink	11/30/2021	20821200-005CF	1.15
Room E7	Drinking Fountain	Fountain	11/30/2021	20821200-002DW	2.65
Room E7	Other Human Consumption	Sink	11/30/2021	20821200-003CF	1.72
E Wing Corridor (Upper)	Drinking Fountain	Fountain	11/30/2021	20821200-006DW	3.77
E Wing Corridor (Lower)	Drinking Fountain	Fountain	11/30/2021	20821200-007DW	0.50
E Wing at North Entrance	Drinking Fountain	Fountain	11/30/2021	20821200-018DW	6.08
Room E1A	Other Human Consumption	Sink	11/30/2021	20821200-074SF	2.09
Big Gym	Drinking Fountain	Fountain	11/30/2021	20821200-079DW	0.66
Boys Locker Room Restroom (South)	Other Human Consumption	Sink	11/30/2021	20821200-076BF	ND
Boys Locker Room Restroom (North)	Other Human Consumption	Sink	11/30/2021	20821200-075BF	0.45
Small Gym	Drinking Fountain	Fountain	11/30/2021	20821200-080DW	1.27
Girls Locker Room Restroom (East)	Other Human Consumption	Sink	11/30/2021	20821200-086BF	1.41
Girls Locker Room Restroom (West)	Other Human Consumption	Sink	11/30/2021	20821200-087BF	0.89
Fixture Types: DF= Drinking Fountain S= Sink IH= Instahot FR= Fridge HB= Hose Bib					

Using EPA's water sampling method for schools, action level is >15 parts per billion (ppb). Samples that tested above the action level are highlighted.