

RADON MONITORING REPORT

Description of the measurement

The measurement was performed with an Activated Charcoal Adsorption detector (QuickScreen) and was analyzed by Alpha Energy Laboratories (NRPP ID: 101132 AL).

The detector(s) arrived to Alpha Energy Laboratories, Inc. **12/09/2022**. They were measured **12/09/2022**.

The detectors were deployed by PBS Engineering and retrieved by PBS Engineering

Property data and address

MEASURE SITE ADDRESS

Sheldon High School Softball Comple

97401

BUILDING ID

Sheldon HS Softball Building 2022

Test results

DETECTOR	MEASUREMENT PERIOD	DESCRIPTION / LOCATION	FLOOR	RADON RESULT
<i>RK108834 [QuickScreen]</i>	<i>12/05/2022 07:00 AM – 12/08/2022 06:00 AM</i>	<i>Concessions</i>		< 1.2 pCi/L
<i>RK108767 [QuickScreen]</i>	<i>12/05/2022 07:00 AM – 12/08/2022 06:00 AM</i>	<i>Concessions</i>		< 1.1 pCi/L
<i>RK108762 [QuickScreen]</i>	<i>12/05/2022 07:00 AM – 12/08/2022 06:00 AM</i>	<i>Coach's Office</i>		1.2 ± 0.5 pCi/L
<i>RK117340 [QuickScreen]</i>	<i>12/05/2022 07:00 AM – 12/08/2022 06:00 AM</i>	<i>Locker Room</i>		< 0.6 pCi/L
<i>RK108776 [QuickScreen]</i>	<i>12/05/2022 07:00 AM – 12/08/2022 06:00 AM</i>	<i>Room A</i>		< 0.9 pCi/L

Radon test result report for:

Sheldon HS Test Results 2019

Sheldon High School

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9158646	9TH GRADE COUNSELOR	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158694	A1	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.7 ± 0.3	2019-02-04
9158695	A10	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.7 ± 0.4	2019-02-04
9158689	A2	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.9 ± 0.4	2019-02-04
9158699	A3	2019-01-28 @ 4:00 pm	2019-01-31 @ 8:00 pm	0.9 ± 0.3	2019-02-04
9158700	A4	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	1.0 ± 0.4	2019-02-04
9158692	A4	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	1.1 ± 0.4	2019-02-04
9158668	A6	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.8 ± 0.4	2019-02-04
9158690	A7	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.8 ± 0.3	2019-02-04
9158794	A8	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	1.1 ± 0.3	2019-02-04
9158691	A9	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.6 ± 0.4	2019-02-04
9175614	AD	2019-02-05 @ 3:00 am	2019-02-08 @ 1:00 am	0.7 ± 0.3	2019-02-11
9158757	AMY	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.2 ± 0.3	2019-02-04
9158687	ASL	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.9 ± 0.3	2019-02-04
9158795	AUDITORIUM	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	0.5 ± 0.3	2019-02-04
9158771	AUDITORIUM	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	0.7 ± 0.3	2019-02-04
9158778	AUDITORIUM	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	0.9 ± 0.3	2019-02-04
9158659	B10	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.9 ± 0.3	2019-02-04
9158652	B11	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.1 ± 0.4	2019-02-04
9158648	B12	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.7 ± 0.4	2019-02-04
9158649	B13	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.5 ± 0.3	2019-02-04
9158647	B13 STORAGE	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158643	B13 STORAGE 2	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.3	2019-02-04
9158644	B13 STORAGE 2	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.8 ± 0.3	2019-02-04
9158658	B14	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.3	2019-02-04
9158660	B15	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.3	2019-02-04
9158664	B16	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.4	2019-02-04
9158663	B16	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.4	2019-02-04
9158657	B17	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.1 ± 0.4	2019-02-04
9158650	B18	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158665	B19	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.3	2019-02-04
9158622	B2 OFFICE	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.9 ± 0.4	2019-02-04
9158620	B2 OFFICE	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.1 ± 0.4	2019-02-04
9158662	B20	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.7 ± 0.3	2019-02-04
9158661	B21	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158655	B22	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158683	B23	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	< 0.3	2019-02-04

Radon test result report for:**Sheldon High School**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9158681	B24	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	< 0.3	2019-02-04
9158684	B25	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.7 ± 0.4	2019-02-04
9158686	B26	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.7 ± 0.4	2019-02-04
9158696	B27	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.5 ± 0.3	2019-02-04
9158675	B28A	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.8 ± 0.4	2019-02-04
9158685	B29	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	< 0.3	2019-02-04
9158640	B3	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.3 ± 0.4	2019-02-04
9158680	B30	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.6 ± 0.4	2019-02-04
9158698	B31	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.9 ± 0.3	2019-02-04
9158626	B4	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.7 ± 0.4	2019-02-04
9158617	B5	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158616	B6	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158615	B7	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.9 ± 0.3	2019-02-04
9158621	B8	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.8 ± 0.3	2019-02-04
9158653	B9	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.8 ± 0.4	2019-02-04
9158773	BLANK	2019-01-29 @ 10:00 am	2019-02-01 @ 12:00 pm	< 0.3	2019-02-04
9158705	BLANK	2019-01-29 @ 10:00 am	2019-02-01 @ 12:00 pm	< 0.3	2019-02-04
9158784	BLANK	2019-01-29 @ 10:00 am	2019-02-01 @ 12:00 pm	< 0.3	2019-02-04
9158781	BLANK	2019-01-29 @ 10:00 am	2019-02-01 @ 12:00 pm	< 0.3	2019-02-04
9158774	BLANK	2019-01-29 @ 10:00 am	2019-02-01 @ 12:00 pm	< 0.3	2019-02-04
9158703	BLANK	2019-01-29 @ 10:00 am	2019-02-01 @ 12:00 pm	< 0.3	2019-02-04
9158978	BLANK	2019-01-29 @ 10:00 am	2019-02-01 @ 12:00 pm	< 0.3	2019-02-04
9158704	BLANK	2019-01-29 @ 10:00 am	2019-02-01 @ 12:00 pm	< 0.3	2019-02-04
9177904	BLUE ROOM IN D1	2019-03-04 @ 4:00 pm	2019-03-07 @ 4:00 pm	0.8 ± 0.4	2019-03-11
9158790	BOYS LOCKER	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.0 ± 0.4	2019-02-04
9158727	BUDDY	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	0.8 ± 0.4	2019-02-04
9158637	C1	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.1 ± 0.4	2019-02-04
9158642	C10	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.2 ± 0.4	2019-02-04
9158645	C11	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.0 ± 0.4	2019-02-04
9158761	C11	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.3	2019-02-04
9158651	C12	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.9 ± 0.4	2019-02-04
9158676	C14	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.6 ± 0.3	2019-02-04
9158641	C15	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.7 ± 0.4	2019-02-04
9158635	C2	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.7 ± 0.4	2019-02-04
9158624	C2 BREAK ROOM	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.8 ± 0.3	2019-02-04
9158631	C3	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.4 ± 0.4	2019-02-04
9158634	C4	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.5 ± 0.3	2019-02-04

Radon test result report for:**Sheldon High School**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9158682	C4	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.4	2019-02-04
9158760	C5	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.3	2019-02-04
9158632	C6	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.3 ± 0.4	2019-02-04
9158633	C7	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.9 ± 0.3	2019-02-04
9158636	C9	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.1 ± 0.4	2019-02-04
9158998	C9	2019-01-28 @ 8:00 pm	2019-01-31 @ 5:00 pm	1.3 ± 0.4	2019-02-04
9158605	CAFETERIA	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	< 0.3	2019-02-04
9158612	CAFETERIA	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.6 ± 0.3	2019-02-04
9158751	CAFETERIA	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.9 ± 0.4	2019-02-04
9158752	CAFETERIA	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.6 ± 0.3	2019-02-04
9158611	CAFETERIA	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.6 ± 0.3	2019-02-04
9158606	CARLEY	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	0.9 ± 0.4	2019-02-04
9158654	CINDY	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158753	CONCESSION	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	1.1 ± 0.3	2019-02-04
9158766	CONFERENCE 2	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.1 ± 0.3	2019-02-04
9158755	CUSTODIAL OFFIC	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	< 0.3	2019-02-04
9158756	CUSTODIAN	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.6 ± 0.3	2019-02-04
9158741	D1	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	1.2 ± 0.4	2019-02-04
9158754	D2	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.7 ± 0.3	2019-02-04
9158747	D2 OFFICE	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	1.1 ± 0.4	2019-02-04
9158609	D2 OFFICE	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.5 ± 0.3	2019-02-04
9158750	D4	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.8 ± 0.3	2019-02-04
9158604	D5	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	1.2 ± 0.3	2019-02-04
9158797	DAVID	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.8 ± 0.4	2019-02-04
9158716	F2	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	0.5 ± 0.3	2019-02-04
9158724	F2	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	< 0.3	2019-02-04
9175605	F2	2019-02-05 @ 3:00 am	2019-02-08 @ 1:00 am	< 0.3	2019-02-11
9158763	F3	2019-01-28 @ 8:00 pm	2019-01-31 @ 7:00 pm	0.8 ± 0.3	2019-02-04
9158730	F3 STORAGE	2019-01-28 @ 8:00 pm	2019-01-31 @ 7:00 pm	0.7 ± 0.4	2019-02-04
9158719	F4	2019-01-28 @ 8:00 pm	2019-01-31 @ 7:00 pm	0.6 ± 0.4	2019-02-04
9158779	F5	2019-01-28 @ 8:00 pm	2019-01-31 @ 7:00 pm	0.9 ± 0.4	2019-02-04
9158817	F6	2019-01-28 @ 8:00 pm	2019-01-31 @ 7:00 pm	< 0.3	2019-02-04
9158768	FINANCE	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.7 ± 0.4	2019-02-04
9158770	FOOTBALL STAFF	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.3 ± 0.3	2019-02-04
9158785	FOOTBALL STAFF 2	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.2 ± 0.3	2019-02-04
9158740	G2	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.0 ± 0.4	2019-02-04
9158744	G2	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.9 ± 0.4	2019-02-04

Radon test result report for:**Sheldon High School**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9158603	GIRLS LOCKER	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	1.0 ± 0.3	2019-02-04
9158792	GIRLS TEAM LOCKER	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.8 ± 0.3	2019-02-04
9158788	GYM	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	< 0.3	2019-02-04
9158723	GYM	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.7 ± 0.3	2019-02-04
9158777	GYM	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.0 ± 0.4	2019-02-04
9158775	GYM	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	< 0.3	2019-02-04
9158772	GYM	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.8 ± 0.3	2019-02-04
9158728	GYM	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.9 ± 0.3	2019-02-04
9158798	GYM	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.7 ± 0.4	2019-02-04
9158746	GYM CONCESSIONS	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.7 ± 0.4	2019-02-04
9158726	H OFFICE	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.9 ± 0.4	2019-02-04
9158729	H1	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.2 ± 0.4	2019-02-04
9158721	H3	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.6 ± 0.3	2019-02-04
9158731	H4	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.6 ± 0.3	2019-02-04
9158639	HEALTH CENTER	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.0 ± 0.3	2019-02-04
9158607	KENDRA	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.0 ± 0.4	2019-02-04
9158610	KITCHEN OFFICE	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.7 ± 0.4	2019-02-04
9158749	KITCHEN OFFICE	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	0.8 ± 0.3	2019-02-04
9158625	LEARNING CENTER	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.6 ± 0.4	2019-02-04
9158619	LEARNING CENTER	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.8 ± 0.4	2019-02-04
9158638	LIBRARY	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.2 ± 0.4	2019-02-04
9158629	LIBRARY	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.9 ± 0.4	2019-02-04
9158630	LIBRARY	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.2 ± 0.4	2019-02-04
9158618	LIBRARY OFFICE	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.1 ± 0.4	2019-02-04
9158767	MAIN OFFICE	2019-01-28 @ 6:00 pm	2019-01-31 @ 8:00 pm	0.9 ± 0.3	2019-02-04
9158762	MAIN OFFICE	2019-01-28 @ 6:00 pm	2019-01-31 @ 8:00 pm	1.1 ± 0.3	2019-02-04
9158613	MARK	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.2 ± 0.3	2019-02-04
9158601	MICHAEL	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.1 ± 0.3	2019-02-04
9158764	MUSIC OFFICE	2019-01-28 @ 8:00 pm	2019-01-31 @ 7:00 pm	0.9 ± 0.3	2019-02-04
9158742	MUSTACHE	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	1.1 ± 0.4	2019-02-04
9158739	NANCY	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.0 ± 0.4	2019-02-04
9158782	NANCY	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.0 ± 0.4	2019-02-04
9158628	NURSE	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.3 ± 0.4	2019-02-04
9158627	NURSE OFFICE	2019-01-28 @ 6:00 pm	2019-01-31 @ 8:00 pm	1.1 ± 0.3	2019-02-04
9158791	P1	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	< 0.3	2019-02-04
9158733	P1	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	< 0.3	2019-02-04
9158789	P2	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	< 0.3	2019-02-04

Radon test result report for:**Sheldon High School**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
9158738	P3	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	< 0.3	2019-02-04
9158735	P4	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	< 0.3	2019-02-04
9158614	PAPER STORAGE	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	1.1 ± 0.3	2019-02-04
9158769	PRINCIPAL	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.5 ± 0.4	2019-02-04
9158737	PRODUCTION	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	1.0 ± 0.4	2019-02-04
9158786	RADIO BREAK	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	< 0.3	2019-02-04
9158672	S1	2019-01-28 @ 4:00 pm	2019-01-31 @ 5:00 pm	0.5 ± 0.4	2019-02-04
9158656	S10	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.5 ± 0.4	2019-02-04
9158666	S10	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.7 ± 0.3	2019-02-04
9158677	S2	2019-01-28 @ 4:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158669	S3	2019-01-28 @ 4:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158670	S4	2019-01-28 @ 4:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.3	2019-02-04
9158673	S5	2019-01-28 @ 4:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.3	2019-02-04
9158697	S5	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.7 ± 0.4	2019-02-04
9158678	S6	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158693	S7	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.4	2019-02-04
9158667	S8	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.4	2019-02-04
9158671	S9	2019-01-28 @ 5:00 pm	2019-01-31 @ 5:00 pm	< 0.3	2019-02-04
9158732	SERVER	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	0.6 ± 0.4	2019-02-04
9158602	STAFF	2019-01-28 @ 6:00 pm	2019-01-31 @ 5:00 pm	0.6 ± 0.3	2019-02-04
9158759	STAFF CONFERENCE	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.6 ± 0.3	2019-02-04
9158722	STAGE	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	0.7 ± 0.3	2019-02-04
9158720	STAGE	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	< 0.3	2019-02-04
9158725	STU	2019-01-28 @ 7:00 pm	2019-01-31 @ 7:00 pm	0.5 ± 0.3	2019-02-04
9158783	STUDIO	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.0 ± 0.3	2019-02-04
9158734	TEAM 1	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.3 ± 0.4	2019-02-04
9158743	TEAM 2	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	1.4 ± 0.3	2019-02-04
9158608	TEXT ROOM	2019-01-28 @ 6:00 pm	2019-01-31 @ 5:00 pm	1.6 ± 0.3	2019-02-04
9158674	TEXTBOOK STORAGE	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	1.1 ± 0.4	2019-02-04
9158679	TEXTBOOK STORAGE	2019-01-28 @ 4:00 pm	2019-01-31 @ 4:00 pm	0.8 ± 0.3	2019-02-04
9158758	TRACY	2019-01-28 @ 6:00 pm	2019-01-31 @ 7:00 pm	1.4 ± 0.4	2019-02-04
9158717	WARM UP	2019-01-28 @ 8:00 pm	2019-01-31 @ 7:00 pm	0.7 ± 0.3	2019-02-04
9158776	WEIGHT ROOM	2019-01-28 @ 7:00 pm	2019-01-31 @ 6:00 pm	0.8 ± 0.3	2019-02-04
9175613	WEIGHT ROOM	2019-02-05 @ 3:00 am	2019-02-08 @ 1:00 am	< 0.3	2019-02-11
9158793	WHIRLPOOL	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	1.1 ± 0.3	2019-02-04
9158748	WRESTLING STORAGE	2019-01-28 @ 6:00 pm	2019-01-31 @ 6:00 pm	1.0 ± 0.3	2019-02-04