

Edison Elementary- Lead Water Testing 2023 (new building)		Water Test			Retest (if needed)			2nd Retest (if needed)			Resolution- Action Items
Location	Fixture Type	Date Sampled	Sample ID #	Results (parts per billion)	Date Sampled	Sample ID #	Results (parts per billion)	Date Sampled	Sample ID #	Results (parts per billion)	
Community Room 120	Sink	8/5/22	20820500-035SF	0.3							
Community Room 120	Ice Machine	8/5/22	20820500-036IM	ND							
Community Room 120	Bottle Filler	8/5/22	20820500-037OT	ND							
Room 131, Cafeteria Ramp	Fountain	8/5/22	20820500-025DW	ND							
Room 131, Cafeteria Ramp	Bottle Filler	8/5/22	20820500-027WB	ND							
Room 131, Cafeteria Ramp	Fountain	8/5/22	20820500-026DW	ND							
By Bathroom, Room 181	Fountain	8/5/22	20820500-033DW	ND							
By Bathroom, Room 181	Bottle Filler	8/5/22	20820500-034WB	ND							
By Bathroom, Room 181	Fountain	8/5/22	20820500-032DW	ND							
Staff Bathroom, Room 176	Sink	8/5/22	20820500-040SF	ND							
Staff Bathroom, Room 177	Sink	8/5/22	20820500-041SF	ND							
Kitchen, Room 178- Sprayer	Sprayer	8/5/22	20820500-050OT	0.7							
Kitchen, Room 178-Sprayer	Sprayer	8/5/22	20820500-052OT	0.3							
Kitchen, Room 178	Sink	8/5/22	20820500053KF	0.6							
Kitchen, Room 178	Ice Machine	8/5/22	20820500-049IM	0.4							
Kitchen, Room 178-Kettle Water Fixture	Kettle Fixtrue	11/9/22	20820500-054KF	ND							
Bathroom, Room 181	Sink	8/5/22	20820500-048BF	0.6							
Bathroom, Room 181	Sink	8/5/22	20820500-042BF	0.2							
Bathroom, Room 181	Sink	8/5/22	20820500-043BF	0.8							
Bathroom, Room 181	Sink	8/5/22	20820500-044BF	ND							
Bathroom, Room 181	Sink	8/5/22	20820500-045BF	0.3							
Bathroom, Room 181	Sink	8/5/22	20820500-047BF	0.3							
Hallway Hand Wash, By Kitchen	Sink	11/9/22	20820500-046OT	0.5							
Health Room, Room 110	Sink	8/5/22	20820500-029NF	0.6							
Health Room Bathroom, Room 109	Sink	8/5/22	20820500-028NF	0.2							
Main Office Bathroom, Room 112	Sink	8/5/22	20820500-030SF	ND							
Main Office, Room 114	Sink	8/5/22	20820500-031SF	ND							
Storage/Laundry, Room122	Sink	8/5/22	20820500-039SF	0.2							
Storage/Laundry, Room123	Sink	8/5/22	20820500-038SF	ND							
Bathroom, Room 131	Sink	8/5/22	20820500-056BF	0.3							
Bathroom, Room 131	Sink	8/5/22	20820500-012BF	0.3							
Bathroom, Room 131	Sink	8/5/22	20820500-011BF	0.2							
Bathroom, Room 131	Sink	8/5/22	20820500-055BF	ND							
Classroom 3, Room 145	Sink	8/5/22	20820500-024CF	0.7							
Classroom 3, Room 145	Fountain	8/5/22	20820500-023DW	0.3							
Classroom 2, Room 143	Sink	8/5/22	20820500-022CF	0.8							
Classroom 2, Room 143	Fountain	8/5/22	20820500-021DW	0.3							
Classroom 4, Room 147	Sink	8/5/22	20820500-018CF	0.8							
Classroom 4, Room 147	Fountain	8/5/22	20820500-017DW	0.4							
Classroom 1, Room 141	Sink	11/9/22	20820500-020CF	0.3							
Classroom 1, Room 141	Fountain	8/5/22	20820500-019DW	0.2							
Staff Bathroom, Room 135	Sink	8/5/22	20820500-016SF	0.3							
Bathroom, Room 134	Sink	8/5/22	20820500-013SF	ND							
Classroom 8, Room 160	Sink	11/9/22	20820500-008CF	ND							
Classroom 8, Room 160	Fountain	8/5/22	20820500-007DW	ND							
Classroom 5, Room152	Sink	8/5/22	20820500-010CF	0.6							
Classroom 5, Room152	Fountain	8/5/22	20820500-009DW	0.5							
Classroom 6, Room 154	Sink	8/5/22	20820500-004CF	0.6							
Classroom 6, Room 154	Fountain	8/5/22	20820500-003DW	0.2							
Classroom 6 Bathroom, Room 155	Sink	8/5/22	20820500-006BF	ND							
Classroom 7 Bathroom, Room 157	Sink	8/5/22	20820500-005BF	ND							
Classroom 7, Room 156	Sink	8/5/22	20820500-002CF	ND							
Classroom 7, Room 156	Fountain	8/5/22	20820500-001DW	0.6							
Bathroom, Room 131	Sink	8/5/22	20820500-015BF	0.2							
Bathroom, Room 131	Sink	8/5/22	20820500-014BF	0.4							
Bathroom, Room 211	Sink	8/5/22	20820500-114BF	0.3							
Bathroom, Room 211	Sink	8/5/22	20820500-077BF	0.3							
Bathroom, Room 211	Sink	8/5/22	20820500-078BF	0.4							
Bathroom, Room 211	Sink	8/5/22	20820500-079BF	0.2							
Bathroom, Room 211	Sink	8/5/22	20820500-080BF	0.7							
Bathroom, Room 211	Sink	8/5/22	20820500-110BF	ND							

Water test results above OHA/ EPA action level of 15.0 parts per billion (ppb) required remedial action and retest.
ND result- lead was not detected

Edison Elementary- Lead Water Testing 2023 (new building)		Water Test			Retest (if needed)			2nd Retest (if needed)			Resolution- Action Items
Location	Fixture Type	Date Sampled	Sample ID #	Results (parts per billion)	Date Sampled	Sample ID #	Results (parts per billion)	Date Sampled	Sample ID #	Results (parts per billion)	
By Bathroom, Room 211	Bottle Filler	8/5/22	20820500-113WB	ND							
By Bathroom, Room 211	Fountain	8/5/22	20820500-112DW	ND							
By Bathroom, Room 211	Fountain	8/5/22	20820500-111DW	ND							
Media Center, Room245	Sink	8/5/22	20820500-105CF	0.2							
Bathroom, Room 261	Sink	11/9/22	20820500-109BF	ND							
Bathroom, Room 261	Sink	8/5/22	20820500-090BF	0.2							
Bathroom, Room 261	Sink	8/5/22	20820500-091BF	0.7							
Bathroom, Room 261	Sink	8/5/22	20820500-092BF	0.7							
Bathroom, Room 261	Sink	8/5/22	20820500-093BF	0.7							
Bathroom, Room 261	Sink	8/5/22	20820500-104BF	0.4							
By Bathroom, Room 261	Bottle Filler	8/5/22	20820500-108WB	ND							
By Bathroom, Room 261	Fountain	8/5/22	20820500-107DW	ND							
By Bathroom, Room 261	Fountain	8/5/22	20820500-106DW	ND							
Staff Bathroom, Room 249	Sink	8/5/22	20820500-095SF	0.3							
Staff Bathroom, Room 250	Sink	8/5/22	20820500-094SF	0.8							
Classroom 21, Room 269	Sink	11/9/22	20820500-102CF	0.6							
Classroom 21, Room 269	Fountain	8/5/22	20820500-103DW	0.7							
Classroom 20, Room 267	Sink	11/9/22	20820500-100CF	0.2							
Classroom 20, Room 267	Fountain	8/5/22	20820500-101DW	0.3							
Classroom 19, Room 265	Sink	8/5/22	20820500-098CF	0.8							
Classroom 19, Room 265	Fountain	8/5/22	20820500-099DW	0.3							
Classroom 18, Room 263	Sink	11/9/22	20820500-096CF	6.2							
Classroom 18, Room 263	Fountain	8/5/22	20820500-097DW	0.4							
Music Room, Room 202	Sink	8/5/22	20820500-088CF	0.9							
Music Room, Room 202	Fountain	8/5/22	20820500-089DW	0.3							
Staff Room, Room 207	Sink	8/5/22	20820500-085SF	0.4							
Staff Room Fridge Water Dispenser-South, Room 207	Dispenser	8/5/22	20820500-084OT	ND							
Staff Room Fridge Water Dispenser-North, Room 207	Dispenser	8/5/22	20820500-082OT	ND							
Staff Room Fridge Ice Maker-South, Room 207	Ice Maker	8/5/22	20820500-083IM	0.2							
Staff Room Fridge Ice Maker-North, Room 207	Ice Maker	8/5/22	20820500-081IM	ND							
Room 242	Sink	8/5/22	20820500-086CF	0.4							
Room 242	Fountain	8/5/22	20820500-087DW	ND							
Classroom 17, Room 233	Sink	8/5/22	20820500-062CF	0.2							
Classroom 17, Room 233	Fountain	8/5/22	20820500-061DW	ND							
Classroom 16, Room 231	Sink	8/5/22	20820500-058CF	0.6							
Classroom 16, Room 231	Fountain	8/5/22	20820500-057DW	ND							
Classroom 15, Room 230	Sink	8/5/22	20820500-060CF	0.3							
Classroom 15, Room 230	Fountain	8/5/22	20820500-059DW	ND							
Classroom 14, Room 228	Sink	8/5/22	20820500-064CF	0.5							
Classroom 14, Room 228	Fountain	8/5/22	20820500-063DW	0.3							
Classroom 13, Room 227	Sink	8/5/22	20820500-066CF	0.5							
Classroom 13, Room 227	Fountain	8/5/22	20820500-065DW	0.3							
Classroom 12, Room 226	Sink	8/5/22	20820500-070CF	0.3							
Classroom 12, Room 226	Fountain	8/5/22	20820500-069DW	ND							
Classroom 11, Room 224	Sink	8/5/22	20820500-074CF	0.5							
Classroom 11, Room 224	Fountain	8/5/22	20820500-073DW	ND							
Classroom 10, Room 223	Sink	8/5/22	20820500-076CF	0.6							
Classroom 10, Room 223	Fountain	8/5/22	20820500-075DW	0.3							
Classroom 9, Room 221	Sink	8/5/22	20820500-072CF	0.5							
Classroom 9, Room 221	Fountain	8/5/22	20820500-071DW	0.3							
Staff Bathroom, Room 215	Sink	8/5/22	20820500-068SF	0.3							
Staff Bathroom, Room 214	Fountain	8/5/22	20820500-067SF	0.4							
Hallway Hand Wash, By Kitchen	Sink	11/9/22	20820500-115OT	0.3							
Hallway Hand Wash, By Kitchen	Sink	11/9/22	20820500-116OT	0.6							

Water test results above OHA/ EPA action level of 15.0 parts per billion (ppb) required remedial action and retest.
ND result- lead was not detected