

**Germantown, Central Schools**  
123 Main Street  
Germantown ,NY 12526

Printed On : 5/5/2022 Page 1 of 2  
Sample ID: **BD03233**  
Date Received: 05/04/2022  
Time Received: 10:37  
Date Finalized: 5/5/2022  
PO Number:  
Your Ref:

Customer: Germantown, Central Schools  
Owner: Germantown School  
Sample Loc: 123 Main Street, Germantown, NY 12526  
Sample Pt: Tank Room

Collect Date: 05/03/2022  
Collect Time: 09:00  
Collected by: FRANK SAVIO  
Receipt Temp: 17 C see note 1

Water Source: Drilled Well  
Chlorinated: No Field Residual Chlorine:

Potable: Yes  
Grab/Comp: grab

L a b o r a t o r y R e p o r t

Test	Result	MCL	Qualifiers	Units	Method Used	Analyst	Analysis Date
Total Coliform	Negative			per 100 mL	SM9223B	BS/BC	5/4/2022

Qualifiers Key:

X Exceeds maximum contamination limit R Duplication outside acceptance limits H Hold time exceeded  
T Temperature outside specifications A Sample contained air bubble or headspace B Analyte detected in  
blank  
C(+/-) CCV outside acceptance limits Z Analysis is not state-certified G Incorrect bottle  
received

Legend: < Less Than, > Greater Than mg/L=PPM, ug/L=PPB If no collection time was given, 00:00 is reported

MCL = Maximum Contaminant Level referenced from New York State Subpart 5-1 of the Public Drinking Water Standards and/or National Primary/Secondary Drinking Water Standards.

Note 1: Per ELAP requirements, water analyzed for alkalinity, color, conductivity, nitrate, nitrite, sulfate, organics, UV absorbance, non-potable bacteriological analyses, BOD/CBOD, solids and phosphorus are required to be on ice to indicate the chilling process has begun. Samples must be between 0-6C and not frozen.

Comments:

Sample is NEGATIVE for Total Coliform. This result indicates that the water WAS of a SATISFACTORY sanitary quality when sampled for the contaminants examined. Sample is NEGATIVE for Escherichia coli. For drinking water samples, any positive result for total coliform and/or Escherichia coli is unacceptable.  
Sample was NEGATIVE when screened for total residual chlorine in laboratory.  
Bacteriological sample was set up on 05/04/22 at 13:00.

Test procedures for all analyses meet NELAC requirements unless noted.

**Germantown, Central Schools**  
123 Main Street  
  
Germantown ,NY 12526


**Printed On :** 5/5/2022 Page 2 of 2  
**Sample ID:** **BD03233**  
*Date Received:* 05/04/2022  
*Time Received:* 10:37  
*Date Finalized:* 5/5/2022  
*PO Number:*  
*Your Ref:*

*Customer:* Germantown, Central Schools  
*Owner:* Germantown School  
*Sample Loc:* 123 Main Street,Germantown,NY 12526  
*Sample Pt:* Tank Room

*Collect Date:* 05/03/2022  
*Collect Time:* 09:00  
*Collected by:* FRANK SAVIO  
*Receipt Temp:* 17 C see note 1

*Water Source:* Drilled Well  
*Chlorinated:* No *Field Residual Chlorine:*

*Potable:* Yes  
*Grab/Comp:* grab



Brian Collins  
Lead Technical Director Environmental Laboratory  
and contact person  
If you have questions, please call.

**Reviewed by Brian Collins**  
These results relate to samples as received.

**New York State DOH E.L.A.P. # 10350**

The documents accompanying this telecopy transmission contain confidential information, belonging to the sender, that is legally privileged. This information is intended only for the use of the individual or entity named above. The authorized recipient of this information is prohibited from disclosing this information after its stated need is fulfilled. If you are not the intended recipient, you are hereby notified that any disclosure, copying, distribution or action taken in reliance on the contents of these documents is strictly prohibited. If you have received this telecopy in error, please notify the sender immediately to arrange for the return of these documents.