



GLENDALE UNIFIED SCHOOL DISTRICT

"Preparing our students for *their* future"

Facilities Planning, Development & Support Operations

349 W. Magnolia Ave., Glendale, CA 91204

Tel: 818/507-0201 - Fax: 818/507-4911

Addendum No. 1

Date: April 28, 2021
Project Name: Glenoaks ES Interim Housing – Fire Hydrant Project
Bid No.: 212-20/21

This Addendum is hereby made a part of the Contract Documents to the same extent as though it were originally included therein. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

General Information:

Receipt of Bids and Bid Opening: Sealed bids must be received at the District Office, 223 N. Jackson Street, Room 305, Glendale, CA 91206 no later than 2:00 pm on May 12, 2021. The actual bid opening will be held in the Board Room and made public through Zoom meetings – **Topic: Bid Opening - Bid # 212-20/21; Date/Time: May 12, 2021 @ 2:30 pm PT (US),**

Join Zoom Meeting

<https://us02web.zoom.us/j/85225143524?pwd=R0tDNVN5ZEImditJMUN6ZGlmTDNJdz09>

Meeting ID: 852 2514 3524

Passcode: N4iqh9

Social Distancing: The District maintains social distancing practices for all staff and visitors. When coming to the district office, please keep a distance of six (6) feet between you and others, and wear a protective mask & gloves.

Request for Information/Response:

Q: For the above mentioned project, are we just doing work for the fire hydrant line? C-2 says that there is more work to be done. Are we responsible for C-2 or is it for reference only?

A: The scope of work is only the underground Fire Hydrant scope of work and associated details. Pages C2.0 and C3.0 are for reference only and are not part of your Scope of Work. As discussed at the job walk the Contractor will be responsible for all City/GWP fees, Permits and coordination for the work outside of the District property line.

Clarifications:

1. GUSD will be contracting with GWP to tap into the water main at Eden Ave with new valve and tee as shown on the following GWP plans. Contractor is still responsible for all work from the tee in the street to the fire hydrant. Including all coordination with the City and associated inspections and fees.
2. Remove sheets C5.0 & C5.1 from the original bid set and replace with the attached revised sheets C5.0 & C5.1. – See Attachment No. 1
3. See attached Glendale Water and Power Fire Service Underground plans for clarification. – See Attachment No. 2

END OF ADDENDUM NO. 1