



Addendum No. 2

June 7, 2017

Tennis Courts Resurfacing at Crescenta Valley High School

Bid No. 154-17/18

This addendum supercedes, supplements and has precedence over all portions of the bidding documents with which it differs. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

Changes of Scope of Work

Question: Per our conversation on the job walk today, I recommend we only put down 1 resurfacer coat and two coats of color, eliminating one resurfacer coat, one color coat, and the clear sealer called out in the specifications. This will end up causing peeling because of the number of coats and the sealer, preventing the vapor to pass through the coatings. Also there is 510' of caulking to be filled with Sika Flex 2cSL.

Answer: Please proceed with this revision.

End of Addendum No. 2