



Addendum No. 2

March 16, 2018
HVAC Replacement at Hoover High School
Bid Number 161-17/18

This addendum supercedes, supplements and has precedence over all portions of the bidding documents with which it differs. Acknowledge receipt of this Addendum in the space provided on Bid Form, paragraph 9. Failure to do so may subject the Bidder to disqualification.

Changes to Specifications:

All condenser units must be York high efficiency 3 phase units. **Please disregard single phase condenser units in Addendum No. 1.**

All line-sets in total must be changed to proper unit sizing required by manufacturer (from condenser to evaporator connection).

All roofing penetration modified must be sealed by Greco certified contractor.

End of Addendum No. 2