



Addendum No. 2

March 14, 2018

HVAC Replacement at Crescenta Valley and Glendale High Schools

Bid Number 166-17/18

This addendum supercedes, supplements and has precedence over all portions of the bidding documents with which it differs. Acknowledge receipt of this Addendum in the space provided on Bid Form, paragraph 9. Failure to do so may subject the Bidder to disqualification.

Changes to Specifications:

Clarification:

Crescenta Valley High School – There are **six (6) units** to be changed, not eight (8).

End of Addendum No. 2