



Results Report

Order ID: 2E04629

Karl Environmental Group
20 Lauck Road
Mohnton, PA 19540

Project: 22-0584 Green Brook Township School District
105 Andrew St.
Green Brook, NJ 08812

Attn: Varsha Swaminathan

Regulatory ID:

Sample Number: 2E04629-01
Collector: DH

Site: FES-BLANK
Collect Date: 05/18/2022 7:14 am

Sample ID: BLANK
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 05/27/22 MKS 05/27/22 15:01 MKS

Sample Number: 2E04629-02
Collector: DH

Site: FES-KIT-REAR-01
Collect Date: 05/18/2022 6:17 am

Sample ID: KIT. R SINK - REAR WALL
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 05/27/22 MKS 05/27/22 15:26 MKS

Sample Number: 2E04629-03
Collector: DH

Site: FES-KIT-FP-02
Collect Date: 05/18/2022 6:14 am

Sample ID: KITCHEN MIDDLE SINK - FP
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 05/27/22 MKS 05/27/22 15:42 MKS

Sample Number: 2E04629-04
Collector: DH

Site: FES-BF-BOILER HALL-04
Collect Date: 05/18/2022 6:11 am

Sample ID: HALLWAY OUTSIDE BOILER ROOM
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 05/27/22 MKS 05/27/22 13:56 MKS

Sample Number: 2E04629-05
Collector: DH

Site: FES-CS-RM115-08
Collect Date: 05/18/2022 6:40 am

Sample ID: SINK BUBBLER
Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead < 1.00 µg/L EPA 200.8 1.00 1 05/27/22 MKS 05/27/22 14:40 MKS

Report Generated On: 06/03/2022 2:44 pm
STL_Results Revision #2.0

2E04629
Effective: 04/20/2022





SUBURBAN TESTING LABS

Sample Number: 2E04629-06	Site: FES-CS-RM114-09	Sample ID: SINK BUBBLER
Collector: DH	Collect Date: 05/18/2022 6:42 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/27/22	MKS	05/27/22 14:42	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2E04629-07	Site: FES-CS-RM13-10	Sample ID: SINK BUBBLER
Collector: DH	Collect Date: 05/18/2022 6:46 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/27/22	MKS	05/27/22 14:45	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2E04629-08	Site: FES-CS-RM112-11	Sample ID: SINK BUBBLER
Collector: DH	Collect Date: 05/18/2022 6:44 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/27/22	MKS	05/27/22 14:47	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2E04629-09	Site: FES-CS-RM111-12	Sample ID: SINK BUBBLER
Collector: DH	Collect Date: 05/18/2022 6:48 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/27/22	MKS	05/27/22 14:28	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2E04629-10	Site: FES-CS-RM110-13	Sample ID: SINK BUBBLER
Collector: DH	Collect Date: 05/18/2022 6:50 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/27/22	MKS	05/27/22 14:49	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2E04629-11	Site: FES-BF-RM121 HALL-16	Sample ID: HALLWAY NEAR RM 121/201
Collector: DH	Collect Date: 05/18/2022 6:35 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/27/22	MKS	05/27/22 14:52	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Report Generated On: 06/03/2022 2:44 pm 2E04629
 STL_Results Revision #2.0 Effective: 04/20/2022





Sample Number: 2E04629-12	Site: FES-CS-RM301-20	Sample ID: SINK BUBBLER
Collector: DH	Collect Date: 05/18/2022 6:54 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/27/22	MKS	05/27/22 14:54	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2E04629-13	Site: FES-FAC-MEDIA-21	Sample ID: MEDIA CENTER OFFICE
Collector: DH	Collect Date: 05/18/2022 6:29 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	7.78	µg/L	EPA 200.8	1.00	1	05/27/22	MKS	05/27/22 14:57	MKS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2E04629-14	Site: FES-TL-FACULTY-22	Sample ID: FACULTY WORK ROOM
Collector: DH	Collect Date: 05/18/2022 6:32 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/27/22	MKS	05/27/22 14:59	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2E04629-15	Site: FES-KIT-REAR-02	Sample ID: REAR SINK SIDE
Collector: DH	Collect Date: 05/18/2022 6:19 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	< 1.00	µg/L	EPA 200.8	1.00	1	05/27/22	MKS	05/27/22 13:40	MKS
------	--------	------	-----------	------	---	----------	-----	----------------	-----

Sample Number: 2E04629-16	Site: FES-KIT-FP-03	Sample ID: KIT MIDDLE WEST
Collector: DH	Collect Date: 05/18/2022 6:23 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

Metals

Lead	2.65	µg/L	EPA 200.8	1.00	1	06/02/22	MKS	06/02/22 15:13	MKS
------	------	------	-----------	------	---	----------	-----	----------------	-----

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

Units P/A = Present/Absent
Units P/F = Pass/Fail

Report Generated On: 06/03/2022 2:44 pm 2E04629
STL_Results Revision #2.0 Effective: 04/20/2022





SUBURBAN TESTING LABS

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Ryan F Knerr
Project Manager II

Report Generated On: 06/03/2022 2:44 pm 2E04629
STL_Results Revision #2.0 Effective: 04/20/2022





2E04629
Ryan F Knerr

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group
 Address: 20 Lauck Road Phone: 610-856-7700
Mohnton PA 19540 Email: dhopkins@karlenv.com
 Contact Name: David Hopkins P.O. Info: 22-0584

Project Name: 22-0584 Green Brook Township School District
 Address: Irene E. Feldkirchner Elementary School
105 Andrew St. Green Brook NJ 08812
 Regulatory ID (SDWA/Permit #): _____

Comments:

*NJ 200.8 Lead in Drinking water - FIRST DRAW

Page 1 of 4

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
(4) 250mL P+HNO3												
1	FES-BLANK	5/18/2022	714	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	BLANK	
2	FES-KIT-Rear-01	5/18/2022	617	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Kit. R Sink - Rear wall	
3	FES- KIT-FP-02	5/18/2022	614	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Kitchen-middle sink - FP East	
*	FES-KIT-IM-03	5/18/2022		DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Kitchen.Ice Machine	
4	FES-BF- Boiler Hall-04	5/18/2022	611	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Hallway outside Boiler Room	
*	FES-WC- Boiler Hall-05	5/18/2022		DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Hallway outside Boiler Room	
*	FES-BF-MDF Hall-06	5/18/2022		DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Across from MDF Room	
*	FES-WC-MDF Hall-07	5/18/2022		DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Across from MDF Room	

Relinquished By: <u>David Hopkins</u>	Count: <u>4</u>	Date: <u>5/18/22</u>	Temp °C: _____	Sample Conditions	Matrix Key	Bottle Type Key
Received By:		Time: <u>10:49 AM</u>	Temp °C: _____	Submitted with COC? <u>Y</u> / N	NPW = Non-Potable Water	P = Plastic
Relinquished By:		Date:	Temp °C: _____	Number of containers match number on COC? <u>Y</u> / N	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	PP = Sterile Polypropylene
Received in Lab By: <u>MA</u>	<u>4</u>	Time:	Acceptable: <u>Y</u> / N	All containers in tact? <u>Y</u> / N	PW = Potable Water (not for SDWA compliance)	G = Glass
		Date: <u>5/18/22</u>	Temp °C: <u>7/22</u>	Tests within holding times? <u>Y</u> / N	SDWA = Safe Drinking Water Act Potable Sample	GA = Glass Amber
		Time: <u>10:49</u>	Acceptable: <u>Y</u> / N	40 mL VOA vials free of headspace? <u>Y</u> / N	Sample Type Key	HDPE = High Density Polyethylene
					G = Grab	VOA = 40mL G or GA
					C = Composite	O = Other
					8HC = 8 Hr. Composite	Preservative Key
					24HC = 24 Hr. Composite	A = Ascorbic Acid
						OH = NaOH
						S = H ₂ SO ₄
						O = Other
						NA = None
						Required

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SFL059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.

* = Out of service



2E04629
Ryan F Knerr

TAT(Check One): Standard 24hr 48hr 72hr Other _____
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group
Address: 20 Lauck Road Phone: 610-856-7700
Mohnton PA 19540 Email: dhopkins@karlenv.com
Contact Name: David Hopkins P.O. Info: 22-0584

Project Name: 22-0584 Green Brook Township School District
Address: Irene E. Feldkirchner Elementary School
105 Andrew St. Green Brook NJ 08812
Regulatory ID (SDWA/Permit #): _____

Comments:

*NJ 200.8 Lead in Drinking water - FIRST DRAW

Page 2 of 4

5
6
7
8
9
10
**

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
	(6) 250ml P + HNO ₃											
	FES-CS-RM115-08	5/18/2022	640	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Sink Bubbler	
	FES-CS-RM114-09	5/18/2022	642	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Sink Bubbler	
	FES-CS-RM13-10	5/18/2022	646	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Sink Bubbler	
	FES-CS-RM112-11	5/18/2022	644	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Sink Bubbler	
	FES-CS-RM111-12	5/18/2022	648	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Sink Bubbler	
	FES-CS-RM110-13	5/18/2022	650	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Sink Bubbler	
	FES-BF-205 Hall-14	5/1/2022		DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Hall outside room 205	
	FES-WC-205 Hall-15	5/1/2022		DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Hall outside room 205	

Relinquished By: <u>David Hopkins</u>	Count: <u>6</u>	Date: <u>5/18/22</u>	Temp °C: _____	Sample Conditions	Matrix Key	Bottle Type Key
Received By:		Time: <u>1050AM</u>	Temp °C: _____	Submitted with COC? <u>(Y) N</u>	NPW = Non-Potable Water	P = Plastic
Relinquished By:		Date:	Temp °C: _____	Number of containers match number on COC? <u>(Y) N</u>	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	PP = Sterile Polypropylene
Received in Lab By: <u>MAW</u>	<u>6</u>	Time:	Acceptable: Y / N	All containers in tact? <u>(Y) N</u>	PW = Potable Water (not for SDWA compliance)	G = Glass
		Date: <u>5/18/22</u>	Temp °C: <u>21.28</u>	Tests within holding times? <u>(Y) N</u>	SDWA = Safe Drinking Water Act Potable Sample	GA = Glass Amber
		Time: <u>1049</u>	Acceptable: <u>(Y) N</u>	40 mL VOA vials free of headspace? <u>(Y) N</u>	Sample Type Key	HDPE = High Density Polyethylene
					G = Grab	VOA = 40mL G or GA
					C = Composite	O = Other
					8HC = 8 Hr. Composite	Preservative Key
					24HC = 24 Hr. Composite	A = Ascorbic Acid
						OH = NaOH
						C = HCl
						H = HNO ₃
						N = Sodium
						NA = None
						Thiosulfate
						Residence

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.

* = Out of service



2E04629
Ryan F Knerr

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group
 Address: 20 Lauck Road Phone: 610-856-7700
Mohnton PA 19540 Email: dhopkins@karlenv.com
 Contact Name: David Hopkins P.O. Info: 22-0584

Project Name: 22-0584 Green Brook Township School District
 Address: Irene E. Feldkirchner Elementary School
105 Andrew St. Green Brook NJ 08812
 Regulatory ID (SDWA/Permit #): _____

Comments:

*NJ 200.8 Lead in Drinking water - FIRST DRAW

Page 3 of 4

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:	
							Matrix	Sample Type	Bottle Type	Preservative		
(5) 250mL P + HN ⁰³												
	FES-BF-Rm121 Hall-16	5/18/2022	635	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H		Hallway near rm 121/201
*	FES-WC-Rm121 Hall-17	5/18/2022		DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H		Hallway near rm 121/201
*	FES-BF-Rm301 Hall-18	5/18/2022		DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H		Art Room Hallway
*	FES-WC-Rm301 Hall-19	5/18/2022		DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H		Art Room Hallway
	FES-CS-RM301-20	5/18/2022	654	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H		Sink Bubbler
	FES-FAC-media-21	5/18/2022	629	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H		Media Center Office
	FES-TL-Faculty-22	5/18/2022	632	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H		Faculty Work Room
	FES-KIT-Rear-02	5/18/22	619	DH		1						Rear sink L side

Relinquished By: <i>David Hopkins</i>	Count 5	Date: <u>5/18/22</u> Time: <u>10:51 AM</u>	Temp °C: _____	Sample Conditions Submitted with COC? <u>Y/N</u>	Matrix Key NPW = Non-Potable Water Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg) PW = Potable Water (not for SDWA compliance) SDWA = Safe Drinking Water Act Potable Sample	Bottle Type Key P = Plastic G = Glass GA = Glass Amber VOA = 40mL G or GA O = Other PP = Sterile Polypropylene PS = Sterile Polystyrene HDPE = High Density Polyethylene
Received By:		Date: _____ Time: _____	Temp °C: _____	Number of containers match number on COC? <u>Y/N</u>	Sample Type Key G = Grab C = Composite 8HC = 8 Hr. Composite 24HC = 24 Hr. Composite	SDWA Sample Types D=Distribution E=Entry Point R=Raw C=Check S=Special M=Maximum Residence
Relinquished By:		Date: _____ Time: _____	Temp °C: _____	All containers in tact? <u>Y/N</u>	Preservative Key A = Ascorbic Acid C = HCl H = HNO ₃ N = Sodium Thiosulfate OH = NaOH S = H ₂ SO ₄ O = Other NA = None Required	
Received in Lab By: <i>MW</i>	S	Date: <u>5/18/22</u> Time: <u>10:51</u>	Temp °C: <u>7/22</u>	Tests within holding times? <u>Y/N</u> 40 mL VOA vials free of headspace? <u>Y/N</u>		

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.

* = Out of service



SUBURBAN
TESTING LABS



2E04629
Ryan F Knerr

TAT(Check One): Standard 24hr 48hr 72hr Other
(Additional charges may apply for rush TAT. If not specified, standard TAT will apply)

Order ID: _____

Client Name: Karl Environmental Group
Address: 20 Lauck Road
Mohnton PA 19540
Contact Name: David Hopkins

Phone: 610-856-7700
Email: dhopkins@karlenv.com
P.O. Info: 22-0584

Project Name: Green Brook
Address: Irene E. Feldkirchner Elem. School
105 Andrew St, Green Brook NJ 08812
Regulatory ID (SDWA/Permit #): _____

Comments:

*NJ 200.8 Lead in Drinking water - FIRST DRAW

Page 4 of 4

STL Sample Number	Sample Description / Site ID:	Date Sampled	Time Sampled	Samplers Initials	Test(s) Requested:	Bottle Quantity	See Codes Below				Comments / Field Data:
							Matrix	Sample Type	Bottle Type	Preservative	
16	1) 250mL P + HNO ₃ . FES-KIT-FP-03	5/18/22	623	DH	200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	Kat middle west
					200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	
					200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	
					200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	
					200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	
					200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	
					200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	
					200.8 LEAD IN WATER NJDOE	1	PW	G	P	H	

Relinquished By: <u>David Hopkins</u>	Count: <u>1</u>	Date: <u>5/18/22</u>	Temp °C: _____	Sample Conditions	Matrix Key	Bottle Type Key
Received By: _____		Time: <u>1053AM</u>	Temp °C: _____	Submitted with COC? <u>Y/N</u>	NPW = Non-Potable Water	P = Plastic
Relinquished By: _____		Date: _____	Temp °C: _____	Number of containers match number on COC? <u>Y/N</u>	Solid = Raw Sludge, Dewatered sludge, soil, etc. (reported as mg/kg)	PP = Sterile Polypropylene
Received In Lab By: <u>mmw</u>		Time: _____	Acceptable: Y/N	All containers in tact? <u>Y/N</u>	PW = Potable Water (not for SDWA compliance)	PS = Sterile Polystyrene
		Date: <u>5/18/22</u>	Temp °C: <u>21.28</u>	Tests within holding times? <u>Y/N</u>	SDWA = Safe Drinking Water Act Potable Sample	GA = Glass Amber
		Time: <u>1053</u>	Acceptable: <u>Y/N</u>	40 mL VOA vials free of headspace? <u>Y/N</u>	Sample Type Key	HDPE = High Density Polyethylene
					G = Grab	VOA = 40mL G or GA
					C = Composite	O = Other
					8HC = 8 Hr. Composite	Preservative Key
					24HC = 24 Hr. Composite	A = Ascorbic Acid
						OH = NaOH
						C = HCl
						H = HNO ₃
						O = Other
						N = Sodium
						Thiosulfate
						NA = None
						Required

Signing this form indicates your agreement with STL's Standard Terms and Conditions unless otherwise specified in writing. SLF059 Rev. 1.5 Effective April 24, 2020. Shaded areas are for STL use only.