

ELEMENTARY SCHOOL



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Homer Central Schools

Project Name: Drinking Water Lead

Scott Cavellier
P.O. Box 500
Homer, NY 13077-0500

Project / PO Number: N/A
Received: 12/16/2020
Reported: 12/30/2020

Analytical Testing Parameters

Client Sample ID: Main Office	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:05
Lab Sample ID: J0L1279-01	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0050	0.0010	mg/L	1		12/28/20 1113	12/28/20 1220	LLW

Client Sample ID: Nurses Office Sink	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:05
Lab Sample ID: J0L1279-02	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0017	0.0010	mg/L	1		12/28/20 1113	12/28/20 1226	LLW

Client Sample ID: Room 102	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:06
Lab Sample ID: J0L1279-03	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.0010	mg/L	1		12/28/20 1113	12/28/20 1228	LLW

Client Sample ID: Nurses Office BR	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:07
Lab Sample ID: J0L1279-04	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.0010	mg/L	1		12/28/20 1113	12/28/20 1229	LLW

Microbac Laboratories, Inc.

3821 Buck Dr. | Cortland, NY 13045 | 607-753-3403 p | www.microbac.com



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Room 104	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:08
Lab Sample ID: J0L1279-05	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.0010	mg/L	1		12/28/20 1113	12/28/20 1231	LLW

Client Sample ID: Room 105	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:09
Lab Sample ID: J0L1279-06	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0245	0.0010	mg/L	1		12/28/20 1113	12/28/20 1233	LLW

Client Sample ID: Faculty Bathroom	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:09
Lab Sample ID: J0L1279-07	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.0010	mg/L	1		12/28/20 1113	12/28/20 1239	LLW

Client Sample ID: Room 107	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:09
Lab Sample ID: J0L1279-08	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.0010	mg/L	1		12/28/20 1113	12/28/20 1240	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Room 106	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:10
Lab Sample ID: J0L1279-09	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0062	0.0010	mg/L	1		12/28/20 1113	12/28/20 1242	LLW

Client Sample ID: Room 110	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:10
Lab Sample ID: J0L1279-10	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.0010	mg/L	1		12/28/20 1113	12/28/20 1244	LLW

Client Sample ID: Room 109	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:11
Lab Sample ID: J0L1279-11	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0016	0.0010	mg/L	1		12/28/20 1113	12/28/20 1246	LLW

Client Sample ID: Room 112	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:12
Lab Sample ID: J0L1279-12	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.0010	mg/L	1		12/28/20 1113	12/28/20 1249	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Room 113	
Sample Matrix: Drinking Water	
Lab Sample ID: J0L1279-13	Collected By: KN-Client
	Collection Date: 12/16/2020 7:12

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.0010	mg/L	1		12/28/20 1113	12/28/20 1251	LLW

Client Sample ID: Room 114	
Sample Matrix: Drinking Water	
Lab Sample ID: J0L1279-14	Collected By: KN-Client
	Collection Date: 12/16/2020 7:13

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.0010	mg/L	1		12/28/20 1113	12/28/20 1253	LLW

Client Sample ID: Kitchen Prep Sink	
Sample Matrix: Drinking Water	
Lab Sample ID: J0L1279-15	Collected By: KN-Client
	Collection Date: 12/16/2020 7:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0015	0.0010	mg/L	1		12/28/20 1113	12/28/20 1255	LLW

Client Sample ID: Handwash Sink Washroom	
Sample Matrix: Drinking Water	
Lab Sample ID: J0L1279-16	Collected By: KN-Client
	Collection Date: 12/16/2020 7:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0146	0.0010	mg/L	1		12/28/20 1113	12/28/20 1300	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Dishwash Sink Left	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-17	Collection Date: 12/16/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0050	0.0020	mg/L	2	D	12/28/20 1113	12/29/20 1050	LLW

Client Sample ID: Handwash Main Room	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-18	Collection Date: 12/16/2020 7:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0119	0.0010	mg/L	1		12/28/20 1113	12/28/20 1304	LLW

Client Sample ID: Ice Machine	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-19	Collection Date: 12/16/2020 7:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0010	mg/L	1		12/28/20 1113	12/28/20 1306	LLW

Client Sample ID: Faculty BR @ 114	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-20	Collection Date: 12/16/2020 7:18

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.0010	mg/L	1		12/28/20 1113	12/28/20 1308	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Bottle Filler @ Cafe	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:19
Lab Sample ID: J0L1279-21	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0010	mg/L	1		12/28/20 1115	12/28/20 1317	LLW

Client Sample ID: Boys Cafe BR Right	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:19
Lab Sample ID: J0L1279-22	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0063	0.0010	mg/L	1		12/28/20 1115	12/28/20 1322	LLW

Client Sample ID: Boys Cafe BR Center	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:19
Lab Sample ID: J0L1279-23	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.0010	mg/L	1		12/28/20 1115	12/28/20 1324	LLW

Client Sample ID: Boys Cafe BR Left	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:19
Lab Sample ID: J0L1279-24	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0022	0.0020	mg/L	2	D	12/28/20 1115	12/29/20 1054	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Girls Cafe BR Left	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-25	Collection Date: 12/16/2020 7:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0051	0.0051	mg/L	5	D	12/28/20 1115	12/29/20 1109	LLW

Client Sample ID: Girls Cafe BR Center	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-26	Collection Date: 12/16/2020 7:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.0010	mg/L	1		12/28/20 1115	12/28/20 1330	LLW

Client Sample ID: Girls Cafe BR Right	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-27	Collection Date: 12/16/2020 7:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.0020	mg/L	2	D	12/28/20 1115	12/29/20 1112	LLW

Client Sample ID: Cafe Gang Sink Left	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-28	Collection Date: 12/16/2020 7:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0048	0.0010	mg/L	1		12/28/20 1115	12/28/20 1337	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Cafe Gang Sink Left Center	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:21
Lab Sample ID: J0L1279-29	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0034	0.0010	mg/L	1		12/28/20 1115	12/28/20 1339	LLW

Client Sample ID: Cafe Gang Sink Right Center	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:21
Lab Sample ID: J0L1279-30	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.0010	mg/L	1		12/28/20 1115	12/28/20 1341	LLW

Client Sample ID: Cafe Gang Sink Right	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:21
Lab Sample ID: J0L1279-31	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.0010	mg/L	1		12/28/20 1115	12/28/20 1343	LLW

Client Sample ID: Bottle Filler @ Rm 131	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:23
Lab Sample ID: J0L1279-32	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.0010	mg/L	1		12/28/20 1115	12/28/20 1346	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Staff BR @ 131		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:23
Lab Sample ID: J0L1279-33		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0153	0.0010	mg/L	1		12/28/20 1115	12/28/20 1348	LLW

Client Sample ID: Room 127		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:24
Lab Sample ID: J0L1279-34		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0052	0.0010	mg/L	1		12/28/20 1115	12/28/20 1350	LLW

Client Sample ID: Room 125		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:24
Lab Sample ID: J0L1279-35		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0264	0.0010	mg/L	1		12/28/20 1115	12/28/20 1352	LLW

Client Sample ID: Girls Left @ 125		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:25
Lab Sample ID: J0L1279-36		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0069	0.0051	mg/L	5	D	12/28/20 1115	12/29/20 1121	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Girls Right @ 125	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-37	Collection Date: 12/16/2020 7:26

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0049	0.0010	mg/L	1		12/28/20 1115	12/28/20 1359	LLW

Client Sample ID: Boys Left @ 125	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-38	Collection Date: 12/16/2020 7:27

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.0010	mg/L	1		12/28/20 1115	12/28/20 1401	LLW

Client Sample ID: Room 124	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-39	Collection Date: 12/16/2020 7:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.0010	mg/L	1		12/28/20 1115	12/28/20 1403	LLW

Client Sample ID: Room 126	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: J0L1279-40	Collection Date: 12/16/2020 7:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0118	0.0010	mg/L	1		12/28/20 1115	12/28/20 1405	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Boys Right @ 125	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:28
Lab Sample ID: J0L1279-41	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.0010	mg/L	1		12/28/20 1116	12/28/20 1434	LLW

Client Sample ID: Room 123 Sink	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:28
Lab Sample ID: J0L1279-42	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0044	0.0010	mg/L	1		12/28/20 1116	12/28/20 1439	LLW

Client Sample ID: Room 123 Bathroom	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:28
Lab Sample ID: J0L1279-43	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.0010	mg/L	1		12/28/20 1116	12/28/20 1441	LLW

Client Sample ID: Room 121	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:29
Lab Sample ID: J0L1279-44	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0073	0.0010	mg/L	1		12/28/20 1116	12/28/20 1443	LLW



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS
 JOL1279

Client Sample ID: Gym Office Slnk	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:29
Lab Sample ID: JOL1279-45	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0061	0.0010	mg/L	1		12/28/20 1116	12/28/20 1445	LLW

Client Sample ID: Girls Left @234	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:34
Lab Sample ID: JOL1279-46	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0050	0.0010	mg/L	1		12/28/20 1116	12/28/20 1447	LLW

Client Sample ID: Girls Center @ 234	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:34
Lab Sample ID: JOL1279-47	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.0010	mg/L	1		12/28/20 1116	12/28/20 1452	LLW

Client Sample ID: Girls Right @ 234	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:34
Lab Sample ID: JOL1279-48	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0061	0.0010	mg/L	1		12/28/20 1116	12/28/20 1454	LLW



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS
 JOL1279

Client Sample ID: Room 122		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:30
Lab Sample ID: JOL1279-49		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0040	0.0010	mg/L	1		12/28/20 1116	12/28/20 1456	LLW

Client Sample ID: Room 234 Bathroom		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:34
Lab Sample ID: JOL1279-50		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0020	0.0020	mg/L	2	D	12/28/20 1116	12/29/20 1159	LLW

Client Sample ID: Art Left Sink		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:35
Lab Sample ID: JOL1279-51		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0118	0.0010	mg/L	1		12/28/20 1116	12/28/20 1500	LLW

Client Sample ID: Right Boys @ 220		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:36
Lab Sample ID: JOL1279-52		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.0010	mg/L	1		12/28/20 1116	12/28/20 1503	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Art Right Sink	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:35
Lab Sample ID: J0L1279-53	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0093	0.0010	mg/L	1		12/28/20 1116	12/28/20 1505	LLW

Client Sample ID: Left Boys @ 220	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:36
Lab Sample ID: J0L1279-54	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.0010	mg/L	1		12/28/20 1116	12/28/20 1507	LLW

Client Sample ID: Room 220	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:37
Lab Sample ID: J0L1279-55	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0033	0.0010	mg/L	1		12/28/20 1116	12/28/20 1509	LLW

Client Sample ID: Room 219	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:37
Lab Sample ID: J0L1279-56	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0236	0.0010	mg/L	1		12/28/20 1116	12/28/20 1514	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

JOL1279

Client Sample ID: Room 218		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:39
Lab Sample ID: JOL1279-57		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0064	0.0010	mg/L	1		12/28/20 1116	12/28/20 1516	LLW

Client Sample ID: Room 216		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:39
Lab Sample ID: JOL1279-58		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0136	0.0010	mg/L	1		12/28/20 1116	12/28/20 1518	LLW

Client Sample ID: Room 217		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:40
Lab Sample ID: JOL1279-59		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0118	0.0010	mg/L	1		12/28/20 1116	12/28/20 1520	LLW

Client Sample ID: Room 214		Collected By: KN-Client
Sample Matrix: Drinking Water		Collection Date: 12/16/2020 7:40
Lab Sample ID: JOL1279-60		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0172	0.0010	mg/L	1		12/28/20 1116	12/28/20 1522	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

JOL1279

Client Sample ID: Room 215	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: JOL1279-61	Collection Date: 12/16/2020 7:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0091	0.0010	mg/L	1		12/28/20 1220	12/28/20 1531	LLW

Client Sample ID: Library Sink	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: JOL1279-62	Collection Date: 12/16/2020 7:43

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0052	0.0010	mg/L	1		12/28/20 1220	12/28/20 1536	LLW

Client Sample ID: Room 202	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: JOL1279-63	Collection Date: 12/16/2020 7:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0028	0.0010	mg/L	1		12/28/20 1220	12/28/20 1538	LLW

Client Sample ID: Room 203	
Sample Matrix: Drinking Water	Collected By: KN-Client
Lab Sample ID: JOL1279-64	Collection Date: 12/16/2020 7:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0056	0.0010	mg/L	1		12/28/20 1220	12/28/20 1540	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

JOL1279

Client Sample ID: Girls @ 203 Left	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:45
Lab Sample ID: JOL1279-65	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0132	0.0010	mg/L	1		12/28/20 1220	12/28/20 1542	LLW

Client Sample ID: Girls @ 203 Center	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:45
Lab Sample ID: JOL1279-66	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0048	0.0010	mg/L	1		12/28/20 1220	12/28/20 1544	LLW

Client Sample ID: Girls @ 203 Right	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:45
Lab Sample ID: JOL1279-67	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.108	0.0010	mg/L	1		12/28/20 1220	12/28/20 1549	LLW

Client Sample ID: Boys @ 213 Left	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:46
Lab Sample ID: JOL1279-68	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0107	0.0010	mg/L	1		12/28/20 1220	12/28/20 1551	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Boys @ 213 Center	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:46
Lab Sample ID: J0L1279-69	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0094	0.0010	mg/L	1		12/28/20 1220	12/28/20 1553	LLW

Client Sample ID: Boys @ 213 Right	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:46
Lab Sample ID: J0L1279-70	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0088	0.0010	mg/L	1		12/28/20 1220	12/28/20 1555	LLW

Client Sample ID: Room 208	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:47
Lab Sample ID: J0L1279-71	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0129	0.0010	mg/L	1		12/28/20 1220	12/28/20 1556	LLW

Client Sample ID: Room 207	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:48
Lab Sample ID: J0L1279-72	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0036	0.0010	mg/L	1		12/28/20 1220	12/28/20 1600	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

JOL1279

Client Sample ID: Room 206	
Sample Matrix: Drinking Water	
Lab Sample ID: JOL1279-73	Collected By: KN-Client
	Collection Date: 12/16/2020 7:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.0010	mg/L	1		12/28/20 1220	12/28/20 1602	LLW

Client Sample ID: Room 205	
Sample Matrix: Drinking Water	
Lab Sample ID: JOL1279-74	Collected By: KN-Client
	Collection Date: 12/16/2020 7:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0027	0.0010	mg/L	1		12/28/20 1220	12/28/20 1604	LLW

Client Sample ID: Room 204	
Sample Matrix: Drinking Water	
Lab Sample ID: JOL1279-75	Collected By: KN-Client
	Collection Date: 12/16/2020 7:49

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0018	0.0010	mg/L	1		12/28/20 1220	12/28/20 1606	LLW

Client Sample ID: Room 209	
Sample Matrix: Drinking Water	
Lab Sample ID: JOL1279-76	Collected By: KN-Client
	Collection Date: 12/16/2020 7:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0073	0.0010	mg/L	1		12/28/20 1220	12/28/20 1611	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Room 210	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:50
Lab Sample ID: J0L1279-77	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0102	0.0102	mg/L	10	D	12/28/20 1220	12/29/20 1342	LLW

Client Sample ID: Room 211	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:51
Lab Sample ID: J0L1279-78	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0103	0.0010	mg/L	1		12/28/20 1220	12/28/20 1615	LLW

Client Sample ID: Room 212	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:51
Lab Sample ID: J0L1279-79	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.0010	mg/L	1		12/28/20 1220	12/28/20 1617	LLW

Client Sample ID: Girls Left @ 303	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:51
Lab Sample ID: J0L1279-80	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0042	0.0010	mg/L	1		12/28/20 1220	12/28/20 1618	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Girls Right @ 303	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:55
Lab Sample ID: J0L1279-81	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0051	0.0010	mg/L	1		12/28/20 1549	12/28/20 2122	LLW

Client Sample ID: Room 303	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:55
Lab Sample ID: J0L1279-82	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0140	0.0010	mg/L	1		12/28/20 1549	12/28/20 2128	LLW

Client Sample ID: Room 305	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:55
Lab Sample ID: J0L1279-83	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0118	0.0010	mg/L	1		12/28/20 1549	12/28/20 2130	LLW

Client Sample ID: Boys Left @ 306	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:56
Lab Sample ID: J0L1279-84	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0051	0.0051	mg/L	5	D	12/28/20 1549	12/29/20 1353	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Boys Right @ 306	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:56
Lab Sample ID: J0L1279-85	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.0010	mg/L	1		12/28/20 1549	12/28/20 2134	LLW

Client Sample ID: Room 307	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:56
Lab Sample ID: J0L1279-86	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0099	0.0010	mg/L	1		12/28/20 1549	12/28/20 2136	LLW

Client Sample ID: Room 308	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:57
Lab Sample ID: J0L1279-87	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0024	0.0010	mg/L	1		12/28/20 1549	12/28/20 2142	LLW

Client Sample ID: Office 306	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:57
Lab Sample ID: J0L1279-88	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0076	0.0010	mg/L	1		12/28/20 1549	12/28/20 2144	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0L1279

Client Sample ID: Room 309	Collected By: KN-Client
Sample Matrix: Drinking Water	Collection Date: 12/16/2020 7:58
Lab Sample ID: J0L1279-90	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	RL	Units	DF	Note	Prepared	Analyzed	Analyst
EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0066	0.0010	mg/L	1		12/28/20 1549	12/28/20 2146	LLW

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville
11549

New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <<https://www.microbac.com/standard-terms-conditions>>.

Reviewed and Approved By:

Shannon Weeks
Customer Relationship Coordinator
Reported: 12/30/2020 21:06

Microbac Laboratories, Inc.