



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

July 08, 2022

Jodi O'Mara
Mapleton School District
10868 E Mapleton Road
Mapleton, OR 97453
TEL: (541) 268-4312
FAX

RE:

Order No.: 2206728

Dear Jodi O'Mara:

Analytical Laboratory Group received 50 sample(s) on 6/17/2022 for the analyses presented in the following report.

Kimberly Reeve Morghan
Quality Manager
361 West 5th Ave
Eugene, OR 97401



ALG ORELAP ID #OR100012
361 West 5th Ave
Eugene, OR 97401
TEL: (541) 485-8404 FAX: (541) 484-5995
Website:

Case Narrative

WO#: 2206728
Date: 7/8/2022

CLIENT: Mapleton School District

Project:

This report presents the results of the analyses of the sample(s) received on the date above and assigned the listed Analytical Laboratory Group Analytical Report numbers. Test results relate only to the parameters tested and to the samples as received by the laboratory.

This report shall not be reproduced, except in full, without written consent of Analytical Laboratory Group, Inc.

ALG recommends that Public Water Systems monitor the Oregon OHA website (www.yourwater.oregon.gov) to verify that all expected compliance testing results have been entered.

All analyses were performed according to the Analytical Laboratory Group, Inc. Quality Assurance Program. All QA/QC requirements were met and test results meet all requirements of TNI except as noted below.

Analytical comments are noted with data flags on the reports and/or below.

Original



WO#: 2206728
CLIENT: Mapleton School District
Project:
PWS Number:
Sample Source:

Received Date: 6/17/2022 10:16:00 AM
Sampler Name: Randy Duval
Matrix: Drinking Water
Sample Type:

Lab ID: 2206728-001 **Client Sample ID** 20850300001CF22A **Collection Date:** 6/15/2022 6:59:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	21.5	15.0	4.00	*	ppb	6/20/2022 9:00:00 PM	AS

Lab ID: 2206728-002 **Client Sample ID** 20850300002CF22A **Collection Date:** 6/15/2022 7:02:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.70	15.0	2.00		ppb	6/20/2022 9:00:00 PM	AS

Lab ID: 2206728-003 **Client Sample ID** 20850300003CF22A **Collection Date:** 6/15/2022 7:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	46.8	15.0	8.00	*	ppb	6/20/2022 9:00:00 PM	AS

Lab ID: 2206728-004 **Client Sample ID** 20850300004CF22A **Collection Date:** 6/15/2022 7:06:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 1:33:00 PM	KG

Lab ID: 2206728-005 **Client Sample ID** 20850300005BF22A **Collection Date:** 6/15/2022 7:09:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2,710	15.0	400	*	ppb	6/22/2022 4:00:00 PM	AS

Lab ID: 2206728-006 **Client Sample ID** 20850300006BF22A **Collection Date:** 6/15/2022 7:11:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.27	15.0	2.00		ppb	6/27/2022 1:33:00 PM	KG

Lab ID: 2206728-007 **Client Sample ID** 20850200010BF22A **Collection Date:** 6/15/2022 7:15:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 1:33:00 PM	KG

Lab ID: 2206728-008 **Client Sample ID** 20850200011BF22A **Collection Date:** 6/15/2022 7:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 1:33:00 PM	KG

Qualifiers:

* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
C Value is below Minimum Compound Limit.	E Value above quantitation range
H Holding times for preparation or analysis exceeded	LOD Limit of Detection
MCL Maximum Contaminant Level	NAR See note in Case Narrative
ND Not Detected at the Reporting Limit	PL Permit Limit

WO#: 2206728
CLIENT: Mapleton School District
Project:
PWS Number:
Sample Source:

Received Date: 6/17/2022 10:16:00 AM
Sampler Name: Randy Duval
Matrix: Drinking Water
Sample Type:

Lab ID: 2206728-009 **Client Sample ID** 20850200012CF22A **Collection Date:** 6/15/2022 7:19:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 1:33:00 PM	KG

Lab ID: 2206728-010 **Client Sample ID** 20850200013DW22A **Collection Date:** 6/15/2022 7:22:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	17.4	15.0	2.00	*	ppb	6/27/2022 1:33:00 PM	KG

Lab ID: 2206728-011 **Client Sample ID** 20850200014BF22A **Collection Date:** 6/15/2022 7:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 1:33:00 PM	KG

Lab ID: 2206728-012 **Client Sample ID** 20850200015BF22A **Collection Date:** 6/15/2022 7:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 1:33:00 PM	KG

Lab ID: 2206728-013 **Client Sample ID** 20850200016BF22A **Collection Date:** 6/15/2022 7:36:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 5:05:00 PM	KG

Lab ID: 2206728-014 **Client Sample ID** 20850200017BF22A **Collection Date:** 6/15/2022 7:39:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 5:05:00 PM	KG

Lab ID: 2206728-015 **Client Sample ID** 20850200018BF22A **Collection Date:** 6/15/2022 7:39:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 5:05:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit



WO#: 2206728
CLIENT: Mapleton School District
Project:
PWS Number:
Sample Source:

Received Date: 6/17/2022 10:16:00 AM
Sampler Name: Randy Duval
Matrix: Drinking Water
Sample Type:

Lab ID: 2206728-016 **Client Sample ID** 20850200019BF22A **Collection Date:** 6/15/2022 7:39:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 5:05:00 PM	KG

Lab ID: 2206728-017 **Client Sample ID** 20850200020DW22A **Collection Date:** 6/15/2022 7:43:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 5:05:00 PM	KG

Lab ID: 2206728-018 **Client Sample ID** 20850200021DW22A **Collection Date:** 6/15/2022 7:43:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 5:05:00 PM	KG

Lab ID: 2206728-019 **Client Sample ID** 20850200022WB22A **Collection Date:** 6/15/2022 7:43:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 5:05:00 PM	KG

Lab ID: 2206728-020 **Client Sample ID** 20850200023BF22A **Collection Date:** 6/15/2022 7:44:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 5:05:00 PM	KG

Lab ID: 2206728-021 **Client Sample ID** 20850200024KF22A **Collection Date:** 6/15/2022 7:49:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	6/27/2022 5:05:00 PM	KG

Lab ID: 2206728-022 **Client Sample ID** 20850200025KF22A **Collection Date:** 6/15/2022 7:49:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.59	15.0	2.00		ppb	6/27/2022 5:05:00 PM	KG

Lab ID: 2206728-023 **Client Sample ID** 20850200026CF22A **Collection Date:** 6/15/2022 7:53:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit

WO#: 2206728
CLIENT: Mapleton School District
Project:
PWS Number:
Sample Source:

Received Date: 6/17/2022 10:16:00 AM
Sampler Name: Randy Duval
Matrix: Drinking Water
Sample Type:

Lab ID: 2206728-024 **Client Sample ID** 20850200027BF22A **Collection Date:** 6/15/2022 7:55:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-025 **Client Sample ID** 20850200028CF22A **Collection Date:** 6/15/2022 7:57:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-026 **Client Sample ID** 20850200029CF22A **Collection Date:** 6/15/2022 7:57:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-027 **Client Sample ID** 20850200030CF22A **Collection Date:** 6/15/2022 7:57:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-028 **Client Sample ID** 20850200031BF22A **Collection Date:** 6/15/2022 8:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-029 **Client Sample ID** 20850200032BF22A **Collection Date:** 6/15/2022 8:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.40	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-030 **Client Sample ID** 20850200033BF22A **Collection Date:** 6/15/2022 8:00:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit



WO#: 2206728
CLIENT: Mapleton School District
Project:
PWS Number:
Sample Source:

Received Date: 6/17/2022 10:16:00 AM
Sampler Name: Randy Duval
Matrix: Drinking Water
Sample Type:

Lab ID:	Client Sample ID						Collection Date:	
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2206728-031	20850200034BF22A						6/15/2022 8:06:00 AM	
Lead	SM 3113 B	4.32	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID:	Client Sample ID						Collection Date:	
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2206728-032	20850200035BF22A						6/15/2022 8:06:00 AM	
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID:	Client Sample ID						Collection Date:	
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2206728-033	20850200036BF22A						6/15/2022 8:06:00 AM	
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID:	Client Sample ID						Collection Date:	
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2206728-034	20850200037CF22A						6/15/2022 8:13:00 AM	
Lead	SM 3113 B	3.99	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID:	Client Sample ID						Collection Date:	
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2206728-035	20850200038CF22A						6/15/2022 8:13:00 AM	
Lead	SM 3113 B	6.21	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID:	Client Sample ID						Collection Date:	
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2206728-036	20850200039CF22A						6/15/2022 8:13:00 AM	
Lead	SM 3113 B	16.6	15.0	2.00	*	ppb	7/7/2022 12:20:00 PM	KG

Lab ID:	Client Sample ID						Collection Date:	
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2206728-037	20850200040DW22A						6/15/2022 8:18:00 AM	
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID:	Client Sample ID						Collection Date:	
Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
2206728-038	20850200041DW22A						6/15/2022 8:18:00 AM	
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Qualifiers:

- * Value exceeds Maximum Contaminant Level (MCL)
- C Value is below Minimum Compound Limit.
- H Holding times for preparation or analysis exceeded
- MCL Maximum Contaminant Level
- ND Not Detected at the Reporting Limit
- A Accredited by ORELAP
- E Value above quantitation range
- LOD Limit of Detection
- NAR See note in Case Narrative
- PL Permit Limit

WO#: 2206728
CLIENT: Mapleton School District
Project:
PWS Number:
Sample Source:

Received Date: 6/17/2022 10:16:00 AM
Sampler Name: Randy Duval
Matrix: Drinking Water
Sample Type:

Lab ID: 2206728-039 **Client Sample ID** 20850200042WB22A **Collection Date:** 6/15/2022 8:18:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-040 **Client Sample ID** 20850100050DW22A **Collection Date:** 6/15/2022 8:55:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-041 **Client Sample ID** 20850100051CF22A **Collection Date:** 6/15/2022 8:55:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-042 **Client Sample ID** 20850100052BF22A **Collection Date:** 6/15/2022 8:55:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-043 **Client Sample ID** 20850100053DW22A **Collection Date:** 6/15/2022 8:59:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-044 **Client Sample ID** 20850100054CF22A **Collection Date:** 6/15/2022 8:59:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-045 **Client Sample ID** 20850100055BF22A **Collection Date:** 6/15/2022 8:59:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Analytical Report

Date Reported: 7/8/2022

WO#: 2206728
CLIENT: Mapleton School District
Project:
PWS Number:
Sample Source:

Received Date: 6/17/2022 10:16:00 AM
Sampler Name: Randy Duval
Matrix: Drinking Water
Sample Type:

Lab ID: 2206728-046 **Client Sample ID** 20850100056DW22A **Collection Date:** 6/15/2022 9:03:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-047 **Client Sample ID** 20850100057CF22A **Collection Date:** 6/15/2022 9:03:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-048 **Client Sample ID** 20850100058BF22A **Collection Date:** 6/15/2022 9:03:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-049 **Client Sample ID** 20850100059DW22A **Collection Date:** 6/15/2022 9:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	ND	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Lab ID: 2206728-050 **Client Sample ID** 20850100060CF22A **Collection Date:** 6/15/2022 9:05:00 AM

Analyses	Method	Result	MCL	PQL	Qual	Units	Date Analyzed	Analyst
Lead	SM 3113 B	2.34	15.0	2.00		ppb	7/7/2022 12:20:00 PM	KG

Qualifiers:	* Value exceeds Maximum Contaminant Level (MCL)	A Accredited by ORELAP
	C Value is below Minimum Compound Limit.	E Value above quantitation range
	H Holding times for preparation or analysis exceeded	LOD Limit of Detection
	MCL Maximum Contaminant Level	NAR See note in Case Narrative
	ND Not Detected at the Reporting Limit	PL Permit Limit



Delivering more than
just test results

ALG ORELAP ID #OR100012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Definition Base

WO#: 2206728

Date: 7/8/2022

Definitions:

Qualifiers:

*	Value exceeds Maximum Contaminant Level (MCL)
A	Accredited by ORELAP
C	Value is below Minimum Compound Limit.
E	Value above quantitation range
H	Holding times for preparation or analysis exceeded
LOD	Limit of Detection
MCL	Maximum Contaminant Level
NAR	See note in Case Narrative
ND	Not Detected at the Reporting Limit
PL	Permit Limit
PQL	Practical Quantitation Level or Reporting Limit
R	RPD outside accepted recovery limits
U	Samples with CalcVal < MDL
W	Sample container temperature was outside of the limits as specified by the method.

Original



Delivering more than
just test results

ALG ORELAP ID #ORI00012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2206728

08-Jul-22

Client: Mapleton School District

Project:

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2206728-001A	20850300001CF22 A	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2206728-002A	20850300002CF22 A			Lead	A
	2206728-003A	20850300003CF22 A			Lead	A
	2206728-004A	20850300004CF22 A			Lead	A
	2206728-005A	20850300005BF22 A			Lead	A
	2206728-006A	20850300006BF22 A			Lead	A
	2206728-007A	20850200010BF22 A			Lead	A
	2206728-008A	20850200011BF22 A			Lead	A
	2206728-009A	20850200012CF22 A			Lead	A
	2206728-010A	20850200013DW2 2A			Lead	A
	2206728-011A	20850200014BF22 A			Lead	A
	2206728-012A	20850200015BF22 A			Lead	A
	2206728-013A	20850200016BF22 A			Lead	A
	2206728-014A	20850200017BF22 A			Lead	A
	2206728-015A	20850200018BF22 A			Lead	A
	2206728-016A	20850200019BF22 A			Lead	A
	2206728-017A	20850200020DW2 2A			Lead	A
	2206728-018A	20850200021DW2 2A			Lead	A
	2206728-019A	20850200022WB2 2A			Lead	A
	2206728-020A	20850200023BF22 A			Lead	A

ORELAP A Accredited

ACCRED

Version #2206728# v2

Page 11 of 18



Delivering more than
just test results

ALG ORELAP ID #ORI00012

361 West 5th Ave

Eugene, OR 97401

TEL: (541) 485-8404 FAX: (541) 484-5995

Website:

Accreditation Program Analytes Report

WO#: 2206728

08-Jul-22

Client: Mapleton School District

Project:

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2206728-021A	20850200024KF22 A	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2206728-022A	20850200025KF22 A			Lead	A
	2206728-023A	20850200026CF22 A			Lead	A
	2206728-024A	20850200027BF22 A			Lead	A
	2206728-025A	20850200028CF22 A			Lead	A
	2206728-026A	20850200029CF22 A			Lead	A
	2206728-027A	20850200030CF22 A			Lead	A
	2206728-028A	20850200031BF22 A			Lead	A
	2206728-029A	20850200032BF22 A			Lead	A
	2206728-030A	20850200033BF22 A			Lead	A
	2206728-031A	20850200034BF22 A			Lead	A
	2206728-032A	20850200035BF22 A			Lead	A
	2206728-033A	20850200036BF22 A			Lead	A
	2206728-034A	20850200037CF22 A			Lead	A
	2206728-035A	20850200038CF22 A			Lead	A
	2206728-036A	20850200039CF22 A			Lead	A
	2206728-037A	20850200040DW2 2A			Lead	A
	2206728-038A	20850200041DW2 2A			Lead	A
	2206728-039A	20850200042WB2 2A			Lead	A
	2206728-040A	20850100050DW2 2A			Lead	A

ORELAP A Accredited

ACCREDITED

Version #2206728# v2

Page 12 of 18



ALG ORELAP ID #OR100012
 361 West 5th Ave
 Eugene, OR 97401
 TEL: (541) 485-8404 FAX: (541) 484-5995
 Website:

Accreditation Program Analytes Report

WO#: 2206728
 08-Jul-22

Client: Mapleton School District

Project:

Program Name	Sample ID	ClientSampleID	Matrix	Test Name	Analyte	Status
ORELAP	2206728-041A	20850100051CF22 A	Drinking Water	AA Metals by SM 3113 Schools 250mL	Lead	A
	2206728-042A	20850100052BF22 A			Lead	A
	2206728-043A	20850100053DW2 2A			Lead	A
	2206728-044A	20850100054CF22 A			Lead	A
	2206728-045A	20850100055BF22 A			Lead	A
	2206728-046A	20850100056DW2 2A			Lead	A
	2206728-047A	20850100057CF22 A			Lead	A
	2206728-048A	20850100058BF22 A			Lead	A
	2206728-049A	20850100059DW2 2A			Lead	A
	2206728-050A	20850100060CF22 A			Lead	A

ORELAP A Accredited

ACCRED

Version #2206728# v2

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com

Lins & MT checked & AE



Delivering more than just test results

CHAIN OF CUSTODY

Attention: Jodi O'Mara	Client: Mapleton School District
Phone: 541-268-4312	Address: 10868 E Mapleton Road
Email: jomara@mapleton.k12.or.us	City, State, Zip: Mapleton, OR 97453
Client Project:	Sampler: Print <i>Randy Duval *</i>
Sampler: Signature	

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20850300001CF22A	DW/Grab	6-15-22	6:59	Lead	P	1		N/A	001A
20850300002CF22A	DW/Grab	6-15-22	7:02	Lead	P	1			002A
20850300003CF22A	DW/Grab	6-15-22	7:05	Lead	P	1			003A
20850300004CF22A	DW/Grab	6-15-22	7:06	Lead	P	1			004A
20850300005BF22A	DW/Grab	6-15-22	7:09	Lead	P	1			005A
20850300006BF22A	DW/Grab	6-15-22	7:11	Lead	P	1			006A
20850200010BF22A	DW/Grab	6-15-22	7:15	Lead	P	1			007A
20850200011BF22A	DW/Grab	6-15-22	7:18	Lead	P	1			008A
20850200012CF22A	DW/Grab	6-15-22	7:19	Lead	P	1			009A
20850200013DW22A	DW/Grab	6-15-22	7:22	Lead	P	1			010A

Notes:
** Per Jodi O'Mara AE 6/20/22*

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <i>Carly</i>	Refrigerated: <i>No Ice</i>
--	-------------------------------------	---------------------------------------

Relinquished by: <i>Carly Duval</i>	Date	Time	Received by:	Date	Time
	6/17/22	10:16am			
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by Laboratory:	Date	Time
			<i>[Signature]</i>	6/17/22	10:16

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

Linsie MT checked: AE

CHAIN OF CUSTODY

Attention: Jodi O'Mara	Client: Mapleton School District
Phone: 541-268-4312	Address: 10868 E Mapleton Road
Email: jomara@mapleton.k12.or.us	City, State, Zip: Mapleton, OR 97453
Client Project:	Sampler: Print <i>Randy Duval*</i> Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection Date		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20850200014BF22A	DW/Grab	7:36	6-15-22	Lead	P	1		N/A	011A 011A
20850200015BF22A	DW/Grab	7:36	6-15-22	Lead	P	1			012A
20850200016BF22A	DW/Grab	7:36	6-15-22	Lead	P	1			013A
20850200017BF22A	DW/Grab	7:39	6-15-22	Lead	P	1			014A
20850200018BF22A	DW/Grab	7:39	6-15-22	Lead	P	1			015A
20850200019BF22A	DW/Grab	7:39	6-15-22	Lead	P	1			016A
20850200020DW22A	DW/Grab	743	6-15-22	Lead	P	1			017A
20850200021DW22A	DW/Grab	743	6-15-22	Lead	P	1			018A
20850200022WB22A	DW/Grab	743	6-15-22	Lead	P	1			019A
20850200023BF22A	DW/Grab	744	6-15-22	Lead	P	1			020A

Notes: *Carly only signed 1st page of COC's, mt 6/17/22
 ** Corrections made by client, mt 6/17/22
 * Per Jodi O'Mara AE 6/20/22

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <i>Carly</i>	Refrigerated <i>N/A</i>
---	------------------------------	----------------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: <i>Carly Duval</i>	Date <i>6/17/22</i>	Time <i>10:16</i>	Received by Laboratory: <i>[Signature]</i>	Date <i>6/17/22</i>	Time <i>10:16</i>

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

Lims & MT checked by AE

CHAIN OF CUSTODY

Attention: Jodi O'Mara	Client: Mapleton School District
Phone: 541-268-4312	Address: 10868 E Mapleton Road
Email: jomara@mapleton.k12.or.us	City, State, Zip: Mapleton, OR 97453
Client Project:	Sampler: Print Randy Duval*
	Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles - Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20850200024KF22A	DW/Grab	6/15/22	7:49	Lead	P	1		N/A	021A
20850200025KF22A	DW/Grab	6/15/22	7:49	Lead	P	1			022A
20850200026CF22A	DW/Grab	6/15/22	7:53	Lead	P	1			023A
20850200027BF22A	DW/Grab	6/15/22	7:55	Lead	P	1			024A
20850200028CF22A	DW/Grab	6/15/22	7:57	Lead	P	1			025A
20850200029CF22A	DW/Grab	6/15/22	7:57	Lead	P	1			026A
20850200030CF22A	DW/Grab	6/15/22	7:57	Lead	P	1			027A
20850200031BE22A	DW/Grab	6-15-22	8:00	Lead	P	1			028A
20850200032BF22A	DW/Grab	6-15-22	8:00	Lead	P	1			029A
20850200033BE22A	DW/Grab	6-15-22	8:00	Lead	P	1			030A

Notes: * Carly only signed 1st page of COC's per 6/17/22
 ** Corrections made by client per 6/17/22
 * Per Jodi O'Mara AE 6/20/22

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: Carly	Refrigerated N/A
---	-----------------------	---------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: Carly Duval	Date 6/17/22	Time 10:16	Received by Laboratory: <i>[Signature]</i>	Date 6/17/22	Time 10:16

Lims: MT checked: AE

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

CHAIN OF CUSTODY

Attention: Jodi O'Mara	Client: Mapleton School District
Phone: 541-268-4312	Address: 10868 E Mapleton Road
Email: jomara@mapleton.k12.or.us	City, State, Zip: Mapleton, OR 97453
Client Project:	Sampler: Print Randy Duval*
	Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20850200034BF22A	DW/Grab	6-15-22	8:06	Lead	P	1		N/A	031A
20850200035BF22A	DW/Grab	6-15-22	8:06	Lead	P	1			032A
20850200036BF22A	DW/Grab	6-15-22	8:06	Lead	P	1			033A
20850200037CF22A	DW/Grab	6-15-22	8:13	Lead	P	1			034A
20850200038CF22A	DW/Grab	6-15-22	8:13	Lead	P	1			035A
20850200039CF22A	DW/Grab	6-15-22	8:13	Lead	P	1			036A
20850200040DW22A	DW/Grab	6-15-22	8:18	Lead	P	1			037A
20850200041DW22A	DW/Grab	6-15-22	8:18	Lead	P	1			038A
20850200042WB22A	DW/Grab	6-15-22	8:18	Lead	P	1			039A
20850100050DW22A	DW/Grab	6-15-22	8:55	Lead	P	1			040A

Notes: * Carby only signed 1st page of COC's, MT 6/14/22
 * Per Jodi O'Mara AE 6/20/22

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: Carby	Refrigerated N/A
---	-----------------------	---------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: * Carby Duval	Date 6/17/22	Time 10:16	Received by Laboratory: 	Date 6/17/22	Time 10:16

Analytical Laboratory Group, Inc.

361 WEST FIFTH AVENUE
 EUGENE, OREGON 97401
 800-262-5973/541-485-8404 Fax 541-484-5995
 Email: alglabs@alglabsinc.com



Delivering more than just test results

Lines & MT checked & AE

CHAIN OF CUSTODY

Attention: Jodi O'Mara	Client: Mapleton School District
Phone: 541-268-4312	Address: 10868 E Mapleton Road
Email: jomara@mapleton.k12.or.us	City, State, Zip: Mapleton, OR 97453
Client Project:	Sampler: Print <i>Randy Duval*</i> Sampler: Signature

Client ID	Sample Matrix & Grab/Comp	Collection		Analysis Requested	Bottles -Lab Use Only				
		Date	Time		Type	#	Pres	T °C	Lab ID
20850100051CF22A	DW/Grab	6-15-22	855	Lead	P	1		N/A	041A
20850100052BF22A	DW/Grab	6-15-22	855	Lead	P	1			042A
20850100053DW22A	DW/Grab	6-15-22	859	Lead	P	1			043A
20850100054CF22A	DW/Grab	6-15-22	859	Lead	P	1			044A
20850100055BF22A	DW/Grab	6-15-22	859	Lead	P	1			045A
20850100056DW22A	DW/Grab	6-15-22	903	Lead	P	1			046A
20850100057CF22A	DW/Grab	6-15-22	903	Lead	P	1			047A
20850100058BF22A	DW/Grab	6-15-22	903	Lead	P	1			048A
20850100059DW22A	DW/Grab	6-15-22	905	Lead	P	1			049A
20850100060CF22A	DW/Grab	6-15-22	905	Lead	P	1			050A

Notes: *Carly only signed 1st page of COC's MT 6/17/22*
** Per Jodi O'Mara AE 6/20/22*
*** FM 6/20/22*

Preservation Check				
Lab ID	Date/Time	Pre-Preserved	pH	Tech

Turn Around Time Requested (Rush incurs a Surcharge): <input checked="" type="checkbox"/> NORMAL <input type="checkbox"/> RUSH	Shipped Via: <i>Carly</i>	Refrigerated <i>N/A</i>
---	------------------------------	----------------------------

Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by:	Date	Time	Received by:	Date	Time
Relinquished by: <i>* Carly Duval</i>	Date <i>6/17/22</i>	Time <i>10:16</i>	Received by Laboratory: <i>[Signature]</i>	Date <i>6/17/22</i>	Time <i>10:16</i>