

## Water Testing Results - Nestucca Valley Elementary

EPA Limit is 0.015 mg/l

Location	Test Date	Test Result
Kitchen	8/30/2019	0.001 mg/l
Room 1	8/30/2019	0.001 mg/l
Room 2	8/30/2019	0.001 mg/l
Kindergarten	8/30/2019	0.001 mg/l
Room 6	8/30/2019	0.001 mg/l

ND = Non Detect - Lead level is below the set detection limits

## Water Testing Results - Nestucca Valley Jr/Sr High

EPA Limit is 0.015 mg/l

Location	Test Date	Test Result
Kitchen	9/6/2019	0.001 mg/l
Boys Locker Room	9/6/2019	0.001 mg/l
Downstairs Bathroom Boys	9/16/2020	0.001 mg/l
Teacher's Lounge	9/16/2020	0.001 mg/l
Shop	9/16/2020	0.001 mg/l

ND = Non Detect - Lead level is below the set detection limits

## TEST REPORT

TO: Nestucca Valley School Dist. #101  
PO Box 99  
Cloverdale, OR 97122

09/04/2019

NESELE

PO#: 200034

PWS ID#: 4190595

### Collection Information

Date: 08/15/2019  
Time: 0700  
By: Nathan  
Lab #: 20190815-022  
Location: kitchen

### Lab Receipt Information

08/15/2019  
1154  
MM

Copy Sent to:  
DHS-  
Drinking Water Program

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead/Copper Testing									
Copper	SM3111 B	A	0.209		0.1	mg/l	1.0	08/26/2019	BEM
Lead	SM3113 B	A	ND		0.001	mg/l	0.015	08/30/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



Customer

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Nestucca Valley School Dist. #101  
PO Box 99  
Cloverdale, OR 97122

09/04/2019  
NESELE

PO#: 200034

PWS ID#: 4190595

### Collection Information

Date: 08/15/2019  
Time: 0701  
By: Nathan  
Lab #: 20190815-023  
Location: rm 1

### Lab Receipt Information

08/15/2019  
1154  
MM

Copy Sent to:  
DHS-  
Drinking Water Program

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead/Copper Testing									
Copper	SM3111 B	A	0.209		0.1	mg/l	1.0	08/26/2019	BEM
Lead	SM3113 B	A	ND		0.001	mg/l	0.015	08/30/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes". USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Nestucca Valley School Dist. #101  
PO Box 99  
Cloverdale, OR 97122

09/04/2019  
NESELE

PO#: 200034

PWS ID#: 4190595

### Collection Information

Date: 08/15/2019  
Time: 0701  
By: Nathan  
Lab #: 20190815-024  
Location: rm 2

### Lab Receipt Information

08/15/2019  
1154  
MM

Copy Sent to:  
DHS-  
Drinking Water Program

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead/Copper Testing									
Copper	SM3111 B	A	0.245		0.1	mg/l	1.0	08/26/2019	BEM
Lead	SM3113 B	A	ND		0.001	mg/l	0.015	08/30/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



Customer

## TEST REPORT

TO: Nestucca Valley School Dist. #101  
PO Box 99  
Cloverdale, OR 97122

09/04/2019

NESELE

PO#: 200034

PWS ID#: 4190595

### Collection Information

Date: 08/15/2019  
Time: 0705  
By: Nathan  
Lab #: 20190815-025  
Location: kindergarten

### Lab Receipt Information

08/15/2019  
1154  
MM

Copy Sent to:  
DHS-  
Drinking Water Program

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead/Copper Testing									
Copper	SM3111 B	A	0.203		0.1	mg/l	1.0	08/26/2019	BEM
Lead	SM3113 B	A	ND		0.001	mg/l	0.015	08/30/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



Customer

## TEST REPORT

TO: Nestucca Valley School Dist. #101  
PO Box 99  
Cloverdale, OR 97122

09/04/2019

NESELE

PO#: 200034

PWS ID#: 4190595

### Collection Information

Date: 08/15/2019  
Time: 0710  
By: Nathan  
Lab #: 20190815-026  
Location: rm 6

### Lab Receipt Information

08/15/2019  
1154  
MM

Copy Sent to:  
DHS-  
Drinking Water Program

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead/Copper Testing									
Copper	SM3111 B	A	0.216		0.1	mg/l	1.0	08/26/2019	BEM
Lead	SM3113 B	A	ND		0.001	mg/l	0.015	08/30/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Nestucca Valley School District #101  
PO Box 99  
Cloverdale, OR 97122

09/09/2019  
NESHIG

PO#: 200034

PWS ID#: 4190594

### Collection Information

Date: 08/15/2019  
Time: 0730  
By: Nathan  
Lab #: 20190815-016  
Location: kitchen

### Lab Receipt Information

08/15/2019  
1154  
MM

Copy Sent to:  
DHS-  
Drinking Water Program

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead/Copper Testing									
Copper	SM3111 B	A	ND		0.1	mg/l	1.0	08/19/2019	AS
Lead	SM3113 B	A	ND		0.001	mg/l	0.015	09/06/2019	BEM

ND- No Detection at @ MRL  
SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed  
EPA- "Methods for Chemical Analysis for Water and Wastes". USEPA  
MRL-"Method Reporting Limit"

\* Accreditation  
A- Waterlab Corporation, ORELAP 100039  
The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: 



## TEST REPORT

TO: Nestucca Valley School District #101  
PO Box 99  
Cloverdale, OR 97122

09/09/2019  
NESHIG

PO#: 200034

PWS ID#: 4190594

### Collection Information

Date: 08/15/2019  
Time: 0730  
By: Nathan  
Lab #: 20190815-017  
Location: boys locker room

### Lab Receipt Information

08/15/2019  
1154

MM

Copy Sent to:  
DHS-  
Drinking Water Program

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead/Copper Testing									
Copper	SM3111 B	A	ND		0.1	mg/l	1.0	08/19/2019	AS
Lead	SM3113 B	A	ND		0.001	mg/l	0.015	09/06/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Nestucca Valley School District #101  
PO Box 99  
Cloverdale, OR 97122

09/09/2019  
NESHIG

PO#: 200034

PWS ID#: 4190594

### Collection Information

Date: 08/15/2019  
Time: 0733  
By: Nathan  
Lab #: 20190815-018  
Location: downstairs bathroomboys

### Lab Receipt Information

08/15/2019  
1154  
MM

*Copy Sent to:  
DHS-  
Drinking Water Program*

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead/Copper Testing									
Copper	SM3111 B	A	ND		0.1	mg/l	1.0	08/19/2019	AS
Lead	SM3113 B	A	ND		0.001	mg/l	0.015	09/06/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Nestucca Valley School District #101  
PO Box 99  
Cloverdale, OR 97122

09/09/2019

NESHIG

PO#: 200034

PWS ID#: 4190594

### Collection Information

Date: 08/15/2019  
Time: 0736  
By: Nathan  
Lab #: 20190815-019  
Location: Teachers Lounge

### Lab Receipt Information

08/15/2019  
1154  
MM

Copy Sent to:  
DHS-  
Drinking Water Program

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead/Copper Testing									
Copper	SM3111 B	A	ND		0.1	mg/l	1.0	08/19/2019	AS
Lead	SM3113 B	A	ND		0.001	mg/l	0.015	09/06/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Nestucca Valley School District #101  
PO Box 99  
Cloverdale, OR 97122

09/09/2019

NESHIG

PO#: 200034

PWS ID#: 4190594

### Collection Information

Date: 08/15/2019  
Time: 0740  
By: Nathan  
Lab #: 20190815-020  
Location: shop

### Lab Receipt Information

08/15/2019  
1154  
MM

Copy Sent to:  
DHS-  
Drinking Water Program

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead/Copper Testing									
Copper	SM3111 B	A	ND		0.1	mg/l	1.0	08/19/2019	AS
Lead	SM3113 B	A	ND		0.001	mg/l	0.015	09/06/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

