

Nestucca Valley School District 101 Radon Testing Results

- The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Beaver Gym	Gym	Gym 1	9545452	12/17/2020	Duplicate	1.8
Beaver Gym	Gym	Gym 1	9545674	12/17/2020	Duplicate	1.7
Beaver Gym	Gym	Gym 2	9545307	12/17/2020	Detector kit	1.5
Beaver Gym	Gym	Gym 3	9539017	12/17/2020	Detector kit	1.7
Beaver Gym	Gym	Locker Room 1	9545391	12/17/2020	Detector kit	2.3
Beaver Gym	Gym	Locker Room 2	9545306	12/17/2020	Detector kit	2.2
Nestucca Valley Elementary	main	Room 1	9538384	12/18/2020	Detector kit	2.0
Nestucca Valley Elementary	main	Room 2	9539057	12/18/2020	Duplicate	2.7
Nestucca Valley Elementary	main	Room 2	9545321	12/18/2020	Duplicate	2.1
Nestucca Valley Elementary	main	Room 3	9539058	12/18/2020	Detector kit	2.8
Nestucca Valley Elementary	main	Room 4	9538316	12/18/2020	Detector kit	2.2
Nestucca Valley Elementary	main	Room 5	9539030	12/18/2020	Duplicate	2.2
Nestucca Valley Elementary	main	Room 5	9539040	12/18/2020	Duplicate	2.0
Nestucca Valley Elementary	main	Room 6	9539049	12/18/2020	Detector kit	3.6
Nestucca Valley Elementary	main	Room 7	9539053	12/18/2020	Detector kit	1.5
Nestucca Valley Elementary	main	Room 10	9539037	12/18/2020	Detector kit	1.6
Nestucca Valley Elementary	main	Room 11	9538389	12/18/2020	Detector kit	2.5
Nestucca Valley Elementary	main	Room 12	9538346	12/18/2020	Detector kit	1.4
Nestucca Valley Elementary	main	12 office 1	9539050	12/18/2020	Detector kit	1.6
Nestucca Valley Elementary	main	12 office 2	9538365	12/18/2020	Detector kit	1.0
Nestucca Valley Elementary	main	Room 13	9539048	12/18/2020	Detector kit	0.7
Nestucca Valley Elementary	main	Room 14	9539056	12/18/2020	Duplicate	1.0
Nestucca Valley Elementary	main	Room 14	9539042	12/18/2020	Duplicate	0.9
Nestucca Valley Elementary	main	Room 15	9539062	12/18/2020	Detector kit	0.9
Nestucca Valley Elementary	main	Gym A	9539039	12/18/2020	Detector kit	0.8
Nestucca Valley Elementary	main	Gym C	9545486	12/18/2020	Duplicate	1.0
Nestucca Valley Elementary	main	Gym C	9538376	12/18/2020	Duplicate	0.8
Nestucca Valley Elementary	main	Gym E	9545693	12/18/2020	Detector kit	0.8
Nestucca Valley Elementary	main	Teachers Lounge	9545669	12/18/2020	Detector kit	1.0
Nestucca Valley Jr/Sr High	High School	Entry Lobby	9538373	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	High School	Entry Lobby	9538315	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	High School	Room 101	9545450	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 105	9538363	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 118	9538387	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	High School	Room 118	9539036	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	High School	Room 118 office	9545351	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 119	9545460	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 119 office	9545460	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 121	9545416	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 123	9539021	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 123 office	9545392	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 124	9545666	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 125	9539023	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 126	9539034	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 128	9545347	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Room 130	9545394	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	High School	Room 130	9539025	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	High School	Admin Office	9538375	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Admin Conference	9545381	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	High School	Admin Conference	9545373	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	High School	Concessions	9539033	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Locker/Lobby	9545374	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Strut room	9538388	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	High School	Strut room	9538398	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	High School	Laundry Office	9545459	12/17/2020	Detector kit	0.7
Nestucca Valley Jr/Sr High	High School	Boys Locker Room	9538369	12/17/2020	Detector kit	0.9
Nestucca Valley Jr/Sr High	High School	Boys Locker Office	9538358	12/17/2020	Detector kit	0.3

- The EPA's recommended action level for radon is 4 pCi/L and will require mitigation by the district, followed by retesting.

Site Name	Building Name	Room Description (per floor plan)	Kit serial #	Date Sampled	Type of test	Results (pCi/L)
Nestucca Valley Jr/Sr High	High School	Boys Locker Team Room	9539022	12/17/2020	Detector kit	1.5
Nestucca Valley Jr/Sr High	High School	Girls Locker Room	9538351	12/17/2020	Duplicate	1.1
Nestucca Valley Jr/Sr High	High School	Girls Locker Room	9538382	12/17/2020	Duplicate	0.8
Nestucca Valley Jr/Sr High	High School	Girls Locker Office	9545348	12/17/2020	Detector kit	1.2
Nestucca Valley Jr/Sr High	High School	Girls Team Room	9538343	12/17/2020	Detector kit	1.1
Nestucca Valley Jr/Sr High	High School	Cafeteria 1	9545681	12/17/2020	Detector kit	0.6
Nestucca Valley Jr/Sr High	High School	Cafeteria 2	9545671	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	High School	Cafeteria Office	9545313	12/17/2020	Detector kit	2.8
Nestucca Valley Jr/Sr High	Shop	Connections Room	9538394	12/17/2020	Detector kit	12.2
Nestucca Valley Jr/Sr High	Shop	Drafting Room	9545473	12/17/2020	Duplicate	8.8
Nestucca Valley Jr/Sr High	Shop	Drafting Room	9545464	12/17/2020	Duplicate	8.2
Nestucca Valley Jr/Sr High	Shop	Shop Office	9539020	12/17/2020	Detector kit	7.9
Nestucca Valley Jr/Sr High	Shop	Weight Room A	9538395	12/17/2020	Detector kit	1.6
Nestucca Valley Jr/Sr High	Shop	Weight Room C	9545303	12/17/2020	Detector kit	1.7
Nestucca Valley Jr/Sr High	Field Building	Field A	9539035	12/17/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	Field Building	Field C	9539028	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	Field Building	Field C	9545380	12/17/2020	Duplicate	0.3
Nestucca Valley Jr/Sr High	Field Building	Field E	9538363	12/17/2020	Detector kit	0.3
Pre-Kindergarten Modular	Main	Room1	9539068	12/18/2020	Detector kit	0.3
Pre-Kindergarten Modular	Main	Room 2	9538390	12/18/2020	Duplicate	0.3
Pre-Kindergarten Modular	Main	Room 2	9539067	12/18/2020	Duplicate	0.3
Pre-Kindergarten Modular	Main	Room 3	9539041	12/18/2020	Detector kit	0.3
Pre-Kindergarten Modular	Main	Room 4	95390047	12/18/2020	Detector kit	0.3
Pre-Kindergarten Modular	Main	Room 5	9545327	12/18/2020	Detector kit	0.3
Pre-Kindergarten Modular	Main	Room 7	9545682	12/18/2020	Detector kit	0.3
Pre-Kindergarten Modular	Main	Room 8	9539045	12/18/2020	Detector kit	0.3
Pre-Kindergarten Modular	Main	Room 8A	9539051	12/18/2020	Duplicate	0.3
Pre-Kindergarten Modular	Main	Room 8A	9539055	12/18/2020	Duplicate	0.3
Pre-Kindergarten Modular	Main	Room 9	9538399	12/18/2020	Detector kit	0.3
Pre-Kindergarten Modular	Main	Room 10	9545463	12/18/2020	Detector kit	0.3
Pre-Kindergarten Modular	Main	Lobby	9545312	12/18/2020	Detector kit	0.3
Nestucca Valley Jr/Sr High	Shop	Classroom	9545579	1/28/2021	Duplicate	11.1
Nestucca Valley Jr/Sr High	Shop	Classroom	9545563	1/28/2021	Duplicate	10.2
Nestucca Valley Jr/Sr High	Shop	Office	9545589	1/28/2021	Detector kit	6.7
Nestucca Valley Jr/Sr High	Shop	Weight Room 1	9545576	1/28/2021	Detector kit	2.2
Nestucca Valley Jr/Sr High	Shop	Weight Room 2	9538438	1/28/2021	Detector kit	2.2