



Microbac Laboratories, Inc., New York Division
CERTIFICATE OF ANALYSIS

J0J1424

Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCES

Project Name: South Jeff H.S.

Fred Hauck
 20104 NYS Route 3
 Watertown, NY 13601

Project / PO Number: N/A
 Received: 10/16/2020
 Reported: 11/16/2020

Analytical Testing Parameters

Client Sample ID:	56	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/14/2020 6:44
Lab Sample ID:	J0J1424-01		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0136	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1037	LLW

Client Sample ID:	57	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/14/2020 6:44
Lab Sample ID:	J0J1424-02		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.345	0.015 AL	0.0200	mg/L	D	11/03/20 1320	11/05/20 2014	LLW

Client Sample ID:	25	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/14/2020 7:10
Lab Sample ID:	J0J1424-03		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0031	0.015 AL	0.0010	mg/L		11/03/20 0858	11/04/20 1122	LLW

Client Sample ID:	74	Collected By:	RF - Client
Sample Matrix:	Drinking Water	Collection Date:	10/14/2020 6:50
Lab Sample ID:	J0J1424-04		

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0360	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1044	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 33	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-05		Collection Date: 10/14/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0237	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1046	LLW

Client Sample ID: 94	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-06		Collection Date: 10/14/2020 7:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0089	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1047	LLW

Client Sample ID: 84	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-07		Collection Date: 10/14/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0202	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1049	LLW

Client Sample ID: 58	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-08		Collection Date: 10/14/2020 6:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1055	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 85	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-09		Collection Date: 10/14/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0275	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1057	LLW

Client Sample ID: 35	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-10		Collection Date: 10/14/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0399	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1058	LLW

Client Sample ID: 28	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-11		Collection Date: 10/14/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0075	0.015 AL	0.0051	mg/L	D	11/03/20 0858	11/04/20 2026	LLW

Client Sample ID: 36	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-12		Collection Date: 10/14/2020 7:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1102	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 83	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-13		Collection Date: 10/14/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0144	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1106	LLW

Client Sample ID: 103	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-14		Collection Date: 10/14/2020 6:00

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1108	LLW

Client Sample ID: 86	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-15		Collection Date: 10/14/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0084	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1109	LLW

Client Sample ID: 37	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-16		Collection Date: 10/14/2020 7:03

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0483	0.015 AL	0.0010	mg/L		11/03/20 1320	11/04/20 1051	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 102	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:35
Lab Sample ID: J0J1424-17	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0090	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1111	LLW

Client Sample ID: 99	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:33
Lab Sample ID: J0J1424-18	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0208	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1117	LLW

Client Sample ID: 68	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:55
Lab Sample ID: J0J1424-19	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0222	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1119	LLW

Client Sample ID: 66	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 6:55
Lab Sample ID: J0J1424-20	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0150	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1120	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 75	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-21		Collection Date: 10/14/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0168	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1122	LLW

Client Sample ID: 70	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-22		Collection Date: 10/14/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0238	0.015 AL	0.0010	mg/L		11/03/20 0858	11/03/20 1124	LLW

Client Sample ID: 55B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-23		Collection Date: 10/14/2020 6:44

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0038	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1133	LLW

Client Sample ID: 67	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-24		Collection Date: 10/14/2020 6:55

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0219	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1139	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 73	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-25		Collection Date: 10/14/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0273	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1141	LLW

Client Sample ID: 29	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-26		Collection Date: 10/14/2020 7:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0127	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1142	LLW

Client Sample ID: 55A	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-27		Collection Date: 10/14/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0206	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1144	LLW

Client Sample ID: 54	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-28		Collection Date: 10/14/2020 6:45

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0851	0.015 AL	0.0020	mg/L	D	11/03/20 1320	11/05/20 2018	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 53	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-29		Collection Date: 10/14/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1146	LLW

Client Sample ID: 51	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-30		Collection Date: 10/14/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0112	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1152	LLW

Client Sample ID: 61	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-31		Collection Date: 10/14/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0014	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1153	LLW

Client Sample ID: 72	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-32		Collection Date: 10/14/2020 6:53

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0124	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1155	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 71	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-33		Collection Date: 10/14/2020 6:52

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0037	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1157	LLW

Client Sample ID: 59	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-34		Collection Date: 10/14/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0021	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1159	LLW

Client Sample ID: 76	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-35		Collection Date: 10/14/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0116	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1202	LLW

Client Sample ID: 77	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-36		Collection Date: 10/14/2020 6:50

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0070	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1204	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 91B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-37		Collection Date: 10/14/2020 6:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0179	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1206	LLW

Client Sample ID: 90	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-38		Collection Date: 10/14/2020 6:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0281	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1208	LLW

Client Sample ID: 88	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-39		Collection Date: 10/14/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0347	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1213	LLW

Client Sample ID: 91A	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-40		Collection Date: 10/14/2020 6:24

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0143	0.015 AL	0.0010	mg/L		11/03/20 0910	11/03/20 1215	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 87	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-41		Collection Date: 10/14/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0456	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1555	LLW

Client Sample ID: 49	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-42		Collection Date: 10/14/2020 6:40

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0162	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1600	LLW

Client Sample ID: 101	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-43		Collection Date: 10/14/2020 6:34

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0052	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1602	LLW

Client Sample ID: 97	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-44		Collection Date: 10/14/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0052	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1604	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 45	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-45		Collection Date: 10/14/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	<0.0010	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1606	LLW

Client Sample ID: 50	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-46		Collection Date: 10/14/2020 6:38

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0095	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1607	LLW

Client Sample ID: 96	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-47		Collection Date: 10/14/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0197	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1613	LLW

Client Sample ID: 100	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-48		Collection Date: 10/14/2020 6:33

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0052	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1615	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 38	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-49		Collection Date: 10/14/2020 6:28

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0032	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1617	LLW

Client Sample ID: 40	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-50		Collection Date: 10/14/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0088	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1618	LLW

Client Sample ID: 52	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-51		Collection Date: 10/14/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0058	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1620	LLW

Client Sample ID: 98	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-52		Collection Date: 10/14/2020 6:30

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0073	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1624	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 48	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-53		Collection Date: 10/14/2020 6:37

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0039	0.015 AL	0.0010	mg/L		11/03/20 1342	11/04/20 2030	LLW

Client Sample ID: 46	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-54		Collection Date: 10/14/2020 6:35

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0104	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1628	LLW

Client Sample ID: 47	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-55		Collection Date: 10/14/2020 6:36

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0150	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1629	LLW

Client Sample ID: 89	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-56		Collection Date: 10/14/2020 6:25

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0362	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1635	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 1	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-57		Collection Date: 10/14/2020 6:05

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0057	0.015 AL	0.0010	mg/L		11/04/20 1319	11/05/20 1943	LLW

Client Sample ID: 5	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-58		Collection Date: 10/14/2020 6:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0012	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1637	LLW

Client Sample ID: 3	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-59		Collection Date: 10/14/2020 6:06

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0101	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1639	LLW

Client Sample ID: 6	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-60		Collection Date: 10/14/2020 6:08

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0019	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1640	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 4	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-61		Collection Date: 10/14/2020 6:07

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0128	0.015 AL	0.0010	mg/L		11/03/20 1342	11/03/20 1642	LLW

Client Sample ID: 19	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-62		Collection Date: 10/14/2020 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0094	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1651	LLW

Client Sample ID: 8B	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-63		Collection Date: 10/14/2020 6:11

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1657	LLW

Client Sample ID: 8A	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-64		Collection Date: 10/14/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0087	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1659	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 9	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-65		Collection Date: 10/14/2020 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0020	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1701	LLW

Client Sample ID: 7	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-66		Collection Date: 10/14/2020 6:10

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0048	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1702	LLW

Client Sample ID: 20	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-67		Collection Date: 10/14/2020 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0107	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1704	LLW

Client Sample ID: 18	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-68		Collection Date: 10/14/2020 6:16

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0026	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1710	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 15	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-69		Collection Date: 10/14/2020 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0046	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1712	LLW

Client Sample ID: 14	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-70		Collection Date: 10/14/2020 6:14

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0052	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1713	LLW

Client Sample ID: 10	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-71		Collection Date: 10/14/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0079	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1715	LLW

Client Sample ID: 11	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-72		Collection Date: 10/14/2020 6:15

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0059	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1717	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 23	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-73		Collection Date: 10/14/2020 6:21

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0262	0.015 AL	0.0010	mg/L		11/03/20 1351	11/03/20 1747	LLW

Client Sample ID: 24	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-74		Collection Date: 10/14/2020 6:22

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0035	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1721	LLW

Client Sample ID: 22	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-75		Collection Date: 10/14/2020 6:20

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.152	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1723	LLW

Client Sample ID: 21	Sample Matrix: Drinking Water	Collected By: RF - Client
Lab Sample ID: J0J1424-76		Collection Date: 10/14/2020 6:19

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0079	0.015 AL	0.0010	mg/L		11/03/20 1344	11/03/20 1724	LLW



Microbac Laboratories, Inc., New York Division

CERTIFICATE OF ANALYSIS

J0J1424

Client Sample ID: 26	Collected By: RF - Client
Sample Matrix: Drinking Water	Collection Date: 10/14/2020 7:10
Lab Sample ID: J0J1424-77	

Analyses Subcontracted to: Microbac Laboratories, Inc. - Dayville

Metals Total by ICPMS	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: EPA 200.8, Rv. 5.4 (1994)								
Lead	0.0054	0.015 AL	0.0010	mg/L		11/03/20 1351	11/03/20 1812	LLW

Results in bold have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- AL: US EPA Action Level
- D: The sample was diluted due to matrix interference.
- mg/L: Milligrams per Liter
- RL: Reporting Limit

Project Requested Certification(s)

Microbac Laboratories, Inc. - Dayville 11549	New York State Department of Health
Microbac Laboratories, Inc., New York Division NY Lab ID No.: 10795	New York State Department of Health

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.

Reviewed and Approved By:

Jennifer Walker
 Operations Manager
 Reported: 11/16/2020 08:05

SOUTH JEFF H.S.

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	Lead Testing	PO#:	
Quote ID:		Date Req.:	
Rush TAT Bus. Days:	< 2-5 5-7 7-10		
Carbon Copy:	Yes		
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com	
Fax Results:	Yes		

Sample Information		Analysis Requested		Receiving Info (Lab Use Only)	
Description/Location	Date	Time	Matrix	Container Material	Container Size (in MI)
516	10/14	6:44	DW	Plastic	250 ml
57		6:44		HNO3	
25		7:10			
74		6:50			
33		6:10			
94		7:01			
84		6:55			
58		6:48			
85		6:55			
35		6:58			
28		7:10			
30		7:05			
83		6:55			
103		6:00			
86		6:50			
37		7:03			
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					

Number of Containers for Analysis Requested	Date/Time	Comments
1	10/14/2010	
	10/16/2010	1700

Sampled:	<i>[Signature]</i>	Print Name and Company
Received:	<i>[Signature]</i>	
Received:	<i>[Signature]</i>	

J 0 J 1 4 2 4
 Jefferson-Lewis-Hamilton-Herkimer-Oneida BOCE
 PM: Shannon Weeks

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone:(607)753-3403 Fax:(607)753-3415
 NY #10795, EPA #NY00935

Microbac Laboratories, Inc. Samples must be returned on ice
CHAIN OF CUSTODY
 MNY Workorder # _____

South Jeff U.S.

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Bocces					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Health/Safety Dept.					Sample Temp:	YES NO
Phone:	315-779-7000					Cooler Seal:	YES NO
Project:	Lead Testing					Pickup:	YES NO
Quote ID:		PO#:				Dropoff:	C W
Rush TAT Bus. Days:	2-5 5-7 7-10	Date Req.:				Accepted?	YES NO
Carbon Copy:	Yes					Container Material	
Email Results:	Yes					Container Size (in MI)	
Fax Results:	Yes					Preservative	
Sample Information						Comments/Field Data	
Description/Location	Date	Time	Matrix	Type	Number of Containers for Analysis Requested		
102	10/14	6:35	DW	DW	1		
199		6:33					
608		6:55					
606		6:55					
75		6:50					
70		6:52					
55B		6:44					
67		6:55					
73		6:53					
29		7:10					
55A		6:45					
54		6:45					
53		6:40					
51		6:40					
61		6:50					
72		6:53					
71		6:52					
59		6:50					
71a		6:50					
77		6:50					
Sampled:		Print Name and Company		Date/Time		Comments	
<i>[Signature]</i>		<i>[Signature]</i>		10/14/2020			
Received:							
<i>[Signature]</i>							
Received:							
<i>[Signature]</i>							

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

SOUTH JEFF H.S.

Client Information		Billing/Invoice:	
Name:	Jeff/Lew Boces		
Address:	20104 NYS Route 3		
Contact:	Health/Safety Dept.		
Phone:	315-779-7000		
Project:	Lead Testing	PO#:	
Quote ID:		Date Req.:	
Rush TAT Bus. Days:	2-5 5-7 7-10		
Carbon Copy:	Yes		
Email Results:	Yes		
Fax Results:	Yes		
	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com		

Sample Information			Analysis Requested			Receiving Info (Lab Use Only)		
Description/Location	Date	Time	Matrix Type	Number of Containers for Analysis Requested	Comments/Field Data	Ice:	YES	NO
91B	10/14	6:24	DW	1				
90		6:24						
88		6:25						
91A		6:24						
87		6:25						
49		6:40						
101		6:34						
97		6:30						
45		6:38						
50		6:38						
96		6:27						
100		6:33						
38		6:28						
40		6:30						
52		6:35						
98		6:30						
48		6:57						
46		6:35						
47		6:26						
59		6:25						

Sampled:	Received:	Received:	Date/Time	Comments

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document, you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.

3821 Buck Drive
 Cortland NY 13045
 Phone: (607)753-3403 Fax: (607)753-3415
 NY #10795, EPA #NY00935

South Jeff H.S.
 Jeff

Client Information		Billing/Invoice:		Analysis Requested		Receiving Info (Lab Use Only)	
Name:	Jeff/Lew Boces					Ice:	YES NO
Address:	20104 NYS Route 3					Cooler:	YES NO
Contact:	Health/Safety Dept.					Sample Temp:	YES NO
Phone:	315-779-7000					Cooler Seal:	YES NO
Project:	Lead Testing	PO#:				Pickup:	YES NO
Quote ID:		Date Req.:				Dropoff:	C W
Rush TAT Bus. Days:	2-5 5-7 7-10					Accepted?	YES NO
Carbon Copy:	Yes					Container Material	
Email Results:	Yes	rfilley@boces.com, fhauck@boces.com, lshaw@boces.com				Container Size (in MI)	
Fax Results:	Yes					Preservative	
Sample Information		Number of Containers for Analysis Requested		Comments/Field Data			
Description/Location	Date	Time	Matrix Type				
1	10/14	6005	DW				
2		6007					
3		6006					
4		6008					
5		6007					
6		6010					
7		6011					
8		6010					
9		6014					
10		6010					
11		6019					
12		6010					
13		6010					
14		6014					
15		6015					
16		6015					
17		6021					
18		6022					
19		6020					
20		6019					

Total Lead (EPA 200.8)
 Plastic
 250 ml
 HINO3
 1

Date/Time: 10/14/2010

Print Name and Company: Raymond Furey

Sampled: Raymond Furey

Received:

Received:

Microbac Laboratories (MNY) may be unable to perform a portion of the requested testing in which case we will subcontract the analysis to another accredited laboratory. By signing this document you are attesting that you have been informed by MNY of the intent to subcontract and are in agreement with this action.